

## Building Assessment Referral Response

|  |  |
|--|--|
| <b>Application Number:</b>             | DA2022/2232  |
| <b>Proposed Development:</b>           | Alterations and additions to a mixed use building.   |
| <b>Date:</b>                           | 10/01/2023   |
| <b>To:</b>                             | Phil Lane  |
| <b>Land to be developed (Address):</b> | Lot 1 DP 329155 , 154 Sydney Road FAIRLIGHT NSW 2094 |

### Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

### Officer comments

The application has been investigated with respect to aspects relevant to the Building Certification and Fire Safety Department.

In this regard the following Report is required to be submitted to enable further consideration of the Development Application.

*A 'Building Code of Australia (BCA) Assessment Report' / 'Fire Audit Report' from an appropriately qualified Registered Certifier\* will need to be submitted addressing the following:*

*The report is to detail the extent to which the existing building (relevant affected parts) does or does not comply with the deemed-to satisfy provisions of Sections C, D, E and F of the Building Code of Australia. The report is to also provide recommendations with respect to the existing building / works required to ensure that the specified measures and facilities contained in the existing building, including any modifications to be made by the proposed development are appropriate for its intended use to:*

- restrict the spread of fire from the building to other buildings nearby, and*
- protect persons using the building, and to facilitate their egress from the building in the event of fire, and*
- where appropriate, provide access for persons with a disability, and*
- provide facilities and services appropriate for the development*

*\*To be regarded as an "appropriately qualified registered certifier" the certifier must hold the relevant level of accreditation that would enable the certifier to issue a construction certificate for the subject building.*

*Reason: To ensure adequate provision is made for Health, Amenity, access and Fire safety for building occupant health and safety*

The proposal is therefore unsupported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

**Recommended Building Assessment Conditions**

Nil.