

Natural Environment Referral Response - Riparian

Application Number:	DA2019/0426
To:	Kelsey Wilkes
Land to be developed (Address):	Lot B DP 76733 , 1226 Pittwater Road NARRABEEN NSW 2101

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land, and located within 40 metres of land, containing a watercourse, or
- All Development Applications on land containing a wetland, or located within 100m of land containing a wetland,
- All Development Applications on land that is mapped as "DCP Map Waterways and Riparian Land".

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The proposed development is supported with conditions to comply with the SEPP Coastal Management. The development must meet sediment and erosion control conditions throughout the duration of the works. The proposed development has been assessed, based on compliance with applied conditions, to cause no adverse impact on the integrity and resilience of the biophysical and ecological environment of the lagoon, particularly water quality.

Referral Body Recommendation

Recommended for approval, subject to conditions

Recommended Natural Environment Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004).

Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site (DACNED06)