

## Building Assessment Referral Response

<b>Application Number:</b>	DA2020/0263
<b>Date:</b>	23/04/2020
<b>To:</b>	Maxwell Duncan
<b>Land to be developed (Address):</b>	Lot 4 DP 547022 , 59 Myoora Road TERREY HILLS NSW 2084

### Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

### Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Building Assessment Conditions

#### **CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE**

#### **Change of Use/ Fire Safety - Egress and Essential Services Upgrade**

The existing levels of essential fire safety measures and egress provisions are to be upgraded to achieve an adequate level of fire safety in accordance with the provisions of clause 94 of the Environmental Planning and Assessment Regulation 2000 and Parts C,D and E of Volume 1 of the Building Code of Australia.

Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for Access, Fire safety and for building occupant safety son>.