

Natural Environment Referral Response - Riparian

Application Number:	DA2022/0783
Date:	11/07/2022
To:	Gareth David
Land to be developed (Address):	Lot 3 DP 1115877 , 53 B Warriewood Road WARRIEWOOD NSW 2102

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land, and located within 40 metres of land, containing a watercourse, or
- All Development Applications on land containing a wetland, or located within 100m of land containing a wetland,
- All Development Applications on land that is mapped as “DCP Map Waterways and Riparian Land”.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The development application DA2022/0783 is for the construction of a new dwelling Lot 11, 53B Warriewood Road Warriewood.

This application has been assessed against relevant legislation and policy relating to waterways, riparian areas and groundwater. Lot 11, 53B Warriewood Road Warriewood is not located within 40 metres of Narrabeen Creek. Therefore the proposal is supported with conditions.

Refer to the Coast and Catchments Team comments as the development site is tagged by the SEPP (Resilience and Hazards) 2021, (sections 2.8 & 2.12).

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Installation and Maintenance of Sediment and Erosion Controls

Council proactively regulates construction sites for sediment management.

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban

Stormwater: Soils and Construction' (2004) and the Erosion and Sediment Control Plan prepared by <INSERT> prior to commencement of any other works on site.

Erosion and sediment controls are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and vegetation cover has been re-established across 70 percent of the site, and the remaining areas have been stabilised with ongoing measures such as jute mesh or matting.

Reason: Protection of the receiving environment.