

Landscape Referral Response

Application Number:	DA2024/0295
Date:	18/04/2024
Proposed Development:	Construction of a boat shed, inclinor and retaining walls
Responsible Officer:	Stephanie Gelder
Land to be developed (Address):	Lot 3 DP 517452 , 186 McCarrs Creek Road CHURCH POINT NSW 2105 Lot LIC 585801 , 186 McCarrs Creek Road CHURCH POINT NSW 2105

Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- Mixed use developments containing three or more residential dwellings.
- New Dwellings or

Officer comments

Council's Landscape Referral is assessed against the Pittwater Local Environment Plan (PLEP) clause C4 zone Environmental Living, and the following Pittwater 21 Development Control Plan (PDCP) controls (but not limited to): B4.22 Preservation of Trees and Bushland Vegetation; C1.1 Landscaping; and D4 Church Point and Bayview Locality.

The site is located in the C4 Environmental Living zone, requiring development to achieve a scale integrated with the landform and landscape, and to minimise impact on the natural environment with ecological, scientific or aesthetic values, including the retention of natural landscape features and existing trees, to satisfy the landscape objectives of the C4 Environmental Living zone.

It is noted that the rear garden, with ferns and palms, landscaped areas, retaining walls were destroyed during a landslide in 2021. The existing boatshed structure was considered unstable, and was demolished shortly thereafter.

There appears to be no prescribed trees located upon the property, and an aerial map investigation indicates that no native canopy trees were present in the foreshore area from 2009 onwards. A Landscape Plan is submitted with the application providing re-establishment of landscape planted areas and Landscape Referral raise no concerns, subject to conditions.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Landscape Conditions:

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Tree and Vegetation Protection

a) Existing trees and vegetation shall be retained and protected, including:

- i) all prescribed trees within the site,
- ii) all trees and vegetation located on adjoining properties,
- iii) all trees and vegetation within the road reserve.

b) Tree protection shall be undertaken as follows:

- i) tree protection shall be in accordance with AS4970-2009 Protection of trees on development sites,
- ii) the following arboricultural requirements shall be adhered to unless authorised by an Arborist with minimum AQF level 5 qualifications: existing ground levels shall be maintained within the tree protection zone of trees to be retained; removal of existing tree roots at or >25mm (Ø) diameter is not permitted; no excavated material, building material storage, site facilities, nor landscape materials are to be placed within the canopy dripline of trees and other vegetation required to be retained; and structures are to bridge tree roots at or >25mm (Ø) diameter,
- iii) the activities listed in section 4.2 of AS4970-2009 Protection of trees on development sites, shall not occur within the tree protection zone of any tree on the lot or any tree on an adjoining site,
- iv) tree pruning from within the site to enable approved works shall not exceed 10% of any tree canopy, and shall be in accordance with AS4373-2007 Pruning of amenity trees,
- v) the tree protection measures specified in this clause must: i) be in place before work commences on the site, and ii) be maintained in good condition during the construction period, and iii) remain in place for the duration of the construction works.

The Principal Certifier must ensure that:

- c) The arboricultural works listed in a) and b) are undertaken as compliant to AS4970-2009 Protection of trees on development sites.

Reason: Tree and vegetation protection.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Landscape Completion

Landscape works are to be implemented in accordance with the approved Landscape Plan, and inclusive of the following conditions:

- a) landscape works are to be contained within the legal property boundaries,
- b) tree, shrub and groundcover planting shall be installed as indicated on the approved Landscape Plan, unless otherwise imposed by conditions,
- c) the nominated Rhipidolepis Oriental Pearl species is not to be planted and shall be substituted with a non self-seeding shrubs of similar size and form.

Prior to the issue of an Occupation Certificate, details (from a landscape architect, landscape designer or qualified horticulturalist) shall be submitted to the Principal Certifier, certifying that the landscape works have been completed in accordance with any conditions of consent.

Reason: Environmental amenity.

ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

Landscape Maintenance

If any landscape materials/components or planting under this consent fails, they are to be replaced with similar materials/components. Trees, shrubs and groundcovers required to be planted under this consent are to be mulched, watered and fertilised as required at the time of planting. If any tree, shrub or groundcover required to be planted under this consent fails, they are to be replaced with similar species to maintain the landscape theme and be generally in accordance with the approved Landscape Plan and any conditions of consent.

The approved landscape area shall in perpetuity remain as planting under the development consent, and shall not be replaced with any hard paved surfaces or structures.

Reason: To maintain local environmental amenity.