

Roger Fenwick Bush Fire Consultant
PO Box 86B
Kettering Tas 7155

Sue Connor
1714 Pittwater Rd
Bayview NSW 2104

sue@sueconnor.com.au

Dear Sue,


Section 4.55 (formerly s96) Amendments – 256 Whale Beach Road, Whale Beach

I am the author of the report 1807.PAN.WHA.WHA1.0 which was used and accepted in support of a DA for alterations and additions at the above site.

I have inspected the proposed new plans, and confirm that all of the changes comply with the recommended construction standard. None of the standards have changed between the date of preparation of that report and now. The changes can all be accepted as proposed as the BAL rating remains at 12.5 for the residence. That continues to include the specification that decks be constructed to BAL-29 standards.

Please do not hesitate to contact me if you would like to clarify any of the contents of this letter.

Yours sincerely,

A handwritten signature in dark ink, appearing to be 'R. Fenwick', followed by a period.

Roger Fenwick
27 June 2019