

Engineering Referral Response

Application Number:	DA2023/0010
Proposed Development:	Alterations and additions to a dwelling house including garage
Date:	01/02/2023
To:	Jordan Howard
Land to be developed (Address):	Lot 8 DP 1011074 , 9 Maybanke Court MONA VALE NSW 2103

Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m² or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

Officer comments

The grade of the ramp from existing garage to existing concrete slab is approximately 23%. This grade shall be no more than 12.5% to avoid vehicle scraping as per AS/NZS 2890.1:2004.

The application can not be supported due to lack of information to assess B6 of the DCP.

The proposal is therefore unsupported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Engineering Conditions:

Nil.