

Landscape Referral Response

| | |
|--|--|
| Application Number: | DA2020/0733 |
| Date: | 19/08/2020 |
| Responsible Officer: | Rhiannon McLardy |
| Land to be developed (Address): | Lot 269 DP 215538 , 14 Wilde Avenue KILLARNEY HEIGHTS NSW 2087 |

Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- Mixed use developments containing three or more residential dwellings.
- New Dwellings or

Officer comments

The plans indicate several small trees to be removed to accommodate the proposed works. No objections are raised to the proposed removals subject to conditions.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Landscape Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Tree protection

- (a) Existing trees which must be retained
 - i) All trees not indicated for removal on the approved plans, unless exempt under relevant planning instruments or legislation
 - ii) Trees located on adjoining land
- (b) Tree protection
 - i) No tree roots greater than 25mm diameter are to be cut from protected trees unless authorised by a qualified Arborist on site.
 - ii) All structures are to bridge tree roots greater than 25mm diameter unless directed otherwise by a qualified Arborist on site.
 - iii) All tree protection to be in accordance with AS4970-2009 Protection of trees on development sites, with particular reference to Section 4 Tree Protection Measures.
 - iv) All tree pruning within the subject site is to be in accordance with WDCP2011 Clause E1 Private Property Tree Management and AS 4373 Pruning of amenity trees
 - v) All tree protection measures, including fencing, are to be in place prior to

commencement of works.

Reason: To ensure compliance with the requirement to retain and protect significant planting on the site.

**CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE
OCCUPATION CERTIFICATE**

Required Planting

Trees shall be planted in accordance with the following schedule:

| Minimum No. of Trees Required. | Species | Location | Minimum Pot Size |
|---|--|-----------------|-----------------------------|
| 1 | Tree species capable of attaining a minimum height of 5 metres at maturity | 1 x Front Yard | 200mm |

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To maintain environmental amenity.