

Landscape Referral Response

Application Number:	DA2018/1814
Date:	02/01/2019
Responsible Officer:	Adam Urbancic
Land to be developed (Address):	Lot 347 DP 11162 , 17 Waterview Street SEAFORTH NSW 2092

Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- Mixed use developments containing three or more residential dwellings.
- New Dwellings or

Officer comments

The landscape component of the proposal is acceptable subject to the protection of existing trees and vegetation, and the completion of landscaping.

Council's Landscape section have assessed the application against the landscape controls of Manly DCP 2013, section 3: General Principles of Development, and section 4: Development Controls and Development Types.

Referral Body Recommendation

Recommended for approval, subject to conditions

Refusal comments

Recommended Landscape Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Required canopy tree planting

Details are to be provided of the existing or proposed native trees for the site which are typically expected to reach a height at maturity of 10 metres, to bring the proposal into compliance with Figure 37 of the Manly Development Control Plan 2013. Details of new planting are to include appropriate siting and pot size (minimum of 75 litres) in accordance with section 2.1.3 of the Manly Development Control Plan 2013, and schedule 4, Part B, Native Tree Selection.

Details are to be submitted with the Construction Certificate to the satisfaction of the Certifying

Authority.

Reason: this is to ensure the planting of endemic trees back onto the site.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Tree and vegetation protection

A) Existing trees and vegetation shall be retained and protected as follows:

- i) all trees and vegetation within the site, nominated on the plans for retention, excluding exempt trees under the relevant planning instruments of legislation,
- ii) all other trees and vegetation located on adjoining properties,
- iii) all road reserve trees and vegetation,

B) Tree protection shall be generally undertaken as follows:

- i) all tree protection shall be in accordance with AS4970- 2009 Protection of Trees on Development Sites, with particular reference to Section 4,
- ii) removal of existing tree roots greater than 25mm is not permitted without consultation with a AQF Level 5 Arborist,
- iii) any tree roots exposed during excavation with a diameter greater than 25mm within the tree protection zone must be assessed by an Arborist. Details including photographic evidence of works undertaken shall be submitted by an AQF Level 5 Arborist to the Certifying Authority,
- iv) to minimise the impact on trees and vegetation to be retained and protected, no excavated material, building material storage, site facilities, nor landscape materials are to be placed within the canopy dripline of trees and other vegetation required to be retained,
- v) no tree roots greater than 25mm diameter are to be cut from protected trees unless authorised by a Project Arborist on site,
- vi) all structures are to bridge tree roots greater than 25mm diameter unless directed by a AQF Level 5 Arborist on site,
- vii) excavation for stormwater lines is not permitted within the tree protection zone, without consultation with a AQF Level 5 Arborist,
- viii) should either or all of v) vi) and vii) occur during site establishment and construction works, a AQF Level 5 Arborist shall provide recommendations for tree protection measures. Details including photographic evidence of works undertaken shall be submitted by the Arborist to the Certifying Authority,
- ix) tree pruning to enable construction shall not exceed 10% of any tree canopy, and shall be in accordance with AS4373-2009 Pruning of Amenity Trees.

Reason: to retain and protect significant planting on development and adjoining sites.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Landscape works

Landscaping is to be implemented in accordance with the plans DA100, DA200, DA400, DA500, and DA501, prepared by Grant Clement Landscape Architect, all issue A, inclusive of the following requirement:

- i) the proposed native screen planting along the common boundary with No. 11, shall consist of species capable of attaining 3 metres in height, and shall be planted no more than 1 metre apart, and at pot size 300mm minimum.

Prior to the issue of an Occupation Certificate, a landscape report prepared by a landscape architect or landscape designer shall be submitted to the Certifying Authority, certifying that the landscape works have been completed in accordance with the plans and inclusive of any conditions of consent.

Reason: to ensure that the landscape treatments are installed to provide landscape amenity.

ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

Landscape maintenance

All landscape components are to be maintained for the life of the development.

A maintenance program is to be established. If any landscape materials/components or planting under this consent fails, they are to be replaced with similar materials/components and species to maintain the landscape theme in accordance with the landscape plan.

Reason: to maintain local environmental amenity and ensure landscaping continues to soften the built form.

Environmental and priority weed control

All weeds are to be removed and controlled in accordance with the Biodiversity Conservation Act 2016.

Reason: preservation of environmental amenity.