

TELEPHONE: (02) 9394 6932
EMAIL: development@ausgrid.com.au
REFERENCE: TRIM 2017/31/313

ATTN:

PO Box 82
Manly NSW 1655

570 George Street
Sydney NSW 2000
All mail to GPO Box 4009
Sydney NSW 2001
T +61 2 131 525
F +61 2 9269 2830
www.ausgrid.com.au

Re: DA2020/1682 - 26 JEANETTE AVENUE MONA VALE - First-floor addition will comprise of a total of 4 bedrooms, the main having a large WIR and en-suite bathroom.

I refer to Northern Beaches Council development application DA2020/1682.

This letter is Ausgrid's response under clause 45(2) of the State Environmental planning Policy (Infrastructure) 2007.

The assessment and evaluation of environmental impacts for a new development consent (or where a development consent is modified) is undertaken in accordance with requirements of Section 79C of the Environmental Planning and Assessment Act 1979. One of the obligations upon consent authorities, such as local councils, is to consider the suitability of the site for the development which can include a consideration of whether the proposal is compatible with the surrounding land uses and the existing environment.

In this regard, Ausgrid requires that due consideration be given to the compatibility of proposed development with existing Ausgrid infrastructure, particularly in relation to risks of electrocution, fire risks, Electric & Magnetic Fields (EMFs), noise, visual amenity and other matters that may impact on Ausgrid or the development.

With Regard to: First-floor addition will comprise of a total of 4 bedrooms, the main having a large WIR and en-suite bathroom at 26 JEANETTE AVENUE MONA VALE

- Plans as of 041220_26 Jeanette Ave_V1
- Plans as of 041220_26 Jeanette Ave_V2
- Plans as of 041220_26 Jeanette Ave_V3

Ausgrid consents to the above mentioned development subject to the following conditions:-

Proximity to Existing Network Assets

Substation

There are existing electricity substation assets within 26 Jeanette Ave.

The substation ventilation openings, including substation duct openings and louvered panels, must be separated from building air intake and exhaust openings, natural ventilation openings and boundaries of adjacent allotments, by separation distances which meet the requirements of all relevant authorities, building regulations, BCA and Australian Standards including AS 1668.2: The use of ventilation and air-conditioning in buildings - Mechanical ventilation in buildings.

In addition to above, Ausgrid requires the substation ventilation openings, including duct openings and louvered panels, to be separated from building ventilation system air intake and exhaust openings, including those on buildings on adjacent allotments, by not less than 6 metres.

Any portion of a building other than a BCA class 10a structure constructed from non combustible materials, which is not sheltered by a non-ignitable blast-resisting barrier and is within 3 metres in any direction from the housing of a kiosk substation, is required to have a Fire Resistance Level (FRL) of not less than 120/120/120. Openable or fixed windows or glass blockwork or similar, irrespective of their fire rating, are not permitted within 3 metres in any direction from the housing of a kiosk substation, unless they are sheltered by a non-ignitable blast resisting barrier.

The development must comply with both the Reference Levels and the precautionary requirements of the ICNIRP Guidelines for Limiting Exposure to Time-varying Electric and Magnetic Fields (1 HZ – 100 kHz) (ICNIRP 2010).

For further details on fire segregation requirements refer to Ausgrid's Network Standard 141.

Existing Ausgrid easements, leases and/or right of ways must be maintained at all times to ensure 24 hour access. No temporary or permanent alterations to this property tenure can occur without written approval from Ausgrid.

For further details refer to Ausgrid's Network Standard 143.

Please do not hesitate to contact Wei Yao on Ph: (02) 9394 6932 (please quote our ref: Trim 2017/31/313) should you require any further information.

Regards,

Wei Yao
Asset Protection Officer
Ausgrid - Field Services
Ph: (02) 9394 6932