



FIRE SAFETY CERTIFICATE

Issued Under the Environmental Planning and Assessment Regulation 2000

The owner of a building, or the owner's agent, needs to provide to the council:

- a final fire safety statement each year where an essential fire safety measure applies;
- a supplementary fire safety statement, as often as set out in the current fire safety schedule for the building, where a critical fire safety measure applies.
- In either case, you can use this form to do so.

A copy of the statement also needs to be given to the Commissioner of NSW Fire Brigades and displayed in the building in a prominent position.

1. Description of the building being certified

Name of the owner of the building / part of the building

Manly Wharf c/- TMG Developments Pty Ltd

Address of the building or part of the building

East Esplanade
Manly NSW 2095

Owners or representative signature

This statement is for: ☐ part of the building ()

☒ whole building (excluding ferry terminal)

2. Assessment of fire safety measures

Measure	Standard	Description	Date
AS1851 2005	AS2444 2001	Portable Fire Extinguishers & Fire Blankets	21 Sep 2013
AS1851 2005	AS1670 2004	Automatic Fire Detection & Alarms (E2.2a)	21 Sep 2013
AS1851 2005	AS2118.1 1999	Automatic Fire Sprinklers (including ferry terminal)	21 Sep 2013
AS1851 2005	AS1670.4 2004	Building Occupant Warning System	21 Sep 2013
AS1851 2005	AS1905.1 1997	Fire Doors	21 Sep 2013
AS1851 2005	AS2293.1 2005	Emergency & Exit Lighting	21 Sep 2013
AS1851 2005	AS2441 1998	Fire Hose Reel Systems	21 Sep 2013
AS1851 2005	AS2419.1 1994	Fire Hydrant Installations	21 Sep 2013
AS1851 2005	AS1668.1 1998	Fire & Smoke Control in Multi Compartment Buildings	21 Sep 2013

3. Type of Certificate

This is: ☐ an interim fire safety certificate ☒ a final fire safety certificate

Date of this certificate 21st September 2013

4. Certification

I Ian Zacher of Reddot Fire being the owner of the building described above, or the agent of the owner, certify that:

- ☒ each of the essential fire safety measures listed above has been assessed by a properly qualified person, and was found, when it was assessed by that person, to be capable of performing to at least the standard required by the current fire safety schedule for the building;
- ☒ the information contained in this statement is true and accurate to the best of my knowledge and belief.

5. Signature The owner of the building, or the agent's owner, must complete and sign the certificate.

Signature

Name

Ian Zacher

Address

10 Lackenwood Crescent Galston NSW 2159

Capacity in which person is signing

Agent - (Fire Services Contractor)

6. Privacy Policy

You need to provide the information in this certificate to the certifying authority if you are applying for an occupation certificate. You also need to give the information to the council and the Commissioner of New South Wales Fire Brigades if a fire safety order has been made for the building once you have satisfied that order. If you do not supply a fire safety certificate as required, you will be in breach of the Environmental Planning and Assessment Act 1979 and you could be found guilty of an offence and/or required to take further action. Please contact the council if the information you have provided in this certificate is incorrect or changes.

7. System Maintenance Information

The system(s) is under contract and being maintained to AS1851 by Reddot Fire beyond the inspection date Yes

8. Contact Information

Reddot Enterprises trading as Reddot Fire ABN 21 142 783 873 10 Lackenwood Crescent Galston NSW 2159
PO Box 3258 Dural NSW 2158 ph 1300 787 903 email service@reddotenterprises.com.au