



Fire - Lighting - Maintenance - Electrical  
ABN 50 638 958 068  
p: (02) 9053 7370  
e: [info@flameservices.com.au](mailto:info@flameservices.com.au)  
w: [www.flameservices.com.au](http://www.flameservices.com.au)

# Fire Safety Schedule

Note: This list of measures does not replace the Fire Safety Schedule specified in Part 9 Division 2 of the EPA&R 2000  
Circa BCA 1996.

**Address:** 63-67 The Corso, Manly NSW 2095

**Current Classification of Use:** Class 6

**New Classification of Use:** Class 6

## List of essential fire safety measures for compliance

**Fire safety measure**                      **Minimum standard of performance**

Emergency lighting	BCA 2019 E4.2, E4.4 & AS2293.1-2018
Exit signs	BCA 2019 E4.5, E4.6 & E4.8, AS2293 1-2018
Portable fire extinguishers	BCA 2019 E1.6 & AS 2444-2001
Automatic Fire Detection and Alarm System	BCA 2019 E2 2 Specification E2.2a, AS1670.1-2014

A copy of this schedule:

- 1- Must be forwarded to the Council and the Commissioner of Fire (see council website) & Rescue NSW ([afss@fire.nsw.gov.au](mailto:afss@fire.nsw.gov.au))
- 2- Must be prominently displayed in the building

**COUNCIL SHALL BE NOTIFIED IMMEDIATELY IN WRITING OF ANY DELETIONS OR ADDITIONS TO THE ABOVEMENTIONED MEASURES.**

**Note:** The Environmental Planning and Assessment Regulation 2000 act required each year that the building owner provide to council an annual fire safety statement for the building.