

DELMEGE

BCA ASSESSMENT REPORT

1749-1753 Pittwater Road, Mona Vale

Project Number: 120252
Report Type: BCA
Revision: 1
Date: 10 December 2024

PREPARED FOR

Delmege
c/o Sean Gartner
sean@g-t.com.au

PREPARED BY

Warwick Hunter
8484 4077
Warwick.hunter@jensenhughes.com




JENSEN HUGHES

Jensen Hughes Pty Limited
Suite 302, Level 3, 151 Castlereagh St, Sydney NSW 2000
Postal Address: PO Box Q1440, Queen Victoria Building NSW 1230

Liability limited by a scheme approved under Professional Standards Legislation

Document Control

Revision	Issue Date	Issue Description	Prepared By:	Verified by:
120252-BCA-r1	10 December 2024	BCA Assessment Report (DA Stage)	Warwick Hunter	Cynthia Lawes
	10 December 2024	Warwick Hunter Registered Certifier Grade A1, BDC 2417	Signed:  34688FE12EE445A...	

Jensen Hughes Australia

Providing building regulations, fire engineering, accessibility, and energy consulting services to NSW for over 25 years

Our story begins in 1997 with the founding of BCA Logic to fulfill the demand of a consultancy company whose expertise expanded across the entire life cycle of a building, from consulting on the initial planning through to construction and occupation.

BCA Logic, SGA Fire and BCA Energy joined Jensen Hughes in 2021, a leading global, multi-disciplinary engineering, consulting and technology firm focused on safety, security, and resiliency. We continue to be at the forefront of our industry and work thoroughly to preserve our position by ensuring the successful delivery of projects.

Jensen Hughes was launched in 2014 through the historic merger of Hughes Associates and Rolf Jensen & Associates (RJA), two of the most experienced and respected fire protection engineering companies at the time. Since then, we have gained market leadership in nuclear risk consulting and established commanding positions in areas like forensic engineering, security risk consulting and emergency management. Over the past 22 years, our integration of more than 30 privately held engineering and consulting firms has dramatically expanded our global footprint, giving us a powerful market presence ten times larger than our nearest competitor in some of our markets and extending our historical lineage back to 1939.

With more than 90 offices and 1500 employees worldwide supporting clients globally across all markets, we utilise our geographic reach to help better serve the needs of our local, regional, and multinational clients. In every market, our teams are deeply entrenched in local communities, which is important to establishing trust and delivering on our promises.


Table of Contents


EXECUTIVE SUMMARY	4
1.0 BASIS OF ASSESSMENT	6
1.1 LOCATION AND DESCRIPTION	6
1.2 PURPOSE	6
1.3 BUILDING CODE OF AUSTRALIA	6
1.4 LIMITATIONS	7
1.5 DESIGN DOCUMENTATION	8
2.0 BUILDING DESCRIPTION	9
2.1 RISE IN STOREYS (CLAUSE C2D3)	9
2.2 CLASSIFICATION (CLAUSE A6G1)	9
2.3 EFFECTIVE HEIGHT (CLAUSE A1G4)	9
2.4 TYPE OF CONSTRUCTION REQUIRED (TABLE C2D2)	9
2.5 FLOOR AREA AND VOLUME LIMITATIONS (TABLE C3D3)	9
2.6 FIRE COMPARTMENTS	10
2.7 EXITS	10
2.8 CLIMATE ZONE	11
2.9 BUILDING IMPORTANCE LEVEL	11
2.10 LOCATION OF FIRE-SOURCE FEATURES	12
3.0 BCA ASSESSMENT	13
3.1 INTRODUCTION	13
3.2 RELATIONSHIP TO THE DESIGN AND BUILDING PRACTITIONERS ACT	13
3.3 FIRE RESISTANCE AND STABILITY – PART C2 & SPECIFICATION 5	13
3.4 COMPARTMENTATION AND SEPARATION – PART C3	14
3.5 PROTECTION OF OPENINGS – PART C4	15
3.6 OCCUPANT ACCESS AND EGRESS – SECTION D	17
3.7 SERVICES AND EQUIPMENT- PARTS E1, E2, E3 AND E4	20
3.8 FACILITIES IN BUILDINGS – PART F4	22
3.9 FACILITIES IN CLASS 3 TO 9 BUILDINGS – PART F4	22
3.10 ROOM HEIGHTS – PART F5	22
3.11 LIGHT AND VENTILATION – PART F6	22
3.12 CLEANING WINDOWS – NSW G1D5	23
3.13 ENERGY EFFICIENCY - SECTION J	23
4.0 STATEMENT OF COMPLIANCE	24
ANNEXURE A - DESIGN DOCUMENTATION	26
ANNEXURE B - ESSENTIAL SERVICES	27
ANNEXURE C - FIRE RESISTANCE LEVELS	30
ANNEXURE D DEFINITIONS	33
ANNEXURE E - BCA COMPLIANCE SPECIFICATION	36

Executive summary

This document provides an assessment of the architectural design drawings for the proposed mixed use residential development at 1749-1753 Pittwater Road, Mona Vale, against the Deemed-to-Satisfy Provisions of the Building Code of Australia (BCA) 2022 Volume One.

Part 4 of this report outlines the identified BCA compliance issues that require further information or consideration and/or assessment as Performance Solutions. Any Performance Solution will need to be detailed in a separate report and must clearly indicate methodologies for achieving compliance with the relevant BCA Performance Requirements.

Item	Description	BCA Provision
Performance Solutions required		
1.	<p>Fire Stair Discharge</p> <p>To permit the discharge of two (2) fire isolated stairs to the Pittwater Road frontage where there is an exit travel distance exceeding 6.0 metres to open space (up to 9.0 metres) and path of travel is exposed to Retail 01 & 02 frontage.</p>	D2D12
Building Code of Australia compliance matters to be addressed		
1.	<p>Protection of Openings</p> <p>Level 5 - Openings on the southern elevation are within three (3) metres of the boundary and will require protection.</p> <p>Alternatively, extend the blade walls to ensure 3.0 metre setback.</p> 	C4D3 C4D5
2.	<p>Protection of Openings</p> <p>It is proposed to enter the carpark via the existing adjacent carpark. Therefore, an opening will be provided with a security gate which is located within 3.0 metres of the allotment boundary.</p> <p>In accordance with the provisions of BCA Clause C4D3/C4D5 it will be necessary for a fire shutter with an FRL not less than FRL--/60/--.</p>	C4D3 C4D5

Item	Description	BCA Provision
	<p>Alternatively, if the right of way is "benefitting" the allotment it might be possible to seek a performance solution to delete protection requirements.</p> 	

1.0 Basis of Assessment

1.1 LOCATION AND DESCRIPTION

The building development, the subject of this report, is located at 1749-1753 Pittwater Road, Mona Vale and comprises a five (5) storey residential flat building located above ground floor level retail tenancies with frontage to Pittwater Road at the front and to Bungan laneway at the rear.

The development comprises 36x residential apartments which are accessed from both the Pittwater Road frontage and the Bungan Lane frontage.

The building is located above three (3) levels of basement carparking and the carpark is accessed from the adjacent Council public carpark.



Front Elevation (Courtesy of Gartner Trovato Architects)

1.2 PURPOSE

The purpose of this report is to assess the current design proposal against the Deemed-to-Satisfy Provisions of the BCA, and to clearly outline those areas (if any) where compliance is not achieved, where areas may warrant redesign to achieve strict BCA compliance or where areas may be able to be assessed against the relevant performance criteria of the BCA. Such assessment against relevant performance criteria will need to be addressed by means of a separate Fire Engineering Report (FER) for fire safety matters, and Performance Solution Report for non-fire-safety matters; such reports are to be prepared under separate cover.

1.3 BUILDING CODE OF AUSTRALIA

The National Construction Code (**NCC**) is Australia's primary set of technical design and construction provisions for buildings.

As a performance-based code, it sets the minimum required level for the safety, health, amenity, accessibility, and sustainability of certain buildings. The Australian Building Codes Board, on behalf of the

Australian Government and each State and Territory government, produces and maintains the National Construction Code.

The NCC has three (3) volumes being:

- + Volume One - containing technical design and construction requirements for all Class 2 to 9 buildings.
- + Volume Two - containing technical design and construction requirements for certain residential (Class 1) and non-habitable buildings and structures (Class 10).
- + Volume Three - Containing technical requirements for the design and construction for plumbing and drainage systems in new and existing buildings.

This report is based on the Deemed-to-Satisfy Provisions of the National Construction Code (**NCC**) Series Volume One – Building Code of Australia, 2022 Edition (**BCA**), incorporating the State variations where applicable.

Please note that the version of the BCA applicable to new building works is the version applicable at the time of the lodgement of the Construction Certificate application to the Accredited Certifying Authority, or for Crown projects the date of the invitation for tenders to carry out the Crown building work, or in the absence of tenders the date on which the Crown building work commences.

A reference to the BCA in this report is a reference to **BCA2022**, being volume 1 of the NCC.

1.4 LIMITATIONS

This report does not include nor imply any detailed assessment for design, compliance or upgrading for:

1. the structural adequacy or design of the building;
2. the inherent derived fire-resistance ratings of any proposed structural elements of the building (unless specifically referred to); and
3. the design basis and/or operating capabilities of any proposed electrical, mechanical or hydraulic services.

This report does not include, or imply compliance with:

1. the National Construction Code – Plumbing Code of Australia Volume 3
2. the Disability Discrimination Act 1992 including the Disability ((Access to Premises – Buildings) Standards 2010 – unless specifically referred to) (Note: The provision of access for people with a disability for the subject development has not been assessed against the Deemed-to-Satisfy Provisions of Part D4 and Clauses E3D7, E3D8, F4D5, F4D6, F4D7 and F4D12 of BCA2022 unless otherwise discussed in this report);
3. Demolition Standards not referred to by the BCA;
4. Work Health and Safety Act 2011;
5. Requirements of Australian Standards unless specifically referred to;
6. Requirements of other Regulatory Authorities including, but not limited to, Telstra, Telecommunications Supply Authority, Water Supply Authority, Electricity Supply Authority, Work Cover, Roads and Maritime Services (RMS), Local Council, ARTC, Department of Planning and the like; and
7. Conditions of Development Consent issued by the Local Consent Authority.

1.5 DESIGN DOCUMENTATION

This report has been based on the Design plans and Specifications listed in Annexure A of this Report.

2.0 Building Description

For the purposes of the Building Code of Australia (BCA), the development may be described as follows.

2.1 RISE IN STOREYS (CLAUSE C2D3)

The building has a rise in storeys of six (6)

2.2 CLASSIFICATION (CLAUSE A6G1)

The building has been classified as follows.

Table 1: Building Classification

Class	Level	Description
Class 2	Part Level 2	Residential apartments
	Level 3, 4, 5 & 6	
Class 6	Part Level 1 (Retail 1 & 2)	Retail tenancies
	Part Level 2 (Retail 3 & 4)	
Class 7a	Basement 2	Carpark
	Basement 1	
	Part Level 1	

2.3 EFFECTIVE HEIGHT (CLAUSE A1G4)

The building has an *effective height* of less than twenty-five (25) metres and more than twelve (12) metres. RL22.600 – RL6.340 = 16.26m.

2.4 TYPE OF CONSTRUCTION REQUIRED (TABLE C2D2)

The building is required to be of Type A Construction.

2.5 FLOOR AREA AND VOLUME LIMITATIONS (TABLE C3D3)

The building is less than the maximum floor area and volume limits of: -


Class 6	Maximum Floor Area	5,000m ²
	Maximum Volume	30,000m ³
Class 7a	The carpark is to be provided with a sprinkler system (other than a FPAA101D or FPAA101H system) complying with Specification 17) and as such there are no maximum floor area or volume limitations for this area.	

Class 2 The Class 2 portions of the building are not subject to floor area and volume limitations of C3D3 as Specifications 5 and Clause C4D12 of the BCA regulate the compartmentation and separation provisions applicable to buildings, or building portions, of Class 2 buildings.


2.6 FIRE COMPARTMENTS

The following fire compartments have been assumed:

1. Basement level 2, basement level 1 & part level 1 carpark (due to connection by vehicular ramp)
2. Level 1 retail



3. Level 2 retail



4. Each level of residential apartments

2.7 EXITS

The following points in the building have been considered as the exits:

1. Basement level fire isolated stairs
2. Ground floor level (Retail 1/2/3/4) – Doorways opening direct to open space.
3. Residential levels – Fire isolated stairs

2.8 CLIMATE ZONE

The building is located within Climate Zone 5

2.9 BUILDING IMPORTANCE LEVEL

Certain Australian Standards (particularly structural standards) require the Importance Level of the building to be determined. The importance level relates to the individual actions on a building listed in Clause B1D3 of the BCA. The building is importance level 2.

Table B1D3a of the BCA provides the following:

Importance Level	Building Types	Jensen Hughes Interpretation and Examples
1	Buildings or structures presenting a low degree of hazard to life and other property in the case of failure.	1 and 2 storey factory buildings
2	Buildings or structures not included in Importance Level 1, 3 and 4.	Residential apartment buildings and associated carparking. Office buildings
3	Buildings or Structures that are designed to contain a large number of people.	Stadia, Entertainment venues, shopping centres. Transport facilities
4	Buildings or Structures that are essential to post-disaster recovery or associated with hazardous facilities.	Data centres, evacuation centres

The Guide to the BCA provides a generic description of building types which have Importance Levels assigned. The Guide states that the "Importance Level" concept is applicable to building structural safety only. Specific examples from the Guide are provided below. The examples provided by the Guide are not exhaustive of all building types.

Importance Level 1:

- Farm buildings and farm sheds.
- Isolated minor storage facilities.
- Minor temporary facilities.

Importance Level 2:

- Low rise residential construction.
- Buildings and facilities below the limits set for Importance Level 3.

Importance Level 3:

- Buildings and facilities where more than 300 people can congregate in one area.
- Buildings and facilities with a primary school, a secondary school or day care facilities with a capacity greater than 250.
- Buildings and facilities with a capacity greater than 500 for colleges or adult educational facilities.
- Health care facilities with a capacity of 50 or more residents but not having surgery or emergency treatment facilities.
- Jails and detention facilities.
- Any occupancy with an occupant loads greater than 5000.
- Power generating facilities, water treatment and wastewater treatment facilities, any other public utilities not included in Importance Level 4.
- Buildings and facilities not included in Importance Level 4 containing hazardous materials capable of causing hazardous conditions that do not extend beyond property boundaries.

2.10 LOCATION OF FIRE-SOURCE FEATURES

The fire source features for the subject development are:

North: The side allotment boundary

South: The side allotment boundary

East: The far boundary of Pittwater Road

West: The far boundary of Bungan Lane

In accordance with Clause S5C2 of Specification 5, a part of a building element is exposed to a *fire-source feature* if any of the horizontal straight lines between that part and the fire-source feature, or vertical projection of the feature, is not obstructed by another part of the building that–

- a. has an FRL of not less than 30/–/–; and
- b. is neither transparent nor translucent.

3.0 BCA Assessment

3.1 INTRODUCTION

The assessment undertaken is in relation to the plans prepared for the development consent application. The technical details required for a development consent are far less than that required for a construction certificate and as such, this assessment is designed to address a higher-level assessment of the building against the provisions of the BCA.

The main purpose of this report is to identify any major design changes required to the building, services required to be installed, and the fundamentals of design required by sections C, D, E, F, G and H (where applicable) of the BCA. This report does not address the design requirements for the structure of the building (Section B), or for the detailed design of services (Section E) and is subject to the limitations outlined under Section 1.4 of this report.

The summary below is to be read in conjunction with the BCA specification contained in Annexure E of the report.

3.2 RELATIONSHIP TO THE DESIGN AND BUILDING PRACTITIONERS ACT

The Design and Building Practitioners Act requires certain specified design to be certified by a Registered Practitioner and the issuing of a Design Compliance Declaration (DCD). The declared designs include:

- Structure
- Building Enclosure (e.g. Façade);
- Fire Safety Systems (e.g. services, egress and FRLs)
- Waterproofing
- Fire Safety performance solutions

This report contains an assessment of the plans and specifications available, which are not sufficient in detail to allow any DCD to be issued by others. This report is not to be construed as, or used to support to a DCD at Construction Certificate Stage as it is based on development application drawings only.

3.3 FIRE RESISTANCE AND STABILITY – PART C2 & SPECIFICATION 5

The building is proposed to be constructed of the following elements:

Element	Method of Construction
External Walls	Concrete
Floors	Concrete
Roof	Concrete with membrane
Internal Walls (between SOU's)	Assumed to be lightweight steel/hebel/plasterboard
Basement walls	Concrete
Lift shafts	Concrete
Stair shafts	Concrete

The required fire resistance levels for the building elements are outlined in Annexure C of this report.

The fire resistance levels of the building are assumed to be consistent with Type A Construction which in general will be:-

- a. Residential levels – FRL 90 minutes
- b. Carpark levels – FRL 120 minutes
- c. Retail fire compartments – FRL 180 minutes. Note: with design development at Construction Certificate stage it might be possible to consider FRL reductions subject to fire engineering input.

The external walls and all components of the wall, in a building of Type A construction, are required to be non-combustible. Full details have not been provided with respect to the materials of the external wall and further details will be required to be submitted at Construction Certificate Stage for assessment.

Combustibility of External Walls

The plans indicate that the external walls are to be constructed of concrete which can readily meet the requirements of BCA Clause C2D10 (non-combustible). However, it will be necessary to consider the proposed planter boxes and hanging vegetation with design development at Construction Certificate stage.

Fire Hazard Properties

Internal linings and materials are required to meet the specified fire hazard properties of BCA Clause C2D11 and Specification 7.

Subject to the required FRL's being provided, the proposed building is capable of complying with the requirements of the BCA with respect to fire resistance.

3.4 COMPARTMENTATION AND SEPARATION – PART C3

Under the provisions of BCA Clause C3D3, the residential portion of the building is not the subject to any floor area and volume limitations.

The Class 6 portion of the building has been assessed and the floor area and volume of these compartments is less than that permitted by BCA Clause C3D3. As such compliance with the provisions of the BCA for compartmentation is readily achieved, however this assessment is to be reaffirmed at Construction Certificate stage once holistic fire compartment drawings are available for assessment.

Carpark

The carpark is required to have an AS2118.1 sprinkler system, as it accommodates more than forty (40) vehicles and/or is part of a building *required* to have sprinklers. Therefore, the carpark is not subject to the floor area and volume limitations under BCA Clause C3D3.

Spandrel Separation

The development is Type A Construction and is required to have spandrel separation between openings in an external wall. However, as the building will be required to be protected with an AS2118.1 system, fire rated spandrel panels are not required under the provisions of BCA Clause C3D7.

Main Switchboard

If the switchboard is required to sustain emergency equipment in an emergency, the switch room is to have an FRL of 120/120/120. The design of the switch room is such that compliance can be readily achieved.


Compliance with Part C3 of the BCA can be readily achieved by the proposal.

3.5 PROTECTION OF OPENINGS – PART C4

3.5.1 Openings in external walls

The openings on the northern and southern elevation are within three (3) metres of the boundary and have been protected with blade walls on all levels, except for level 5 where the blade walls are less than 3.0 metres length.


Unless the blade walls are extended it will be necessary for protection to be provided by self-closing fire windows, fire shutters or fixed glazing with sprinklers. Details are to be provided at Construction Certificate Stage to outline how compliance will be achieved.



Carpark Entrance Opening

It is proposed to enter the carpark via the existing adjacent carpark. Therefore, an opening will be provided with a security gate which is located within 3.0 metres of the allotment boundary. In accordance with the provisions of BCA Clause C4D3/C4D5 it will be necessary for a fire shutter with an FRL not less than FRL--/60/--.

Alternatively, if the right of way is "benefitting" the allotment it might be possible to seek a performance solution to delete protection requirements.



3.5.2 Bounding Construction

The walls between the Sole-Occupancy-Units (SOUs) and between the SOUs and corridor are internal walls that require an FRL. In addition, the walls to the lift and stairs require an FRL. As such, the doors to the sole occupancy units and fire stairs are required to be self-closing FRL --/60/30 fire doors in accordance with BCA Clause C4D12. The doors to the lift are required to have an FRL of -/60/- in accordance with BCA Clause C4D11.

3.5.3 Openings to Fire Walls

The building design includes fire wall separation to the retail fire compartments and will require self-closing fire doors to be provided to protect openings.

As such, the openings to fire walls are required to be FRL --/180/30 in accordance with BCA Clause C4D6, where "180" is the structural integrity rating required for the fire wall separating the differing Classifications each side of the fire wall.

3.5.4 Openings in Floors for Services and Service Installations

Where electrical, plumbing, mechanical or other services pass through an element of construction that is required to achieve a fire resistance level (FRL), the service installation shall not compromise the fire resistance level of the element. As such, the service installation must be fire sealed with a compliant system such as fire collar on PVC pipes or fire rated mastic on electrical cables tested in accordance with AS1530.4-2014.

Fire sealing of services is a design element that will require detailed assessment and specification at Construction Certificate stage.

3.6 OCCUPANT ACCESS AND EGRESS – SECTION D

3.6.1 Egress from the building

General Requirements

As the development is under twenty-five (25) metres effective height, each storey is permitted to have a single exit.

Where the egress discharges to open space on the property, a continuous pathway from the point of discharge to the street is required. The plans do indicate such a pathway and as such the provisions of BCA Clause D2D15 are readily satisfied.

Details of treads and risers, landings, thresholds, balustrades, and handrails have not been provided however compliance is readily achievable. The design of these elements can be assessed at the Construction Certificate Stage.

Electrical distribution cupboards are to be provided with smoke separation to satisfy the requirements of BCA Clause D3D8. The doors are to be lined internally with fire grade plasterboard or metal backing sheets and smoke seals provided to all four sides, including drop down seals on the bottom. All penetrations from the enclosure are to be suitably sealed against smoke spread by sealing with non-combustible mastic.

Basement Car Park

Egress from the carpark shall ensure that no point on the floor is more than twenty (20) metres from an exit, or where a point of choice of two (2) exits is available, the distance to the nearest of those exits can increase up to forty (40) metres, as permitted by BCA Clause D2D5.

The distance between alternative exits is required by BCA Clauses D2D7-D2D11 to be no closer than nine (9) metres and no further apart than sixty (60) metres when measured through the point of choice.

The exit travel distances and distances between exits comply with the above requirements.

Note: At level 1, no allowance for pedestrian egress is made through to the southern elevation Council carpark as no legal means of egress is known at this stage. In any case the carpark has two exits with compliant exit travel.


Retail Tenancies

Egress from the retail tenancies are permitted to be thirty (30) metres to an exit and the total travel from all retail tenancies is less than thirty (30) metres as required.

Note: to retail tenancy 01 & 02 the exit travel distance has been measured to the top of the stairs and ramp which are both considered to be non-fire isolated stairs/ramps and are defined as an "exit" in accordance with the definitions of the BCA.

Bin Rooms

The exit travel distance exceeds 20m to a single exit therefore, alternative means of egress is required and is available subject to door hardware enabling unobstructed egress to an alternative exit. Details of door hardware to be addressed at Construction Certificate stage.



Residential Floors


The building has a rise in storeys of more than three (3) with all levels connected by a common stairway. Therefore, BCA Clause D2D4 requires the residential building to have a fire-isolated stair and this has been provided. All fire stairs discharge externally as required.

To the upper floors, the travel distance to an exit is no more than six (6) metres to a single exit as required.

The longest travel distance is at level 2 common space where travel is more than 20m to a single exit, therefore, exit travel is needed between alternative exits and it is possible to reach an exit within forty-five (45) metres as required.


Fire Stair Discharge (Bungan Lane)

The fire stair discharge to Bungan Lane results in travel in front of the residential lobby and retail 04 therefore, it will be necessary to have self-closing doors and internal wall wetting drenchers in accordance with BCA Clause D2D12 and C4D5.



Fire Stair Discharge (Pittwater Road)

Both the fire isolated stair discharges to Pittwater Road frontage results in exit travel in excess of 6.0 metres to open space at the footpath (up to 9.0 metres). Furthermore, the path travel is within 6.0 metres of unprotected openings to the front of the retail tenancy 01 & 02 and is a non-conformance with BCA Clause D2D12 therefore, will require a fire engineered performance solution to assess the protection of the egress path.



Note: the lobby height as shown on the elevation drawings a height of greater than 3.0 metres (3.3)

3.6.2 Access for people with a disability

BCA Part D4 has not been assessed within this report. The accessibility requirements have been assessed in separate Jensen Hughes report 120252-Access-r1.

3.7 SERVICES AND EQUIPMENT- PARTS E1, E2, E3 AND E4

The building is required to be provided with the services and equipment set out in Annexure B of this report. The annexure also outlines the standard of performance to be achieved by the services and equipment.

3.7.1 Part E1 – Fire Fighting Equipment

Specific comments pertaining to fire fighting services and equipment required for the building as set out in Annexure B of this report are provided as follows:

Fire hydrant

As the building has a floor area greater than 500m², fire hydrant protection is required.

Due to the size of the building, it will be necessary to install onsite fire hydrants with hydrants located within four (4) metres of exits, or within fire isolated stairs as relevant to the requirements contained within AS2419.1-2021. The hydrant booster is proposed to the front elevation and is within sight of the principal pedestrian entrance as well as located not less than ten (10) metres from any substation.

The plans do not show the location of fire hydrants and further information will be required at the Construction Certificate Stage from the Hydraulic Consultant to demonstrate compliance.

Fire Hose Reel

The Class 6 & 7a portions of the building are greater than 500m² and is required to have fire hose reels (FHR's) located within four (4) metres of an *exit*, and that coverage to all points on a floor are within thirty-six (36) metres, plus four (4) metres of spray as per AS2441-2005.

The plans do not show the location of fire hose reels and further information will be required at the Construction Certificate Stage from the Hydraulic Consultant to demonstrate compliance.

Sprinklers

The building is required to have a sprinkler system installed as per BCA Clause E1D6 & Specification 17/18. Details are to be provided at the Construction Certificate Stage by the Hydraulic Consultant to demonstrate compliance. As the building is under twenty-five (25) metres, a sprinkler system complying with the following standards is required:

- + AS 2118.1-2017; or
- + AS2118.6-2012

Portable Fire Extinguishers

The development is required to have portable fire extinguishers installed throughout in accordance with AS2444-2001. Compliance is readily achievable.

3.7.2 Part E2 – Smoke Hazard Management

Specific comments pertaining to smoke hazard management system services and equipment required for the building as set out in Annexure B of this report are provided as follows:

Smoke Alarms

Smoke alarms will be required within residential sole occupancy units in accordance with Part E2 & AS3786-2014.

Smoke Detection & Alarm System

The development must be provided with a smoke hazard management system and this is being substantially provided by the installation of sprinklers in accordance with BCA Clause E1D6 due to the rise in storeys being more than four (4).

Due to the sprinkler system, there is no requirement for smoke detection to the residential corridors in accordance with Clause 5 of Specification 20. However, the Building occupant warning system will be activated by the sprinkler system in accordance with BCA Clause 7 of Specification 20.

To the retail tenancies, there is also no requirement for smoke detection and alarm system due to the presence of sprinklers in accordance with BCA Clause E1D6.

Carpark

Due to the sprinkler system in accordance with BCA Clause E1D6 (due to the rise in storeys being more than four (4)), there is no requirement for smoke detection to the carpark in accordance with BCA Clause E2D12 and Clauses 5.5 of AS1668.1. The sprinkler system will need to activate the operation of the on/off/auto controls to carpark ventilation system upon fire trip.

Note: the carpark only has two below ground levels therefore, stair pressurisation is not required.

3.7.3 Part E3 – Lift Installations

Lifts Serving More than 12 Metres Effective Height

Lifts are provided to the building and are located within their own shaft, serviced by a common lobby. The lifts require stretcher facilities as they serve a height above twelve (12) metres in *effective height* and the dimensions of the shaft are sufficient to allow compliance for a 1400 mm width x 2000 mm length lift car.

No details have been provided to undertake an assessment. Therefore, further information is required during the Construction Certificate Stage.

3.7.4 Part E4 – Visibility in emergency, exit signs and warning systems.

Specific comments pertaining to emergency lighting, exit signs and warning systems required for the building as set out in Annexure B of this report are provided as follows:

- + Emergency lighting is required as per BCA Clause E4D2 for all non-fire-isolated stairs, corridors, passageways, hallways, or the like that is part of a path of travel to an exit.
- + Exit signs are required to be installed throughout the building, including directional exit signs to guide occupants to the designated exits in the building.

The DA plans do not provide any details for the emergency lighting and exit signs. As such further information will be required at the Construction Certificate Stage, however compliance is readily achievable.

3.8 FACILITIES IN BUILDINGS – PART F4

Clause F4D2 of the BCA requires the following facilities within a Class 2 building:

- + Kitchen sink;
- + Bath or shower;
- + Closet pan;
- + Washbasin
- + Laundry facilities

The plans indicate that each of these facilities are provided within each sole occupancy unit and therefore compliance is achieved with BCA Clause F4D2.

3.9 FACILITIES IN CLASS 3 TO 9 BUILDINGS – PART F4

There are four (4) retail tenancies each with their own accessible bathroom. As a retail tenancy with unknown future use it might be used as a shop with only requirements for amenities for staff in which there would be less than 10x staff based upon the floor area being 70m², 90m², 144m² & 146m² and is therefore, deemed compliant for a base case scenario.

Should future fitout and use include a restaurant, café or bar it would be necessary for additional amenities to be provided and would need to be separately addressed via separate approvals process.

3.10 ROOM HEIGHTS – PART F5

The section drawings indicate that the ceiling heights for all habitable spaces, corridors, and the like can achieve the minimum height of 2400 mm. In non-habitable rooms such as toilets, garages and storage rooms, the ceiling height is no less than 2100 mm.

The ceiling heights have been assessed in accordance with BCA Part F5 which has indicated that compliance is readily achievable within all habitable spaces, corridors, and the like.

3.11 LIGHT AND VENTILATION – PART F6

3.11.1 Residential Accommodation

3.11.1.1 *Method and extent of natural light*

Class 2

Natural light is required to all habitable rooms within a Class 2 building. The plans have been assessed which reveals all habitable spaces are served by windows or glazed doors. The area of the doors and windows (exclusive of any framing members, glazing bars or other obstructions) are likely to be sufficient in size to provide the required 10% natural light to all habitable rooms. However, window specification will be needed with design development to verify compliance.

3.11.1.2 *Ventilation of rooms*

Ventilation is required to all habitable rooms within a Class 2 building. Clause F6D6 allows for either natural ventilation as per Clause F6D7 or mechanical ventilation or air-conditioning system complying with AS1668.2 and AS/NZS3666.1.

The plans have been assessed which reveals all habitable spaces are served by windows or glazed doors. The area of the doors and windows (exclusive of any framing members, glazing bars or other obstructions) are likely to be sufficient in size to provide the required 5% ventilation to all habitable rooms. However, a window specification will be needed with design development to verify compliance if natural ventilation is relied upon.

3.11.2 Retail Tenancies

For a Class 6 portion of the building, artificial lighting and mechanical ventilation are required, and these systems can be readily installed in the building. Further design development and input will be required from the Electrical and Mechanical Consultants at the Construction Certificate Stage.

The carpark (other than an *open-deck* carpark) is required to have a mechanical ventilation system complying with AS1668.2. No information has been provided; However, the mechanical system can be readily designed. Further design input will be required from the Mechanical Consultant to demonstrate compliance.

3.12 CLEANING WINDOWS – NSW G1D5

A building must provide for a safe manner of cleaning any *windows* located three (3) or more storeys above ground level as per NSW Clause G1D5. Two (2) options are available for cleaning the windows:

1. The windows can be cleaned wholly from within the building; or
2. Provisions are made for cleaning windows by a method complying with the *Work Health and Safety Act 2011* and regulations made under the Act.

No information has been provided to determine if the development can comply with this requirement, and further information will be required during the design development stage.

3.13 ENERGY EFFICIENCY - SECTION J

To be separately assessed by Energy Consultant.

4.0 *Statement of Compliance*

The plans assessed were developed to a standard suitable for submission as a development application and do not contain all the details necessary information to allow a CC to be issued. As such, this assessment was limited to the major items of the BCA with the view of identifying any items that may result in a modified development consent being required, or additional key items that need to be included in the design.

The architectural design documentation as referred to in report has been assessed against the applicable provisions of the Building Code of Australia, (BCA) and it is considered that such documentation complies or is capable of complying with that Code, subject to all matters for further consideration identified in this report being addressed in the design, and subject to compliance with all Annexures and Specifications included with this report.

Annexures

Annexure A - Design Documentation

This report has been based on the following design documentation.

Table 2: Architectural Plans

Architectural Plans Prepared by Gartner Trovato Architects			
Drawing Number	Revision	Date	Title
A00	A	5/12/2024	Cover
A01	A	5/12/2024	Site plan
A02	A	5/12/2024	Basement 2
A03	A	5/12/2024	Basement 1
A04	A	5/12/2024	Level 1
A05	A	5/12/2024	Level 2
A06	A	5/12/2024	Level 3
A07	A	5/12/2024	Level 4
A08	A	5/12/2024	Level 5
A09	A	5/12/2024	Level 6
A10	A	5/12/2024	Elevations NW & SE
A11	A	5/12/2024	Elevations NE & SW
A12	A	5/12/2024	Section A & F
A13	A	5/12/2024	Section B, C, D, E
A14	A	5/12/2024	Context views 1
A15	A	5/12/2024	Context views 2
A16	A	5/12/2024	Courtyard views
A17	A	5/12/2024	Shadow diagrams
A18	A	5/12/2024	Area calculations

Annexure B - Essential Services

The following fire safety measures are required to be installed in the building. The following table may be required to be updated as the design develops and options for compliance are confirmed, including any omissions or additions as a result of the fire engineering processes.

This section provides information for the design team, including service designers, and may need to be updated upon receipt of final designs and performance solutions at the construction approval stage.

Table 3: Essential Fire Safety Measures

Item	Essential Fire and Other Safety Measures	Standard of Performance
Fire Resistance (Floors – Walls – Doors – Shafts)		
4.	Access Panels & doors/hoppers (fire rated)	BCA2022 C4D14 (Openings in Shafts) BCA2022 Specification 12 AS 1905.1:2015 (Fire Resistant Door sets)
5.	Construction Joints	BCA2022 C2D2, Specification 5 BCA2022 C4D16 AS 1530.4:2014 & AS 4072.1:2005
6.	Fire doors	BCA2022 C4D5 (Acceptable methods of Protection) BCA2022 C4D6 (Doors in Fire Walls) BCA2022 C4D9 (Openings in Fire Isolated Exits) BCA2022 C4D11 (Opening in Fire Isolated Lift Shafts) AS1735.11- 1986 BCA2022 C4D12 (Bounding Construction) BCA2022 C4D14 (Opening in Shafts) Specification 12 AS1905.1: 2015
7.	Fire seals protecting openings in fire resisting components of the building	BCA2022 C4D15 (Openings for service installations) BCA2022 Specification 13 AS1530.4:2014 & AS4072.1-2005
8.	Fire shutters (Where required)	BCA2022 C4D5 (Acceptable methods of protection) BCA2022 Specification 12 AS1905.2-2005
9.	Lightweight construction	BCA2022 C2D2, Specification 5 BCA2022 C2D9, Specification 6 BCA2022 C4D12 (Bounding Construction) AS1530.4:2014

Item	Essential Fire and Other Safety Measures	Standard of Performance
General		
10.	Portable fire extinguishers	BCA2022 E1D14 AS 2444–2001
11.	Fire blankets	AS 2444–2001
General Egress		
12.	Required Automatic Doors	D3D24 (Doorways and Doors)
13.	Warning & operational signs	BCA2022 D3D28 (Signs on Fire Doors) BCA2022 D4D7 (Braille Exit Signs) (Note: E4D5 (Exit Signs)) BCA2022 E3D4 (Lift Signs)
Lifts		
14.	Access to Lift Pits Located at lowest level or if >3m provided through an access door	BCA2022 D2D22 (Access to Lift Pits) 'DANGER LIFT WELL – ENTRY OF UNAUTHORISED PERSONS PROHIBITED – KEEP CLEAR AT ALL TIMES'
15.	Passenger lift	BCA2022 E3D3 BCA2022 E3D9 (Fire Service Controls) BCA2022 E3D11 (Fire Service Recall Operation Switch) BCA2022 E3D12 (Lift Car Fire Service drive control switch) BCA2022 Specification 24 AS 1735.11:1986 (Fire rated landing doors)
Electrical Services		
16.	Automatic fail-safe devices Auto open Sliding Exit doors	BCA2022 D3D26 (Operation of Latches) AS1670.1:2018 (Fire)
17.	Automatic fire detection & alarm:	BCA2022 E2D8, E2D9, E2D12 Spec 20 BCA2022 S20C5 (Combined smoke alarm and smoke detection system) BCA2022 S20C7 (BOWS) AS 3786:2014 (Amdt 1-4) AS 1670.1 (Amdt 1) (Fire) – Section 4 and 5 (Detectors)
18.	Emergency lighting	BCA2022 E4D2, E4D4 AS/NZS 2293.1:2018
19.	Exit signs	BCA2022 E4D55 (Exit Signs) BCA2022 E4D6 (Direction Signs)

Item	Essential Fire and Other Safety Measures	Standard of Performance
		BCA2022 E4D8 (Design and Operation - Exits) AS/NZS 2293.1:2018
20.	System Monitoring	BCA2022 S20C8 AS 1670.3 (Amdt 1) Monitoring Required for any: Any Sprinkler System
Hydraulic Services		
21.	Automatic fire suppression system	BCA2022 E1D6 BCA2022 Specification 17 / 18 AS 2118.1:2017 (Sprinklers) AS 2118.6:2012 (Combined Sprinklers/Hydrant)
22.	Fire hydrant systems	BCA2022 E1D2 AS 2419.1:2021 FRNSW Technical Sheet D15/45534.V9 issued 10.01.19, 'Compatible Hose Connections'
23.	Hose reel systems	BCA2022 E1D3 AS 2441:2005
24.	Wall-wetting sprinkler / drenchers	BCA2022 C4D5, D2D12 AS 2118.2: Wall-wetting sprinkler / drenchers
Mechanical Services		
25.	Fire dampers	BCA2022 E2, Specification 20, Specification 21 BCA2022 C4D16 AS 1668.1:2015 (Amdt 1) AS 1682.1:2015 & AS 1682.2:2015
26.	<ol style="list-style-type: none"> Mechanical air handling systems Mechanical ventilation to carpark. <p>Any system that recycles air from one fire compartment to another, or operates in a manner that may spread smoke and does not operate as a smoke control system as per AS 1668.1:2015;</p>	BCA2022 E2, Specification 20, Specification 21 AS 1668.1:2015 (Amdt 1) Note: 5.5.3 Override control To enable manual control by attending emergency services personnel, fans that are not required to shut down on initiation of fire mode in the car park shall be provided with a control switch at the designated building entry point. Note: Signage should be located at the car park entry indicating the location of the control switches.

Annexure C - Fire Resistance Levels

The following fire resistance levels (FRL's) are required for the various building elements, with a fire source feature being the far boundary of a road adjoining the allotment, a side or rear boundary or an external wall of another building on the allotment except a Class 10 structure.

Type A Construction

Table 4: Type A Construction

Table S5C11a: Type A construction: FRL of loadbearing parts of external walls

Distance from a fire-source feature	FRL (in minutes): Structural adequacy / Integrity / Insulation			
	Class 2, 3 or 4 Part	Class 5, 7a or 9	Class 6	Class 7b or 8
Less than 1.5 m	90/90/90	120/120/120	180/180/180	240/240/240
1.5 to less than 3 m	90/60/60	120/90/90	180/180/180	240/240/180
3m, or more	90/60/30	120/60/30	180/120/90	240/180/90

Table S5C11b: Type A construction: FRL of non-loadbearing parts of external walls

Distance from a fire-source feature	FRL (in minutes): Structural adequacy / Integrity / Insulation			
	Class 2, 3 or 4 Part	Class 5, 7a or 9	Class 6	Class 7b or 8
Less than 1.5 m	-/90/90	-/120/120	-/180/180	-/240/240
1.5 to less than 3 m	-/60/60	-/90/90	-/180/120	-/240/180
3m, or more	-/-/-	-/-/-	-/-/-	-/-/-

Table S5C11c: Type A construction: FRL of external columns not incorporated in an external wall.

Column Type	FRL (in minutes): Structural adequacy / Integrity / Insulation			
	Class 2, 3 or 4 Part	Class 5, 7a or 9	Class 6	Class 7b or 8
Loadbearing	90/-/-	120/-/-	180/-/-	240/-/-
Non-loadbearing	-/-/-	-/-/-	-/-/-	-/-/-

Table S5C11d: Type A construction: FRL of common walls and fire walls

FRL (in minutes): Structural adequacy / Integrity / Insulation				
Wall Type	Class 2, 3 or 4 Part	Class 5, 7a or 9	Class 6	Class 7b or 8
Loadbearing or non-bearing	90/90/90	120/120/120	180/180/180	240/240/240

Table S5C11e: Type A construction: FRL of loadbearing internal walls

FRL (in minutes): Structural adequacy / Integrity / Insulation				
Location	Class 2, 3 or 4 Part	Class 5, 7a or 9	Class 6	Class 7b or 8
Fire-resisting lift and stair shafts	90/90/90	120/120/120	180/120/120	240/120/120
Bounding public corridors, public lobbies and the like	90/90/90	120/-/-	180/-/-	240/-/-
Between or bounding sole-occupancy unit	90/90/90	120/-/-	180/-/-	240/-/-
Ventilating, pipe, garbage, and like shafts not used for the discharge of hot products of combustion	90/90/90	120/90/90	180/120/120	240/120/120

Table S5C11f: Type A construction: FRL of non-loadbearing internal walls

FRL (in minutes): Structural adequacy / Integrity / Insulation				
Location	Class 2, 3 or 4 Part	Class 5, 7a or 9	Class 6	Class 7b or 8
Fire-resisting lift and stair shafts	-/90/90	-/120/120	-/120/120	-/120/120
Bounding public corridors, public lobbies and the like	-/60/60	-/-/-	-/-/-	-/-/-
Between or bounding sole-occupancy unit	-/60/60	-/-/-	-/-/-	-/-/-
Ventilating, pipe, garbage, and like shafts not used for	-/90/90	-/90/90	-/120/120	-/120/120

the discharge of hot products of combustion				
---	--	--	--	--

Table S5C11g: Table A construction: FRL of other building elements not covered by Tables S5C11a to S5C11f

Building Element	FRL (in minutes): Structural adequacy / Integrity / Insulation			
	Class 2, 3 or 4 Part	Class 5, 7a or 9	Class 6	Class 7b or 8
Other loadbearing internal walls, internal beams, trusses and columns	90/-/-	120/-/-	180/-/-	240/-/-
Floors	90/90/90	120/120/120	180/180/180	240/240/240
Roofs	90/60/30	120/60/30	180/60/30	240/90/60

Annexure D Definitions

Average specific extinction area

Average specific extinction area means the average specific extinction area for smoke as determined by AS 5637.1:2015.

Critical radiant flux

Critical radiant flux (CRF) means the critical heat flux at extinguishment (CHF in kW/m²) as determined by AS ISO 9239.1:2003.

Effective height

Effective height means the vertical distance between the floor of the lowest storey included in a determination of rise in storeys and the floor of the topmost storey (excluding the topmost storey if it contains only heating, ventilating, lift or other equipment, water tanks or similar service units).

Exit

Exit means –

1. Any, or any combination of the following if they provide egress to a road or open space—
 - a. An internal or external stairway.
 - b. A ramp.
 - c. A fire-isolated passageway.
 - d. A doorway opening to a road or open space.
 - e. A horizontal exit or a fire-isolated passageway leading to a horizontal exit.

Fire compartment

Fire compartment means –

1. the total space of a building; or
2. when referred to in—
 - a. the Performance Requirements — any part of a building separated from the remainder by barriers to fire such as walls and/or floors having an appropriate resistance to the spread of fire with any openings adequately protected; or
 - b. the Deemed-to-Satisfy Provisions — any part of a building separated from the remainder by walls and/or floors each having an FRL not less than that required for a fire wall for that type of construction and where all openings in the separating construction are protected in accordance with the Deemed-to-Satisfy Provisions of the relevant Part.

Fire-resistance level (FRL)

Fire-resistance level (FRL) means the grading periods in minutes determined in accordance with Specification A2.3, for the following criteria—

1. structural adequacy; and
2. integrity; and

3. insulation,

and expressed in that order.

Note: A dash means that there is no requirement for that criterion. For example, 90/–/– means there is no requirement for an FRL for integrity and insulation, and –/–/– means there is no requirement for an FRL.

Fire-source feature

1. the far boundary of a road, river, lake or the like adjoining the allotment; or
2. a side or rear boundary of the allotment; or
3. an external wall of another building on the allotment which is not a Class 10 building.

Fire wall

Fire wall means a wall with an appropriate resistance to the spread of fire that divides a storey or building into fire compartments.

Flammability index

Flammability Index means the index number as determined by AS 1530.2:1993.

Group number

Group number means the number of one of 4 groups of materials used in the regulation of fire hazard properties and applied to materials used as a finish, surface, lining, or attachment to a wall or ceiling.

Horizontal exit

Horizontal exit means a required doorway between 2 parts of a building separated from each other by a fire wall.

Loadbearing

Intended to resist vertical forces additional to those due to its own weight.

Non-combustible

Non-combustible means—

1. applied to a material — not deemed combustible as determined by AS 1530.1:1994 — Combustibility Tests for Materials; and
2. applied to construction or part of a building — constructed wholly of materials that are not deemed combustible.

Occupiable outdoor area

Occupiable outdoor area means a space on a roof, balcony or similar part of a building—

1. that is open to the sky; and
2. to which access is provided, other than access only for maintenance; and
3. that is not open space or directly connected with open space.

Open space

Open space means a space on the allotment, or a roof or similar part of a building adequately protected from fire, open to the sky and connected directly with a public road.

Performance Requirement

Performance Requirement means a requirement which states the level of performance which a Performance Solution or Deemed-to-Satisfy Solution must meet.

Performance Solution

Performance Solution means a method of complying with the Performance Requirements other than by a Deemed-to-Satisfy Solution.

Sarking-type material

Sarking-type material means a material such as a reflective insulation or other flexible membrane of a type normally used for a purpose such as waterproofing, vapour management or thermal reflectance.

Smoke developed index.

Smoke developed index means the index number for smoke as determined by AS/NZS 1530.3.

Smoke development rate

Smoke development rate means the development rate for smoke as determined by testing flooring materials in accordance with AS ISO 9239.1.

Smoke growth rate index

Smoke growth rate index (SMOGR RC) means the index number for smoke used in the regulation of fire hazard properties and applied to materials used as a finish, surface, lining or attachment to a wall or ceiling.

Sole-occupancy unit

Sole-occupancy unit means a room or other part of a building for occupation by one or joint owner, lessee, tenant, or other occupier to the exclusion of any other owner, lessee, tenant, or other occupier and includes—

1. a dwelling; or
2. a room or suite of rooms in a Class 3 building which includes sleeping facilities; or
3. a room or suite of associated rooms in a Class 5, 6, 7, 8 or 9 building; or
4. a room or suite of associated rooms in a Class 9c building, which includes sleeping facilities and any area for the exclusive use of a resident.

Annexure E - BCA Compliance Specification

The following BCA matters are to be addressed by specific BCA Design Certificate to be issued by the relevant architectural, services and engineering consultants at the Construction Certificate Stage. This schedule should be forwarded to all consultants to obtain verification that these items have and will be included in the design documentation / specifications:

Architectural Design Certification

1. The FRL's of building elements for the proposed works have been designed in accordance with S5C11 of Specification 5 of BCA2022 for a building of Type A Construction.
2. Lightweight construction used to achieve required fire resistance levels will comply with Specification 6 of BCA2022.
3. Building elements, including external walls and their components in buildings of Type A Construction, must be non-combustible in accordance with C2D10 of BCA2022.
4. Materials, floor and wall linings/coverings, surface finishes and air-handling ductwork used in the works will comply with the fire hazard properties of Clause C2D11 and Specification 7 of BCA2022.
5. Any concrete external walls that could collapse as complete panels (e.g. tilt-up and pre-cast concrete), in a building having a rise in storeys of not more than 2, will comply with Specification 8.
6. Any ancillary elements fixed, installed, or attached to the internal parts or external face of an external wall that is required to be non-combustible will comply with Clause C2D14 of BCA2022.
7. The external walls and openings of separate fire compartments will be protected in accordance with Clause C4D4.
8. The parts of different classifications located alongside one another in the same storey will be separated in accordance with Clause C3D9 and Specification 5 of BCA2022.
9. Floors separating storeys of different classifications will comply with BCA Clause C3D10 of BCA2022.
10. Equipment will be separated in accordance with Clause C3D13 of BCA2022.
11. Any electricity substation, any main switch room sustaining emergency equipment required to operate in emergency mode, will be separated from the remaining building with construction having an FRL 120/120/120 and provided with self-closing -/120/130 fire doors in accordance with Clause C3D14 of BCA2022.
12. Openings in the external walls that are required to have an FRL will be in located in accordance with Clause C4D3 and C4D4 of BCA2022 or protected in accordance with Clause C4D5 of BCA2022.
13. Doorways in any fire walls separating fire compartments will be protected in accordance with Clause C4D6 of BCA2022.
14. Doors in a fire-isolated exit will be self-closing or automatic closing fire doors with an FRL of not less than -/60/30 in accordance with Clause C4D9 of BCA2022.
15. Fire-isolated stairways will not be penetrated by services other than those permitted by Clause C4D10 of BCA2022.
16. Services penetrating elements required to possess an FRL including the floor slabs, walls, shafts, etc. will be protected in accordance with Clause C4D13, C4D14 and C4D15 and Specification 13 of BCA2022.

17. Construction joints, spaces and the like in and between building elements required to be fire-resisting with respect to integrity and insulation will be protected in accordance with BCA Clause C4D16.
18. The lift doors will be -/60/- fire doors complying with AS 1735.11:1986 in accordance Clause C4D11 of BCA2022.
19. Doorways and other opening in internal walls required to have an FRL will be protected in accordance with Clause C4D12 of BCA2022.
20. Columns protected by light weight construction will achieve an FRL not less than the FRL for the element it is penetrating, in accordance with Clause C4D17 of BCA2022.
21. A lintel will have the FRL required for the part of the building in which it is situated, unless it does not contribute to the support of a fire door, fire window or fire shutter, and it spans an opening in masonry which is not more than 150 mm thick and is not more than 3m wide if the masonry is non- loadbearing; or not more than 1.8m wide if the masonry is loadbearing and part of a solid wall or one of the leaves of a cavity wall, or it spans an opening in a non-loadbearing wall of the Class 2 or 3 building, in accordance with Specification 5 Clause S5C4 BCA2022.
22. The top and bottom of the riser shafts will achieve an FRL not less than the FRL required for the walls of the shaft in accordance with Clause S5C8 of Specification 5 of BCA2022.
23. Fire doors will comply with AS 1905.1:2015 and Specification C4D5 of BCA2022.
24. Fire shutters and fire windows will be in accordance with Specification 12 of BCA2022.
25. The required exits will be fire-isolated in accordance with Clause D2D4 of BCA2022.
26. The alternative exits will be distributed uniformly around the storey and will be not less than 9m apart, and not more that 45m apart in any residential portions or patient care areas in the health-care building, or otherwise not more than 60m apart, in accordance with Clause D2D6 of BCA2022.
27. The dimensions of exits and paths of travel to exits will be provided in accordance with Clause D2D7 to D2D11 of BCA2022.
28. The fire-isolated exits will be in accordance with Clause D2D12 of BCA2022.
29. Discharge from exits will be in accordance with Clause D2D15 of BCA2022.
30. The ladder from the plant, lift machine rooms, and electricity network substation in lieu of a stairway will be in accordance with Clause D2D21 of BCA2022.
31. Access to the lift pit will be in accordance with Clause D2D22 of BCA2022.
32. The stairway or ramp within the fire-isolated shaft is to be non-combustible, and if there is a local failure not cause structural damage or impair the fire resistance of the shaft, in accordance with Clause D3D3 of BCA2022.
33. The non-fire isolated stairs will be constructed in accordance with Clause D3D4 of BCA2022.
34. The construction separating rising and descending stairs in the fire-isolated exit stairway will be non-combustible and smoke proof, in accordance with Clause D3D5 of BCA2022.
35. The ramp or balcony provided for smoke hazard management requirements will be in accordance with Clause D3D6 of BCA2022.
36. The smoke lobby to the fire-isolated exit will be constructed in accordance with Clause D3D7 of BCA2022.
37. The construction of EDB's and telecommunications distribution boards will be in accordance with Clause D3D8 of BCA2022 with the enclosure bounded by non-combustible construction or fire protective

- covering and smoke seals provided around the perimeter of the non-combustible doors and any openings sealed with non-combustible mastic to prevent smoke spreading from the enclosure.
38. The enclosing walls and ceiling under the non-fire-isolated stairway will achieve an FRL of 60/60/60 and have a self-closing -/60/30 fire door, in accordance with Clause D3D9 of BCA2022.
 39. New pedestrian ramps will comply with AS 1428.1:2009, Clause D3D11 and Part D4 of BCA2022. The floor surface of a ramp must have a slip-resistance classification complying with Table D3D15 when tested in accordance with AS 4586:2013.
 40. The fire-isolated passageway will be in accordance with Clause D3D12 of BCA2022.
 41. The roof of the building where the exit discharges will have an FRL of 120/120/120 and will not have roof lights or openings within 3m of the path of travel in accordance with Clause D3D13 of BCA2022.
 42. Stair geometry to the new stairways will be in accordance with Clause D3D14 of BCA2022. Stair treads are to have a surface with a slip-resistance classification complying with Table D3D15 when tested in accordance with AS 4586:2013.
 43. Landings and door thresholds throughout the development will be provided in accordance with Clause D3D15 and D3D16 of BCA2022. Landings to have either a surface with a slip-resistance classification complying with Table D3D15 when tested in accordance with AS 4586:2013 or a strip at the edge of the landing with a slip-resistance classification complying with Table D3D15 when tested in accordance with AS 4586:2013 where the edge ledge to a flight below.
 44. The handrails and balustrades to all stairs and throughout the building will be in accordance with Clause D3D17 to D3D21, and D3D22 of BCA2022.
 45. The fixed platform, walkway, stairway and ladder and any associated going and riser, landing handrail, balustrade, located within the machinery room, boiler house, lift-machine room, plantroom, or non-habitable attic/storeroom within the sole occupancy unit will comply with AS 1657:2018 or Part D3 of BCA2022.
 46. The doorways and doors will be in accordance with Clause D3D24 and D3D25 of BCA2022.
 47. Door latching mechanisms will be in accordance with Clause D3D26 of BCA2022.
 48. Signage will be provided on fire and smoke doors in accordance with Clause D3D28 of BCA2022.
 49. The openable portion of a window in a bedroom of a Class 2 building will be protected with a restricting device or secure screen that does not allow a 125mm sphere to pass through the opening or screen and resist an outward horizontal action of 250N in accordance with Clause D3D29 of BCA2022. In addition to window protection, and for other openable windows 4 meters or more above the ground below, a barrier with a height not less than 865mm above the floor will be installed to the openable window.
 50. Fire precautions whilst the building is under construction will be in accordance with Clause E1D16 of BCA2022.
 51. Additional provisions will be made in accordance with Clause E1D17 and E2D21 of BCA2022, due to the special hazards associated with the building works or the location of the building works.
 52. External above ground waterproofing membranes will comply with Clause F1D5 of BCA2022 and AS 4654 Parts 1 & 2:2012.
 53. The new roof covering will be in accordance with Clause F3D2 of BCA2022.
 54. Any sarking proposed will be installed in accordance with Clause F3D3 of BCA2022.
 55. Waterproofing of all wet areas to the building will be carried out in accordance with Clause F2D2 and F2D3 of BCA2022 and AS 3740:2010.

56. Damp proofing of the proposed structure will be carried out in accordance with Clause F1D6 and F1D7 of BCA2022.
57. Floor wastes, including falls to floor wastes (including any voluntarily proposed floor wastes), will be installed in accordance with Clause F2D4 of BCA2022.
58. All new glazing to be installed throughout the development will be in accordance with Clause F3D4 of BCA2022 and AS 1288:2006 / AS 2047:2014.
59. Sanitary facilities will be provided in the building in accordance with Clause F4D2, Table F4D2, Clause F4D4 and Table F4D4 of BCA2022.
60. The construction of the sanitary facilities will be in accordance with Clause F4D8 of BCA2022.
61. Ceiling heights will be in accordance with Clause F5D2 of BCA2022.
62. Natural light will be provided in accordance with Clause F6D2, F6D3, and F6D4 of BCA2022.
63. Natural or mechanical ventilation will be provided in accordance with Clause F6D6, F6D7 and F6D8 of BCA2022.
64. Water closets and urinals will be located in accordance with Clause F6D9 of BCA2022.
65. The sanitary compartments will be either be provided with mechanical exhaust ventilation or an airlock in accordance with Clause F6D10 of BCA2022.
66. Pliable building membranes installed in external walls will comply with Clause F8D3 of BCA2022 and where a pliable building membrane is not installed in an external wall, the primary water control layer will be separated from water sensitive materials by a drained cavity.
67. Every storey of the carpark will be provided with an adequate system of permanent natural or mechanical ventilation in accordance with Clause F6D11 of BCA2022.
68. A safe manner for cleaning of windows located 3 or more storeys above ground level will be provided in accordance with the Work Health & Safety Act 2011 and regulations made under that Act in accordance with NSW G1D5 of BCA2022.
69. Boilers and pressure vessels shall be installed in accordance with Specification G2D2 of BCA2022.
70. The construction of the residential portions of the development will be undertaken in accordance with the relevant BASIX commitments that form part of the Development Consent approval.
71. Essential fire or other safety measures must be maintained and certified on an ongoing basis, in accordance with the provisions of the Environmental Planning and Assessment Regulation, 2021.
72. Building Fabric and Thermal Construction will be in accordance with Part J4 of BCA2022.
73. Glazing will be in accordance with Part J4 of BCA2022.
74. Building sealing will be in accordance with Part J5 of BCA2022.
75. Facilities for Energy Monitoring will be provided in accordance with Clause J9D3 of BCA2022.

Electrical Services Design Certification:

76. A smoke detection and alarm system will be installed throughout the building in accordance with E2D4 to E2D13, and Specification 20 of BCA2022, except where sprinkler system eliminates smoke detector locations.
77. Emergency lighting will be installed throughout the development in accordance with Clause E4D2, E4D4 of BCA2022 and AS/NZS 2293.1:2018.

78. Exit signage will be installed in accordance with Clause E4D5 and E4D8 of BCA2022 and AS/NZS 2293.1:2018.
79. Artificial lighting will be installed throughout the development in accordance Clause F6D5 of BCA2022 and AS/NZS 1680.0:2009.
80. Lighting power and controls will be installed in accordance with Part J7 of BCA2022.
81. Electrical conductors located within the building that supply a main switchboard that sustains emergency equipment will comply with Clause C3D14 of BCA2022.

Hydraulic Services Design Certification:

82. Storm water drainage will be provided in accordance with Clause F1D3 of BCA2022 and AS/NZS 3500.3:2018
83. Fire hydrant system will be installed in accordance with Clause E1D2 of BCA2022 and AS 2419.1:2005 as required.
84. Fire hose reels will be installed in accordance with Clause E1D3 of BCA2022 and AS 2441:2005.
85. A sprinkler system will be installed in accordance with Clause E1D4 of BCA2022 Specification 17, Specification 18 and AS2118.1.
86. Portable fire extinguishers will be installed in accordance with Clause E1D14 of BCA2022 and AS 2444:2001.
87. The heated water supply systems will be designed and installed to NCC Volume 3 – Plumbing code and Clause J8D2 of BCA2022.

Mechanical Services Design Certification:

88. An air-handling system which does not form part of a smoke hazard management system will be installed in accordance with Clause E2D3 of BCA2022, and AS 1668.1:2015.
89. Where not naturally ventilated the building will be mechanically ventilated in accordance with Clause F6D6 of BCA2022 and AS 1668.2:2012.
90. Every storey of the car park will be ventilated in accordance with Clause F6D11 of BCA2022 and where not naturally ventilated it will be mechanically ventilated in accordance with AS 1668.2:2012 as applicable.
91. The commercial kitchen will be provided with a kitchen exhaust hood in accordance with Clause F6D12 of BCA2022, and AS 1668.1:2015 and AS 1668.2:2012.
92. Exhaust systems installed in a kitchen, bathroom, sanitary compartment, or laundry of a Class 2 or 4 sole-occupancy unit will have a minimum flow rate and discharge location in accordance with Clause F8D4 of BCA2022.
93. Where exhaust discharges directly or via shaft into a roof space of a Class 2 or 4 sole-occupancy unit, ventilation of the roof space will comply with Clause F8D5 of BCA2022.
94. The air-conditioning and ventilations systems will be designed and installed in accordance with Part J6 of BCA2022
95. Rigid and flexible ductwork will comply with the fire hazard properties set out in AS 4254 Parts 1 and 2.

Structural Engineers Design Certification:

96. The material and forms of construction for the proposed works will be in accordance with Clause B1D3, B1D4 and B1D6 of BCA2022 as follows:
 - a. Dead and Live Loads – AS/NZS 1170.1:2002
 - b. Wind Loads – AS/NZS 1170.2:2011
 - c. Earthquake actions – AS 1170.4:2007
 - d. Masonry – AS 3700:2018
 - e. Concrete Construction – AS 3600:2018
 - f. Steel Construction AS 4100:1998
 - g. Aluminium Construction – AS/NZS 1664.1 or 2:1997
 - h. Timber Construction – AS 1720.1:2010
 - i. ABCB Standard for Construction of Buildings in Flood Hazard Areas.
97. The FRL's of the structural elements for the proposed works have been designed in accordance with Specification 5 of BCA2022, including S5C11 for a building of Type A Construction
98. The lift shaft will have an FRL in accordance with Clause C3D11 and Specification 5 of BCA2022.
99. Lightweight construction used to achieve required fire resistance levels will comply with Specification 6 of BCA2022.
100. The construction joints to the structure will be in accordance with Clause C4D16 of BCA2022 to reinstate the FRL of the element concerned.
101. The concrete panel external walls will be in accordance with Specification 5 of BCA2022.
102. Upon completion of the works, a structural engineer will be able to certify that local failure will be in accordance with Clause D3D3 of BCA2022 for the fire isolated stairs.

Lift Services Design Certification:

103. The lifts throughout the development will be provided with stretcher facilities in accordance with Clause E3D3 of BCA2022 and will be capable of accommodating a stretcher with a patient lying horizontally by providing a clear space not less than 600mm wide x 2000mm long x 1400mm high above the floor level.
104. Warning signage in accordance with Clause E3D4 of BCA2022 will be provided to the lifts to advise not to use the lifts in a fire.
105. A fire service recall control switch is to be installed on a landing at a location nominated by the appropriate authority in accordance with Clause E3D11.
106. A lift car fire service drive control switch is to be installed within the lift car in accordance with Clause E3D12.
107. Access and egress to the lift well landings will comply with the Deemed-to-Satisfy Provisions of D4 of the BCA2022 and will be suitable to accommodate disabled persons.
108. The type of lifts will also be suitable to accommodate persons with a disability in accordance with Clause E3D7 and E3D8 and will also have accessible features in accordance with E3D7 and E3D8 of BCA2022.
109. The lifts will comply with AS 1735.12:1999 in accordance with Clause E3D7 and E3D8 of BCA2022.

110. All electric passenger lifts and electrohydraulic passenger lifts shall comply with Specification 24 of BCA2022.

Acoustic Services Design Certification:

111. The sound transmission and insulation of the residential portions of the development will comply with Part F7 of BCA2022.

NSW Specification Design Certificate:

112. Materials, floor and wall linings/coverings, surface finished, and air-handling ductwork used in the works will comply with the fire hazard properties in accordance with Clause C2D11, NSW Clause C2D11, Specification 5 and NSW Specification 5 of BCA2022.

113. The building will be separated in accordance with Clause C3D6, and NSW Clause C3D6 of BCA2022.

114. Doorways and other openings in internal walls required to have an FRL will be protected in accordance with Clause C4D12, and NSW Clause C4D12(4) of BCA2022.

115. The discharge points of exits will be in accordance with Clause D2D15, and NSW Clause D2D15(6) of BCA2022.

116. The width of doorways in exits and paths of travel to exits will be provided in accordance with Clause D2D9, and NSW Clause D2D9(a) to (f) of the BCA2022.

117. Stair geometry to the new stairways will be in accordance with Clause D3D14, and NSW Clause D3D14(1) of the BCA. Stair treads are to have a surface with a slip-resistance classification complying with Table D3D154 when tested in accordance with AS 4586:2013 or a nosing strip with a slip-resistance classification complying with Table D3D15 when tested in accordance with AS 4586:2013.

118. Landings and door thresholds throughout the development will be provided in accordance with Clause D3D15 and D3D162.15, and NSW Clause D3D16(a) to (e) of the BCA. Landings to have either a surface with a slip-resistance classification complying with Table D2.14 when tested in accordance with AS 4586:2013 or a strip at the edge of the landing with a slip-resistance classification complying with Table D3D15 when tested in accordance with AS 4586:2013 where the edge leads to a flight below.

119. The height of barriers is to be in accordance with D3D18 and NSW D3D18(1) of the BCA2022.

120. The doorways and doors will be in accordance with Clause D3D24, NSW Clause D23D24(2) of the BCA2022.

121. The door latching mechanisms to the proposed required exit doors will be in accordance with Clause D3D26 and NSW Clause D3D26(5) and (6) of the BCA2022.

122. The development consists of a drive-in theatre therefore it is to comply with NSW Part I6

123. Insulation will be in accordance with AS/NZS 4859.1:2018 and will be installed as required by NSW Part J4 of the BCA.

124. A smoke detection and alarm systems will be installed throughout the building in accordance with E2D10, NSW E2D10 and NSW Specification 20 of BCA2022.

125. Exit signage will be installed in accordance with Clause E4D5, NSW Clause E4D6 and E4D8 of BCA2022 and AS/NZS 2293.1:2018.

126. The building will be mechanically ventilated in accordance with Clause F6D6, NSW F6D6 of BCA2022 and AS 1668.2:2012.