

Landscape Referral Response

Application Number:	DA2018/1816
Date:	26/02/2019
Responsible Officer:	Ashley Warnest
Land to be developed (Address):	Lot 12 DP 1014199 , 102 Wakehurst Parkway ELANORA HEIGHTS NSW 2101

Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- Mixed use developments containing three or more residential dwellings.
- New Dwellings or

Officer comments

The landscape component has been addressed in detail in the Natural Environment - Biodiversity referral.

No objections subject to conditions.

Referral Body Recommendation

Recommended for approval, subject to conditions

Refusal comments

Recommended Landscape Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Tree protection

(a) Existing trees which must be retained

- All trees not indicated for removal on the approved plans, unless exempt under relevant planning instruments or legislation
- Trees located on adjoining land

(b) Tree protection

- No tree roots greater than 50mm diameter are to be cut from protected trees unless authorised by the Project Arborist on site.
- All structures are to bridge tree roots greater than 50mm diameter unless directed

otherwise by the Project Arborist on site.

iii) All tree protection to be in accordance with the approved Tree Protection Plan and AS4970-2009 Protection of trees on

development sites, with particular reference to Section 4 Tree Protection Measures.

iv) All tree pruning within the subject site is to be in accordance with WDCP2011 Clause E1 Private Property Tree Management and AS 4373 Pruning of amenity trees

v) All tree protection measures, including fencing, are to be in place prior to commencement of works.

Reason: To ensure compliance with the requirement to retain and protect significant planting on the site.

Project Arborist

i) A Project Arborist with minimum qualification AQF Level 5 is to be appointed prior to commencement of works.

ii) The Project Arborist is to oversee all tree protection measures, removals and works adjacent to protected trees as outlined in the approved Tree Protection Plan and AS4970-2009 Protection of trees on development sites.

iii) The Project Arborist is to ensure compliance as relevant with any other environmental requirements conditioned under this consent.

Reason: to ensure protection of vegetation proposed for retention on the site.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Protection of rock and sites of significance

a) All rock outcrops outside of the area of approved works are to be preserved and protected at all times during demolition excavation and construction works.

b) Should any Aboriginal sites be uncovered during the carrying out of works, those works are to cease and Council, the NSW Office of Environment and Heritage (OEH) and the Metropolitan Local Aboriginal Land Council are to be contacted.

Reason: Preservation of significant environmental features.