

Building Assessment Referral Response

Application Number:	DA2024/0819
Proposed Development:	Demolition works and construction of a dual occupancy
Date:	02/07/2024
To:	Anaiis Sarkissian
Land to be developed (Address):	Lot 12 DP 7236 , 8 Seabeach Avenue MONA VALE NSW 2103

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application has been investigated with respects to aspects relevant the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Building Assessment Conditions

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Fire Separation - Class 1 Buildings

A separating wall between Class 1 buildings, or a wall that separates a Class 1 building from a Class 10a building which is not associated with the Class 1 building is required to comply with Part 9.3 of the National Construction Code – Housing Provisions – ‘Fire Protection of Separating Walls and Floors’.

Details demonstrating compliance are to be provided to the Certifier prior to the issue of the



Construction Certificate.

Reason: To ensure adequate provision is made for fire safety and for building occupant safety.