

PRELIMINARY GEOTECHNICAL ASSESSMENT: **4 Jamieson Avenue, Fairlight**

1.0 Proposed Development

- 1.1 Demolish and replace the existing carport and driveway.
- 1.2 Extend the first floor of the existing house on the S side.
- 1.3 Construct a paved area with roof in the NW corner of the property.
- 1.4 Landscaping works in the NE corner of the property requiring minor filling.
- 1.5 Other minor external alterations.
- 1.6 No significant excavations are required.
- 1.7 Details of the proposed development are shown on 23 drawings prepared by Hobbs Jamieson Architecture, job number 23/004, drawings numbered DA 00 to DA 22, Revision A, dated 25/3/24.

2.0 Site Location

- 2.1 The site was inspected on the 12th March, 2024.
- 2.2 This residential property is on the low side of the road and has a N aspect. It is located on the gently graded lower reaches of a hillslope. No rock outcrops on the property. The Sydney 1:100 000 Geological Sheet indicates the site is underlain by Hawkesbury Sandstone that is described as a medium to coarse grained quartz sandstone with very minor shale and laminite lenses. Sandstone bedrock is expected to underlie the surface at relatively shallow depths. The natural surface of the block has been altered little with the development to date. The proposed landscaping works will require minor filling.

2.3 The site shows no indications of historical movement in the natural surface that could have occurred since the property was developed. We are aware of no history of instability on the property.

3.0 Site Description

The natural slope falls across the property at gentle angles. At the road frontage, a concrete and brick paved driveway runs to a carport on the SE side of the house. The part two-storey house with deck is supported on brick walls and piers. The supporting walls show no significant signs of movement and the supporting piers stand vertical. Gently sloping lawn and garden areas extend off the uphill and downhill sides of the house. The area surrounding the house is mostly lawn/garden covered with some paved areas. No signs of movement associated with slope instability were observed on the grounds. No cliffs or large rock faces were observed on the property or in the near vicinity. The adjoining neighbouring properties were observed to be in good order as seen from the road and the subject property.

4.0 Recommendations

The proposed development and site conditions were considered and applied to the current council requirements. See the required inspection below that is to be carried out during construction and is a requirement for the final geotechnical certification. Apart from the inspection, it is not expected additional geotechnical input will be required provided good design and building practices are followed.

REQUIRED INSPECTION ON NEXT PAGE

5.0 Inspection

The client and builder are to familiarise themselves with the following required inspection as well as council geotechnical policy. We cannot provide geotechnical certification for the owners or the regulating authorities if the following inspection has not been carried out during the construction process.

- All footings are to be inspected and approved by the geotechnical consultant while the excavation equipment and contractors are still onsite and before steel reinforcing is placed or concrete is poured.

White Geotechnical Group Pty Ltd.



Dion Sheldon
BEng(Civil)(Hons),
Geotechnical Engineer.

Reviewed By:



Nathan Gardner B.Sc. (Geol. & Geophys. & Env. Stud.)
AIG., RPGeo Geotechnical & Engineering.
No. 10307
Engineering Geologist & Environmental Scientist.



Information about your Preliminary Assessment

This Preliminary Assessment relies on visual observations of the surface features observed during the site inspection. Where reference is made to subsurface features (e.g. the depth to rock) these are interpretations based on the surface features present and previous experience in the area. No ground testing was conducted as part of this assessment and it is possible subsurface conditions will vary from those interpreted in the assessment.

In some cases, we will recommend no further geotechnical assessment is necessary despite the presence of existing fill or a rock face on the property that exceed the heights that would normally trigger a full geotechnical report, according to the Preliminary Assessment Flow Chart. Where this is the case, if it is an existing fill, it is either supported by a retaining wall that we consider stable, or is battered at a stable angle and situated in a suitable position on the slope. If it is a rock face that exceeds the flow chart limit height, the face has been deemed to be competent rock that is considered stable. These judgements are backed by the inspection of over 5000 properties on Geotechnical related matters.

The proposed excavation heights referred to in section 1.0 of this assessment are estimated by review of the plans we have been given for the job. Although we make every reasonable effort to provide accurate information excavation heights should be checked by the owner or person lodging the DA. If the excavation heights referred to in in section 1.0 of this assessment are incorrect we are to be informed immediately and before this assessment is lodged with the DA.