

Environmental Health Referral Response - Solid Fuel Heaters

Application Number:	DA2024/0888
Proposed Development:	Alterations and additions to a dwelling house including secondary dwelling
Date:	23/07/2024
Responsible Officer	Megan Surtees
Land to be developed (Address):	Lot 40 DP 31139 , 10 Lentara Road BAYVIEW NSW 2104

Reasons for referral

This application requires detailed consideration of solid fuel heaters. And as such, Council's Environmental Investigations officers are required to consider the likely impacts.

Officer comments General Comments

This application is seeking consent for alterations and additions to the existing dwelling and the construction of a secondary dwelling.

There is a proposed fireplace proposed however Environmental Health are of the opinion that given the location of the dwelling, the flue exist can comply with the current Australian Standards.

Environmental Health recommends approval subject to conditions.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Environmental Investigations Conditions:

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Installation and certification of solid/fuel burning heater

The solid fuel heater must be certified to comply with Australian Standards 4012 and 4013.

Provide to the Principal Certifier certification that the solid fuel heater has been installed by an appropriately experienced and qualified person, in accordance with the relevant provisions of AS2918 – Domestic Solid Fuel Burning Appliances – Installation.

Reason: To ensure the installation is completed in a legislatively compliant manner.

Certification of solid fuel burning heaters

A certificate from an appropriately qualified person indicating the system is compliant with all relevant legislation, Building Code of Australia, Australian Standards, Specifications and manufacturer requirements is to be submitted to Council prior to the operation of the solid fuel heater.

Reason: To ensure the system operates in a legislatively compliant manner.