

## Natural Environment Referral Response - Flood

Application Number:	DA2021/0669
---------------------	-------------

Date:	30/08/2021
То:	Jordan Davies
Land to be developed (Address):	Lot 7005 DP 1117451, 1193 Barrenjoey Road PALM BEACH NSW 2108 Lot 7002 DP 1117592, 1193 Barrenjoey Road PALM BEACH NSW 2108 Lot 298 DP 721522, 1191 Barrenjoey Road PALM BEACH NSW 2108

#### Reasons for referral

This application seeks consent for the following:

- All Development Applications on land below the 1 in100 year flood level;
- All Development Applications located on land below the Probable Maximum Flood levels.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

#### Officer comments

A detailed site specific Flood Impact Assessment has been undertaken for the site prepared by Cardno (NSW/ACT) Pty Ltd dated 16 August 2021. The Flood Study identifies that the floor levels for the proposed ground floor of the boathouse, sewer tank/grease arrestor and male and female toilets have an appropriate freeboard in a Probable Maximum Flood event. The Boat Hire General Storage and Bin Room are located marginally below the Probable Maximum Flood level and conditions are included to ensure that these buildings are flood proofed to reduce potential flood damages.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

#### **Recommended Natural Environment Conditions:**

# CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

#### **Flooding**

In order to protect property and occupants from flood risk the following is required:

## Building Components and Structural Soundness - B1

All new development below the Flood Planning Level of shall be designed and constructed as flood compatible buildings in accordance with Reducing Vulnerability of Buildings to Flood Damage:

DA2021/0669 Page 1 of 2



Guidance on Building in Flood Prone Areas, Hawkesbury-Nepean Floodplain Management Steering Committee (2006).

#### Building Components and Structural Soundness – B2

All new development must be designed to ensure structural integrity up to the Probable Maximum Flood level of 2.93m AHD, taking into account the forces of floodwater, wave action, flowing water with debris, buoyancy and immersion.

#### Building Components and Structural Soundness - B3

All new electrical equipment, power points, wiring, fuel lines, sewerage systems or any other service pipes and connections must be waterproofed and/or located above the Flood Planning Level. All existing electrical equipment and power points located below the Flood Planning Level must have residual current devices installed to cut electricity supply during flood events.

#### Fencing – F1

New fencing (including pool fencing, boundary fencing, balcony balustrades and accessway balustrades) shall be open to allow for the unimpeded movement of flood waters. It must be designed with a minimum of 50% open area from the natural ground level up to the 1% AEP flood level. Openings should be a minimum of 75mm x 75mm.

## Storage of Goods - G1

Storage areas for hazardous or potentially polluting materials shall not be located below the Flood Planning Level unless adequately protected from floodwaters in accordance with industry standards.

## Flood Proofing

The floor levels of the Boat Hire General Storage and Bin Room must be wet flood proofed up to the Probable Maximum Flood level of 2.93m AHD.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.

DA2021/0669 Page 2 of 2