

## Engineering Referral Response

<b>Application Number:</b>	DA2021/2580
<b>Date:</b>	10/02/2022
<b>To:</b>	Nick England
<b>Land to be developed (Address):</b>	Lot 6 DP 736961 , 10 Fern Creek Road WARRIEWOOD NSW 2102

### Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m<sup>2</sup> or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

### Officer comments

**9/Feb/2022:**

#### Stormwater

Submitted stormwater plans have been reviewed.

No objection to approval subject to conditions as recommended.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Engineering Conditions:

## CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

### On-site Stormwater Detention Details

The Applicant is to provide a certification of drainage plans detailing the provision of stormwater controls in accordance with Northern Beaches Council's WATER MANAGEMENT POLICY FOR DEVELOPMENT and generally in accordance with the concept drainage plans prepared by **CAM Consulting, Drawing No-C21187-SW01 & SW02, Rev B, Dated 21/9/2021**. Detailed drainage plans are to be prepared by a suitably qualified Civil Engineer, who has membership to the Institution of

Engineers Australia, National Professional Engineers Register (NPER) and registered in the General Area of Practice for civil engineering.

The drainage plans must address the following:

- i. The clean out pipe is to be extended to the rain garden top water level to ensure any overflow is directed to the adjacent easement inlet pit.
- ii. A 3000 litres rainwater tank for non-potable purposes is to be installed and used as part of an integrated on-site Stormwater management system in accordance with Development Consent N0540/15.
- iii. The inter allotment drainage easement should be free of any structures including raingarden.

Detailed drainage plans, including engineering certification, are to be submitted to the Certifying Authority for approval prior to the issue of the Construction Certificate.

Reason: To ensure appropriate provision for the disposal of stormwater and stormwater management arising from the development.

## **CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE**

### **Stormwater Disposal**

The stormwater drainage works shall be certified as compliant with all relevant Australian Standards and Codes by a suitably qualified person. Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of any final Occupation Certificate.

Reason: To ensure appropriate provision for the disposal of stormwater arising from the development.