

## Landscape Referral Response

<b>Application Number:</b>	DA2019/1369
<b>Date:</b>	04/03/2020
<b>Responsible Officer:</b>	Nick England
<b>Land to be developed (Address):</b>	Lot 6 DP 13900 , 139 Headland Road NORTH CURL CURL NSW 2099

### Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- Mixed use developments containing three or more residential dwellings.
- New Dwellings or

### Officer comments

The plans indicate no significant landscape features are affected by the proposed works. Some rock outcrop is evident in the front of the property which would be affected by the works, however it is not considered significant in this instance.

No objections are raised to approval subject to conditions as recommended.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Landscape Conditions:

#### **CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT**

#### **Tree protection**

- (a) Existing trees which must be retained
- All trees not indicated for removal on the approved plans, unless exempt under relevant planning instruments or legislation
  - Trees located on adjoining land

(b) Tree protection

- No tree roots greater than 25mm diameter are to be cut from protected trees unless authorised by a qualified Arborist on site.
- All structures are to bridge tree roots greater than 25mm diameter unless directed otherwise by a qualified Arborist on site.

- iii) All tree protection to be in accordance with AS4970-2009 Protection of trees on development sites, with particular reference to Section 4 Tree Protection Measures.
- iv) All tree pruning within the subject site is to be in accordance with WDCP2011 Clause E1 Private Property Tree Management and AS 4373 Pruning of amenity trees
- v) All tree protection measures, including fencing, are to be in place prior to commencement of works.

Reason: To ensure compliance with the requirement to retain and protect significant planting on the site.

## CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

### Protection of rock and sites of significance

- a) All rock outcrops outside of the area of approved works are to be preserved and protected at all times during demolition excavation and construction works.
- b) Should any Aboriginal sites be uncovered during the carrying out of works, those works are to cease and Council, the NSW Office of Environment and Heritage (OEH) and the Metropolitan Local Aboriginal Land Council are to be contacted.

Reason: Preservation of significant environmental features.

## CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

### Required Planting

Trees shall be planted in accordance with the following schedule:

Minimum No. of Trees Required.	Species	Location	Minimum Pot Size
2	Trees capable of attaining a minimum height of 4 metres at maturity	Grounds of property	200mm

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To maintain environmental amenity.