



## Flood Structural Integrity Compliance Statement

Date: 25 October 2017 Job No. 191044

Client: Yourstyle Engineer: RW

**Site: 15 Gondola Road, Narrabeen**

Northern Beaches Consulting Engineers P/L has prepared a structural design for the proposed additions and alterations at the above site (Job No: 191044, Drawing Numbers S01 to S04).

The existing and proposed structure will be adequate to endure a flood level of RL4.9m AHD, and debris caused by a water velocity of 0.5m/s.

This certificate does not relate to and we assume no responsibility for the certification of any structural or other elements that have not been inspected by the companies' representatives or are not referred to in this certificate.

We trust that this meets with your requirements. Please contact the author if further clarification is required.

### NORTHERN BEACHES CONSULTING ENGINEERS P/L

**Rick Wray**  
BE CPEng NPER Director