

Environmental Health Referral Response - commercial use

Application Number:	DA2020/0824
Date:	14/08/2020
To:	Daniel Milliken
Land to be developed (Address):	Lot 21 DP 11320 , 323 - 325 Condamine Street MANLY VALE NSW 2093 Lot 22 DP 11320 , 323 - 325 Condamine Street MANLY VALE NSW 2093 Lot 123 DP 737259 , 327 - 329 Condamine Street MANLY VALE NSW 2093 Lot 25 DP 11320 , 331 Condamine Street MANLY VALE NSW 2093 Lot 20 DP 11320 , 321 Condamine Street MANLY VALE NSW 2093

Reasons for referral

This application seeks consent for one or more of the following:

- Food premises, or
- Backpackers/Boarding house, or
- Mortuary, or
- Skin penetration, acupuncture, tattoo, beauty salon, or
- Public pool

And as such, Council's Environmental Health and Protection officers are required to consider the likely impacts.

Officer comments General Comments

Retail spaces are identified in the plans as food business spaces. Standard food business conditions to be recommended.

Recommendation

APPROVAL - subject to conditions

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Environmental Health and Protection Conditions:

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Kitchen Design, construction and fit out of food premises certification

Prior to the issuing of any interim / final occupation certificate, certification that the design, construction and fit out of food premises kitchen is compliant with the requirements of AS 4674 Design, construction and fit out of food premises are to be submitted to the Principal Certifying Authority.

Reason: To ensure that the kitchen complies with the design requirements.

Mechanical Ventilation certification

Prior to the issuing of any interim / final occupation certificate, certification is to be provided by the installer of the mechanical ventilation system that the design, construction and installation of the mechanical ventilation system is compliant with the requirements of *AS1668 The use of mechanical ventilation*.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

Reason: To ensure that the mechanical ventilation system complies with the design requirements.