

Natural Environment Referral Response - Coastal

Application Number:	DA2021/0028
Date:	02/02/2021
Responsible Officer	Kye Miles
Land to be developed (Address):	Lot 8 DP 25959 , 14 Lalchere Street CURL CURL NSW 2096

Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The application has been assessed in consideration of the *Coastal Management Act 2016*, State Environmental Planning Policy (Coastal Management) 2018 and has also been assessed against requirements of the Warringah LEP 2011 and Warringah DCP 2011.

Coastal Management Act 2016

The subject site has been identified as being within the coastal zone and therefore *Coastal Management Act 2016* is applicable to the proposed development. The proposed development is in line with the objects, as set out under Clause 3 of the *Coastal Management Act 2016*.

State Environmental Planning Policy (Coastal Management) 2018

The subject land has been included on the 'Coastal Environment Area' and 'Coastal Use Area' maps under the State Environmental Planning Policy (Coastal Management) 2018 (CM SEPP). Hence, Clauses 13, 14 and 15 of the CM SEPP apply for this DA.

Comment:

On internal assessment, the DA satisfies requirements under clauses 13, 14 and 15 of the CM SEPP.

As such, it is considered that the application does comply with the requirements of the State Environmental Planning Policy (Coastal Management) 2018.

Warringah LEP 2011 and Warringah DCP 2011

No other coastal related issues identified.

As such, it is considered that the application does comply with the requirements of the coastal relevant clauses of the Warringah LEP 2011 and Warringah DCP 2011.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

**CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION
CERTIFICATE**

Swimming Pools

The backwash of Swimming Pool water must be discharged to Sydney Water's sewer in accordance with Australian/New Zealand Standard AS/NZS 3500. Detailed plans and specification must be submitted prior to the issue of the Construction Certificate. The drawings must show the location of Sydney Water's sewer, the yard gully or any new connection to the sewer system including a detailed cross section of the connection complying with Australian/New Zealand Standard AS/NZS 3500.

Reason: To ensure compliance with legislation and Australian Standards and to protect public health, amenity and to ensure the protection and preservation of receiving waters.

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site