

Sent:	31/07/2020 10:42:04 AM
Subject:	NSW RFS Determination - Your Reference - DA2020/0694 (CNR-9842)
Attachments:	DA20200724002684-Original-1 - 30-07-2020 10_17_44 - Determination Letter.pdf;



NSW RURAL FIRE SERVICE

Attention: Livia Kekwick

Your Reference: DA2020/0694 (CNR-9842)

Application Details: s4.14 – Infill – Original

Site Address:

16 Marshall Crescent
Beacon Hill NSW 2100

Please find attached correspondence relating to the above development.

Should you wish to discuss this matter please contact Adam Small on 1300 NSW RFS and quote DA20200724002684-Original-1.



Planning and Environment Services

NSW RURAL FIRE SERVICE

Locked Bag 17 Granville NSW 2142

P 1300 NSW RFS **E** records@rfs.nsw.gov.au

www.rfs.nsw.gov.au | www.facebook.com/nswrfs | www.twitter.com/nswrfs

PREPARE. ACT. SURVIVE.



NSW RURAL FIRE SERVICE

Northern Beaches Council
PO Box 882
MONA VALE NSW 1660

Your reference: DA2020/0694 (CNR-9842)
Our reference: DA20200724002684-Original-1

ATTENTION: Livia Kekwick

Date: Friday 31 July 2020

Dear Sir/Madam,

Development Application

s4.14 - Infill - Single Dwelling - Alterations & Additions

16 Marshall Crescent Beacon Hill NSW 2100, 97//DP204344, 97//DP204344

I refer to your correspondence dated 24/07/2020 seeking advice regarding bush fire protection for the above Development Application in accordance with section 4.14 of the *Environmental Planning and Assessment Act 1979*.

The New South Wales Rural Fire Service (NSW RFS) has considered the information submitted and provides the following recommended conditions:

Asset Protection Zones

Intent of measures: to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting firefighting activities.

1. From the start of building works, and in perpetuity to ensure ongoing protection from the impact of bush fires, the entire property must be managed as an inner protection area (IPA) in accordance with the requirements of Appendix 4 of *Planning for Bush Fire Protection 2019*. When establishing and maintaining an IPA the following requirements apply:

- tree canopy cover should be less than 15% at maturity;
- trees at maturity should not touch or overhang the building;
- lower limbs should be removed up to a height of 2m above the ground;
- tree canopies should be separated by 2 to 5m;
- preference should be given to smooth barked and evergreen trees;
- large discontinuities or gaps in vegetation should be provided to slow down or break the progress of fire towards buildings;
- shrubs should not be located under trees;
- shrubs should not form more than 10% ground cover;
- clumps of shrubs should be separated from exposed windows and doors by a distance of at least twice the height of the vegetation.

Postal address

NSW Rural Fire Service
Locked Bag 17
GRANVILLE NSW 2142

Street address

NSW Rural Fire Service
4 Murray Rose Ave
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555
F (02) 8741 5550
www.rfs.nsw.gov.au

- grass should be kept mown (as a guide grass should be kept to no more than 100mm in height); and
- leaves and vegetation debris should be removed

Construction Standards

Intent of measures: to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting firefighting activities.

2. New construction must comply with Sections 3 and 9 (BAL FZ) of Australian Standard AS3959-2018 *Construction of buildings in bush fire-prone areas* or NASH Standard (1.7.14 updated) *National Standard Steel Framed Construction in Bushfire Areas – 2014* as appropriate and Section 7.5 of *Planning for Bush Fire Protection 2019*.

3. The existing building must be upgraded to improve ember protection by enclosing all openings (excluding roof tile spaces) or covering openings with a non-corrosive metal screen mesh with a maximum aperture of 2mm. Where applicable, this includes any sub floor areas, openable windows, vents, weepholes and eaves. External doors are to be fitted with draft excluders.

Water and Utility Services

Intent of measures: to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting firefighting activities.

4. The provision of water, electricity and gas must comply with Table 7.4a of *Planning for Bush Fire Protection 2019*.

General Advice – Consent Authority to Note

The application has been assessed as an addition to a single dwelling as advised by Council. Any future conversion of the addition for use as a secondary dwelling or granny flat will require referral to the NSW Rural Fire Service. Any such application is unlikely to be supported as the secondary dwelling/granny flat would be located in the flame zone which is not supported by NSW Rural Fire Service Fast Fact No. 4/12 *Increased Density on a Single Parcel of Land*.

The NSW Rural Fire Service recognises that the site is constrained and that the proposed development falls within the Flame Zone. Flame Zone development is high-risk development; consequently, in situations such as this, the NSW Rural Fire Service seeks to improve the overall fire safety of the existing development. This requires greater emphasis on construction standards, landscaping, siting, and vegetation management practices to ensure improved levels of protection are afforded to the development, its occupants and fire fighters. The NSW Rural Fire Service has undertaken a merit based assessment of the proposal and provides the above advice in accordance with *Planning for Bush Fire Protection 2019*.

For any queries regarding this correspondence, please contact Adam Small on 1300 NSW RFS.

Yours sincerely,

Nika Fomin
Manager Planning & Environment Services
Planning and Environment Services