

## Parks, Reserves and Foreshores Referral Response

<b>Application Number:</b>	DA2021/2596
<b>Date:</b>	12/01/2022
<b>To:</b>	Dean Pattalis
<b>Land to be developed (Address):</b>	Lot 10 DP 15762 , 13 Bruce Street MONA VALE NSW 2103 Lot 10 DP 15762 , 13 Bruce Street MONA VALE NSW 2103 Lot 9 DP 15762 , 11 Bruce Street MONA VALE NSW 2103

### Reasons for referral

This application seeks consent for any application on land or land being adjoining or adjacent to any parks, reserves, beaches, or foreshore

And as such, Council's Parks, Reserves and Foreshores officers are required to consider the likely impacts of the proposal.

### Officer comments

The development application is for the demolition of an existing timber and trellis dividing fence between adjoining properties and construction of a new rendered concrete block and timber dividing fence.

The development site adjoins Warriewood Beach Reserve that is located downslope of the property.

All development works must ensure that surface sediment runoff and/or erosion is controlled, managed and contained within the site boundaries and prevented from travelling across the boundary and into the Reserve.

No physical encroachments over the site boundaries and into the public Reserve are permitted, and structures and built elements are to be contained within private property boundaries.

Public access to the Reserve is not impacted by the proposed works.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Parks, Reserves and Foreshores Conditions:

#### **CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT**

#### **Installation and Maintenance of Sediment and Erosion Control**

Prior to commencement of works on site, sediment and erosion controls must be installed along the immediate downslope of the works area in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004).

The erosion controls shall be maintained in an operational condition until the development activities have been completed and the site fully stabilised. Sediment shall be removed from the sediment controls following each heavy or prolonged rainfall period.

Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site.

## **CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK**

### **No Access Through Land Owned or Managed by Council**

Site access is not approved for delivery of materials nor construction of the development through adjacent land owned or managed by Council, without the written approval of Council.

Reason: Public safety, landscape amenity and tree protection.

### **Storage of Materials on Land Owned or Managed by Council Prohibited**

The dumping or storage of building materials, spoil, vegetation, green waste or any other material in land owned or managed by Council is prohibited.

Reason: Public safety and environmental protection.

### **Protection of Council's Public Assets**

Any damage to Council's public assets shall be made good by the applicant, and/or the contractor, to the satisfaction of Council.

Council's public assets include, but is not limited to, the following: road, kerb and gutters, crossovers, crossings, paths, grass verge, trees and vegetation, open space and associated elements such as furniture, recreational facilities and the like, within the meaning of the Local Government Act 1993.

Reason: To protect and/or restore any damaged public asset.