BASIX[°]Certificate

Building Sustainability Index www.basix.nsw.gov.au

Single Dwelling

Certificate number: 1229951S

This certificate confirms that the proposed development will meet the NSW government's requirements for sustainability, if it is built in accordance with the commitments set out below. Terms used in this certificate, or in the commitments, have the meaning given by the document entitled "BASIX Definitions" dated 10/09/2020 published by the Department. This document is available at www.basix.nsw.gov.au

Secretary Date of issue: Thursday, 19 May 2022 To be valid, this certificate must be lodged within 3 months of the date of issue.



Planning, Industry & Environment

| Project summary | | | | |
|---------------------------|---|--|--|--|
| Project name | 41 Coasters Retreat Revised | | | |
| Street address | 41 Coasters Retreat Coasters Retreat 2108 | | | |
| Local Government Area | Northern Beaches Council | | | |
| Plan type and plan number | deposited 25653 | | | |
| Lot no. | 5 | | | |
| Section no. | - | | | |
| Project type | separate dwelling house | | | |
| No. of bedrooms | 3 | | | |
| Project score | | | | |
| Water | V 76 Target 40 | | | |
| Thermal Comfort | V Pass Target Pass | | | |
| Energy | V 97 Target 50 | | | |

Name / Company Name: Graham Midgley

ABN (if applicable): N/A

Description of project

Project address

| 41 Coasters Retreat Revised | | |
|---|--|--|
| 41 Coasters Retreat Coasters Retreat 2108 | | |
| Northern Beaches Council | | |
| Deposited Plan 25653 | | |
| 5 | | |
| - | | |
| | | |
| separate dwelling house | | |
| 3 | | |
| | | |
| 2226 | | |
| 216 | | |
| 167.4 | | |
| 41.5 | | |
| 100 | | |
| | | |

| Assessor details and thermal loads | | | | | | | |
|---|--------|-------------|--|--|--|--|--|
| Assessor number | n/a | | | | | | |
| Certificate number | n/a | | | | | | |
| Climate zone | n/a | | | | | | |
| Area adjusted cooling load (MJ/m ² .year) | n/a | | | | | | |
| Area adjusted heating load (MJ/m ² .year) | n/a | | | | | | |
| Ceiling fan in at least one bedroom | n/a | | | | | | |
| Ceiling fan in at least one living room or other conditioned area | n/a | | | | | | |
| Project score | | | | | | | |
| Water | 76 | Target 40 | | | | | |
| Thermal Comfort | V Pass | Target Pass | | | | | |
| Energy | 97 | Target 50 | | | | | |

Schedule of BASIX commitments

The commitments set out below regulate how the proposed development is to be carried out. It is a condition of any development consent granted, or complying development certificate issued, for the proposed development, that BASIX commitments be complied with.

| Water Commitments | Show on CC/CDC plans & specs | Certifier check | |
|---|------------------------------|--|---|
| Fixtures | · | | |
| The applicant must install showerheads with a minimum rating of 3 star (> 7.5 but <= 9 L/min) in all showers in the development. | | _ | ~ |
| The applicant must install a toilet flushing system with a minimum rating of 1 star in each toilet in the development. | | ~ | ~ |
| The applicant must install taps with a minimum rating of 3 star in the kitchen in the development. | | ~ | |
| The applicant must install basin taps with a minimum rating of 3 star in each bathroom in the development. | | Image: A set of the set of the | |
| Alternative water | | | |
| Rainwater tank | | | |
| The applicant must install a rainwater tank of at least 30000 litres on the site. This rainwater tank must meet, and be installed in accordance with, the requirements of all applicable regulatory authorities. | ~ | Image: A set of the set of the | ~ |
| The applicant must configure the rainwater tank to collect rain runoff from at least 200 square metres of the roof area of the development (excluding the area of the roof which drains to any stormwater tank or private dam). | | ~ | ~ |
| The applicant must connect the rainwater tank to: | | | |
| all toilets in the development | | ~ | ~ |
| the cold water tap that supplies each clothes washer in the development | | ~ | ~ |
| at least one outdoor tap in the development (Note: NSW Health does not recommend that rainwater be used for human consumption in areas with potable water supply.) | | Image: A set of the set of the | ~ |
| all hot water systems in the development | | Image: A second s | ~ |
| | | | . |

| Thermal Comfort Commitments | Show on DA plans | Show on CC/CDC plans & specs | Certifier check |
|---|---------------------|------------------------------|--------------------|
| General features | | | |
| The dwelling must not have more than 2 storeys. | ~ | ~ | ~ |
| The conditioned floor area of the dwelling must not exceed 300 square metres. | ~ | ~ | ~ |
| The dwelling must not contain open mezzanine area exceeding 25 square metres. | ~ | ~ | ~ |
| The dwelling must not contain third level habitable attic room. | ~ | ~ | ~ |
| Floor, walls and ceiling/roof | | | |
| The applicant must construct the floor(s), walls, and ceiling/roof of the dwelling in accordance with the specifications listed in the table below. | ~ | v | ~ |

| Construction | Additional insulation required (R-Value) | Other specifications |
|--|--|---|
| floor - suspended floor above open subfloor, 130 square metres, framed | 0.8 (or 1.5 including construction) (down) | |
| floor - above habitable rooms or mezzanine, 78.9 square metres, framed | nil | |
| external wall - framed (weatherboard, fibre cement, metal clad) | 2.00 (or 2.40 including construction) | |
| ceiling and roof - raked ceiling / pitched or skillion roof, framed | ceiling: 2.24 (up), roof: foil/sarking | framed; medium (solar absorptance 0.475-0.70) |
| ceiling and roof - flat ceiling / flat roof, framed | ceiling: 2.08 (up), roof: foil/sarking | framed; medium (solar absorptance 0.475-0.70) |

Note • Insulation specified in this Certificate must be installed in accordance with Part 3.12.1.1 of the Building Code of Australia.

Note • In some climate zones, insulation should be installed with due consideration of condensation and associated interaction with adjoining building materials.

| Thermal Comfort Commitments | Show on DA plans | Show on CC/CDC plans & specs | Certifier check |
|---|---------------------|------------------------------|--------------------|
| Windows, glazed doors and skylights | | | |
| The applicant must install the windows, glazed doors and shading devices described in the table below, in accordance with the specifications listed in the table. Relevant overshadowing specifications must be satisfied for each window and glazed door. | ~ | ~ | ~ |
| The dwelling may have 1 skylight (<0.7 square metres) which is not listed in the table. | ~ | ~ | ~ |
| The following requirements must also be satisfied in relation to each window and glazed door: | ~ | ~ | ~ |
| • For the following glass and frame types, the certifier check can be performed by visual inspection. | | | |
| - Aluminium single clear | | | |
| - Aluminium double (air) clear | | | |
| - Timber/uPVC/fibreglass single clear | | | |
| - Timber/uPVC/fibreglass double (air) clear | | | |
| • For other glass or frame types, each window and glazed door must be accompanied with certification showing a U value no greater than that listed and a Solar Heat Gain Coefficient (SHGC) within the range of those listed. Total system U values and SHGC must be calculated in accordance with National Fenestration Rating Council (NFRC) conditions. Frame and glass types shown in the table below are for reference only. | | | ~ |
| Vertical external louvres and blinds must fully shade the window or glazed door beside which they are situated when fully drawn or closed. | | ~ | ~ |
| Overshadowing buildings/vegetation must be of the height and distance from the centre and the base of the window and glazed door, as specified in the 'overshadowing' column. | ~ | ✓ | ~ |
| The applicant must install the skylights described in the table below, in accordance with the specifications listed in the table. Total skylight area must not exceed 3 square metres (the 3 square metre limit does not include the optional additional skylight of less than 0.7 square metres that does not have to be listed in the table). | ~ | ~ | ~ |
| The following requirements must also be satisfied in relation to each skylight: | | v | ~ |
| • External awnings and louvres must fully shade the skylight above which they are situated when fully drawn or closed | | | |

| Skylight no. | Maximum area (square metres) | Туре | Shading device |
|--------------|------------------------------|---------------------------------|----------------------------|
| S01 | 0.77 | timber, low-E/double/argon fill | adjustable awning or blind |

| Window/glazed door no. | Maximum height (mm) | Maximum width (mm) | Туре | Shading Device (Dimension within 10%) | Overshadowing | |
|------------------------|------------------------|-----------------------|--|--|------------------------|--|
| North facing | | | | | | |
| W3 L1 | 1250 | 1060 | U-value: 4.3, SHGC: 0.477 - 0.583 (aluminium, double (air), Hi-Tsol Low-e/clear) | solid overhang 450 mm, 0 mm above head of window or glazed door | not overshadowed | |
| East facing | 1 | | | | | |
| D3 L1 | 2400 | 1855 | U-value: 4.3, SHGC: 0.477 - 0.583 (aluminium, double (air), Hi-Tsol Low-e/clear) | external louvre/vertical blind (fixed) | >4 m high, 8-12 m away | |
| W7 L1 | 1420 | 1855 | U-value: 3.1, SHGC: 0.441 - 0.539 (aluminium: thermally broken, double (air), Hi-Tsol Low-e/clear) | eave 300 mm, 200 mm above head of window or glazed door | >4 m high, 8-12 m away | |
| South-East facing | 1 | | ' | | | |
| W15 L1 | 2050 | 1050 | U-value: 4.3, SHGC: 0.477 - 0.583 (aluminium, double (air), Hi-Tsol Low-e/clear) | eave 2600 mm, 0 mm above head of window or glazed door | >4 m high, 8-12 m away | |
| W11 L1 | 600 | 4420 | U-value: 4.3, SHGC: 0.477 - 0.583 (aluminium, double (air), Hi-Tsol Low-e/clear) | eave 300 mm, 100 mm above head of window or glazed door | >4 m high, 8-12 m away | |
| W9 L1 | 450 | 1100 | U-value: 4.3, SHGC: 0.423 - 0.517 (aluminium, double (air), Hi-Tsol Low-e/clear) | eave 3600 mm, 700 mm above head of window or glazed door | >4 m high, 8-12 m away | |
| W14 L1 | 2650 | 1050 | U-value: 3.1, SHGC: 0.441 - 0.539 (aluminium: thermally broken, double (air), Hi-Tsol Low-e/clear) | eave 300 mm, 0 mm above head of window or glazed door | >4 m high, 8-12 m away | |
| W7 GF | 400 | 1810 | U-value: 4.3, SHGC: 0.477 - 0.583 (aluminium, double (air), Hi-Tsol Low-e/clear) | solid overhang 5000 mm, 700 mm above head of window or glazed door | not overshadowed | |
| W10 L1 | 600 | 2650 | U-value: 4.3, SHGC: 0.423 - 0.517 (aluminium, double (air), Hi-Tsol Low-e/clear) | eave 300 mm, 100 mm above head of window or glazed door | >4 m high, 8-12 m away | |
| W12 L1 | 600 | 2650 | U-value: 4.3, SHGC: 0.423 - 0.517 (aluminium, double (air), Hi-Tsol Low-e/clear) | eave 300 mm, 100 mm above head of window or glazed door | >4 m high, 8-12 m away | |

| Window/glazed door no. | Maximum height (mm) | Maximum width (mm) | Туре | Shading Device (Dimension within 10%) | Overshadowing |
|------------------------|------------------------|-----------------------|--|--|------------------------|
| W8 L1 | 450 | 1200 | U-value: 5.4, SHGC: 0.522 - 0.638 (aluminium, single, Hi-Tsol Low-e) | solid overhang 3050 mm, 700 mm above head of window or glazed door | >4 m high, 8-12 m away |
| South facing | | | | | |
| W4 L1 | 2400 | 795 | U-value: 4.3, SHGC: 0.477 - 0.583 (aluminium, double (air), Hi-Tsol Low-e/clear) | none | not overshadowed |
| W6 L1 | 1100 | 795 | U-value: 4.3, SHGC: 0.477 - 0.583 (aluminium, double (air), Hi-Tsol Low-e/clear) | none | not overshadowed |
| South-West facing | | | | | |
| W5 GF | 2700 | 450 | U-value: 4.3, SHGC: 0.477 - 0.583 (aluminium, double (air), Hi-Tsol Low-e/clear) | none | not overshadowed |
| W8 GF | 600 | 1500 | U-value: 4.3, SHGC: 0.423 - 0.517 (aluminium, double (air), Hi-Tsol Low-e/clear) | solid overhang 8000 mm, 600 mm above head of window or glazed door | not overshadowed |
| W9 GF | 2700 | 450 | U-value: 4.3, SHGC: 0.477 - 0.583 (aluminium, double (air), Hi-Tsol Low-e/clear) | solid overhang 1800 mm, 0 mm above head of window or glazed door | not overshadowed |
| West facing | | | | | |
| W16 L1 | 1250 | 2385 | U-value: 2.9, SHGC: 0.396 - 0.484 (aluminium: thermally broken, double (argon), Hi-Tsol Low-e/clear) | solid overhang 450 mm, 0 mm above head of window or glazed door | not overshadowed |
| W2 L1 | 450 | 1600 | U-value: 4.3, SHGC: 0.423 - 0.517 (aluminium, double (air), Hi-Tsol Low-e/clear) | none | not overshadowed |
| North-West facing | · | | | | · · |
| D2 L1 | 2400 | 3180 | U-value: 3.1, SHGC: 0.441 - 0.539 (aluminium: thermally broken, double (air), Hi-Tsol Low-e/clear) | eave 3500 mm, 300 mm above head of window or glazed door | not overshadowed |
| W1 L1 | 2400 | 795 | U-value: 4.3, SHGC: 0.477 - 0.583 (aluminium, double (air), Hi-Tsol Low-e/clear) | eave 2000 mm, 300 mm above head of window or glazed door | not overshadowed |

| Window/glazed door no. | Maximum height (mm) | Maximum width (mm) | Туре | Shading Device (Dimension within 10%) | Overshadowing |
|------------------------|------------------------|-----------------------|--|--|------------------|
| W3 GF | 1200 | 2120 | U-value: 3.1, SHGC: 0.351 - 0.429 (aluminium: thermally broken, double (air), Hi-Tsol Low-e/clear) | solid overhang 910 mm, 600 mm above head of window or glazed door | not overshadowed |
| W1 GF | 1200 | 2120 | U-value: 4.3, SHGC: 0.423 - 0.517 (aluminium, double (air), Hi-Tsol Low-e/clear) | solid overhang 1850 mm, 600 mm above head of window or glazed door | not overshadowed |
| W2 GF | 600 | 1600 | U-value: 4.3, SHGC: 0.423 - 0.517 (aluminium, double (air), Hi-Tsol Low-e/clear) | solid overhang 910 mm, 600 mm above head of window or glazed door | not overshadowed |
| D1 L1 | 2400 | 3180 | U-value: 3.1, SHGC: 0.441 - 0.539 (aluminium: thermally broken, double (air), Hi-Tsol Low-e/clear) | eave 3500 mm, 300 mm above head of window or glazed door | not overshadowed |
| W4 GF | 1200 | 2120 | U-value: 3.1, SHGC: 0.351 - 0.429 (aluminium: thermally broken, double (air), Hi-Tsol Low-e/clear) | solid overhang 910 mm, 600 mm above head of window or glazed door | not overshadowed |

| Energy Commitments | Show on DA plans | Show on CC/CDC plans & specs | Certifier check |
|---|---------------------|---|-----------------------|
| Hot water | | | |
| The applicant must install the following hot water system in the development, or a system with a higher energy rating: electric storage. | ~ | ~ | ~ |
| Cooling system | | | |
| The applicant must install the following cooling system, or a system with a higher energy rating, in at least 1 living area: ceiling fans; Energy rating: n/a | | ~ | ~ |
| The applicant must install the following cooling system, or a system with a higher energy rating, in at least 1 bedroom: ceiling fans; Energy rating: n/a | | v | ~ |
| Heating system | | | |
| The applicant must install the following heating system, or a system with a higher energy rating, in at least 1 living area: wood heater; Energy rating: n/a | | ~ | ~ |
| The bedrooms must not incorporate any heating system, or any ducting which is designed to accommodate a heating system. | | ~ | ~ |
| The wood heater must have a compliance plate confirming that it complies with the relevant Australian standards, and must be installed in accordance with the requirements of all applicable regulatory authorities. | | | ~ |
| Ventilation | | | |
| The applicant must install the following exhaust systems in the development: | | | |
| At least 1 Bathroom: individual fan, ducted to façade or roof; Operation control: manual switch on/off | | | ~ |
| Kitchen: individual fan, ducted to façade or roof; Operation control: manual switch on/off | | Image: A set of the set of the | ~ |
| Laundry: individual fan, ducted to façade or roof; Operation control: manual switch on/off | | ✓ | ✓ |
| Artificial lighting | | | |
| The applicant must ensure that the "primary type of artificial lighting" is fluorescent or light emitting diode (LED) lighting in each of the following rooms, and where the word "dedicated" appears, the fittings for those lights must only be capable of accepting fluorescent or light emitting diode (LED) lamps: | | | |
| at least 4 of the bedrooms / study; | | ~ | ~ |
| at least 2 of the living / dining rooms; | | ✓ | v |

| Energy Commitments | Show on DA plans | Show on CC/CDC plans & specs | Certifier check |
|---|---------------------|------------------------------|--------------------|
| the kitchen; | | ~ | ~ |
| all bathrooms/toilets; | | ~ | ~ |
| the laundry; | | v | ~ |
| all hallways; | | v | ~ |
| Natural lighting | | | - |
| The applicant must install a window and/or skylight in the kitchen of the dwelling for natural lighting. | ~ | > | ~ |
| The applicant must install a window and/or skylight in 3 bathroom(s)/toilet(s) in the development for natural lighting. | ~ | ~ | ~ |
| Alternative energy | | | |
| The applicant must install a photovoltaic system with the capacity to generate at least 5 peak kilowatts of electricity as part of the development. The applicant must connect this system to the development's electrical system. | ~ | ~ | ~ |
| Other | | | |
| The applicant must install an induction cooktop & electric oven in the kitchen of the dwelling. | | | |

Legend

In these commitments, "applicant" means the person carrying out the development.

Commitments identified with a vi in the "Show on DA plans" column must be shown on the plans accompanying the development application for the proposed development (if a development application is to be lodged for the proposed development).

Commitments identified with a vi in the "Show on CC/CDC plans and specs" column must be shown in the plans and specifications accompanying the application for a construction certificate / complying development certificate for the proposed development.

Commitments identified with a vi in the "Certifier check" column must be certified by a certifying authority as having been fulfilled, before a final occupation certificate(either interim or final) for the development may be issued.