

BELOW GROUND OSD TANK 2
 (CATCHMENT 3)
 (SUSPENDED UNDER GROUND FLOOR SLAB)
 VOLUME REQUIRED: 101.51m³
 VOLUME PROVIDED: 102.87m³
 AVERAGE DEPTH: 1.07m
 AREA: 96.14m²
 TWL: 5.25
 RL: 6.20-5.75
 IL: 4.10-4.26
 ORIFICE Ø: 15mm
 MAX PSD: 34 L/s
 REFER TO DETAILS


BELOW GROUND OSD 3
 (CATCHMENT 2)
 (SUSPENDED UNDER LANEWAY)
 VOLUME REQUIRED: 157.44m³
 VOLUME PROVIDED: 164.25m³
 AVERAGE DEPTH: 1.25m
 AREA: 138.32m²
 RL: 7.50-8.00
 TWL: 6.90
 IL: 5.50-5.80
 ORIFICE Ø: 120mm
 REFER TO DETAILS

- DESIGN NOTES:**
- 20,000 LITRES RAINWATER TANK TO BE PROVIDED FOR THE RESIDENTIAL FLAT BUILDING AS A PART OF WATER QUALITY COMMITMENT; AS PER WATER MANAGEMENT REPORT PREPARED BY 'S&G CONSULTANTS P/L'
 - RAINWATER REUSE TO BE USED FOR LAUNDRY, TOILET FLUSHING & WATERING THE LANDSCAPE AREA PURPOSES.
 - MINIMUM 157.44m³ OF OSD VOLUME IS REQUIRED FOR CATCHMENT 2 AS PER WATER MANAGEMENT REPORT PREPARED BY 'S&G CONSULTANTS P/L' WHICH HAS BEEN PROVIDED THROUGH 'OSD TANK - 2'
 - MINIMUM 101.51m³ OF OSD VOLUME IS REQUIRED FOR CATCHMENT 3 AS PER WATER MANAGEMENT REPORT PREPARED BY 'S&G CONSULTANTS P/L' WHICH HAS BEEN PROVIDED THROUGH 'OSD TANK - 3'

Issue	Date	Status	By	Check	Rev
H	16.05.22	2	MS	MS	1
G	28.09.21	2	MS	MS	2
F	31.08.21	2	MS	MS	3
E	03.05.21	2	MS	MS	4
D	26.05.20	2	MS	MS	5
C	15.05.20	2	MS	MS	6
B	05.05.20	2	RJ	MS	7
A	30.04.20	2	RJ	MS	8
P3	24.02.20	1	MS	MS	9
Issue	Last revision title	by	Date	Status	Rev

Discipline	Drawing Title and Number	Date	Rev
MS	Reference Coordination Drawing	10.05.22	1

Checked	SH	DATE	10.05.22
DRAWN	MS	DATE	10.05.22
CHECKED	SH	DATE	10.05.22
DESIGNED	MS	DATE	10.05.22
VERIFIED	SH	DATE	10.05.22
APPROVED	SH	DATE	10.05.22



CLIENT
THE KNOWLES GROUP- ARCADE

ARCHITECT
V/A ARCHITECTS
 LEVEL 3, 377 LONSDALE STREET
 +61 3 8678 1300
 vva@vva.com.au

Suite 5.03, Level 5,
 156 PACIFIC HIGHWAY,
 ST. LEONARDS, NSW 2065
 T: +61 2 8883 4239
 Email: office@sgce.com.au
 Web: www.sgce.com.au

PROJECT
PROPOSED RESIDENTIAL DEVELOPMENT
 25-27 WARRIEWOOD ROAD,
 WARRIEWOOD - STAGE II

Grid	Datum	Sheet	Scale (at original size)
-	A.H.D.	3 OF 8	1:200 @ A1
Project No	Drawing No	Revision No	
20160112	SW201	H	