

---

**Sent:** 15/04/2019 11:22:24 AM  
**Subject:** Re: Our Ref IDAS1114080 - Your Ref DA2019/0239 638 Pittwater Road Brookvale  
**Attachments:** Northern Beaches council IDAS1114080 B 15.04.19 signed.pdf;

Hi,

**Re: Our Ref IDAS1114080 - Your Ref DA2019/0239 638 Pittwater Road Brookvale**

Please see attached WaterNSW's response to the above matter

Thanks Keri

**Keri Izzard**

**Water Regulation Officer**

Customer Assessments and Approval  
Customer and Community (Parramatta)

*As of Monday 30 April 2018 the new independent Natural Resource Access Regulator (NRAR) is the single and independent agency responsible for compliance and enforcement of water management rules in NSW. NRAR has been established to provide greater independence of water regulation and give the community greater confidence in the regulation of this critical resource. The contact details for NRAR are: Website: [www.industry.nsw.gov.au/natural-resources-access-regulator](http://www.industry.nsw.gov.au/natural-resources-access-regulator), Email: [nrar.enquiries@nrar.nsw.gov.au](mailto:nrar.enquiries@nrar.nsw.gov.au) and Phone: 1800 633 362. All future correspondence in relation to any cases worked on collaboratively should be directed to NRAR.*



Level 14, 169 Macquarie St  
PO Box 398  
Parramatta NSW 2124  
T: 02 9865 2327

[keri.izzard@waternsw.com.au](mailto:keri.izzard@waternsw.com.au)

[www.waternsw.com.au](http://www.waternsw.com.au)



PO Box 398, Parramatta NSW 2124  
Level 14, 169 Macquarie Street  
Parramatta NSW 2150  
[www.watarnsw.com.au](http://www.watarnsw.com.au)  
ABN 21 147 934 787

Contact Richard Meares  
Phone 02 9865 2324  
Email [richard.meares@watarnsw.com.au](mailto:richard.meares@watarnsw.com.au)

Carly Sawyer  
Northern Beaches Council  
PO Box 82  
Manly NSW 1655

Our ref IDAS1114080  
Your ref DA2019/0239  
Date 15 April 2019

Via email: [council@northernbeaches.nsw.gov.au](mailto:council@northernbeaches.nsw.gov.au)

Dear Carly,

**Integrated Development referral under s.91A of the *Environmental Planning and Assessment Act 1979* for 638 Pittwater Road Brookvale NSW**

Reference is made to your request for a response in relation to the proposed development described as Lots 1 DP1001963, 638 Pittwater Road Brookvale NSW and identified as DA 2019/0239.

WaterNSW has determined that the proposed development is likely to encounter groundwater during the excavation process, and is subject to a Water Supply Work Approval under the *Water Management Act 2000* for dewatering during the construction phase. This determination is subject to appropriate construction methods to be employed to minimise volume of groundwater take during the construction phase. WaterNSW provides General Terms of Approval attached.

On the basis of limited information available, WaterNSW considers that the take of water may be required during construction. A water supply work approval under S92 of the water Management Act 2000, and, subject to exemptions, a water access licence may be required to account for the water take.

For further information in regards to making an application, and information required for the Approval information licensing requirements, including the preparation of a dewatering management plan, please contact Richard Meares, Water Regulation Officer on (02) 9865 2324, or by email to [richard.meares@watarnsw.com.au](mailto:richard.meares@watarnsw.com.au).

Yours Sincerely,

*Per: K Azzard*

Richard Meares  
Water Regulation Officer  
Coastal (Parramatta)  
Water NSW

<b>DA reference</b>	DA 2019/0239
<b>Proponent</b>	BBF Town Planners
<b>Specified location</b>	Lot 1 DP1001963
<b>Proposed development</b>	3 Level Basement Car Parking
<b>Water sharing plan</b>	Greater Metropolitan Region Groundwater Sources WSP 2011
<b>Water source</b>	Metropolitan Coastal Sands
<b>Water management zone</b>	

## General Terms of Approval

1. A Water Supply Work Approval from WaterNSW must be obtained prior to commencing dewatering activity on the proposed site. Please complete an [Application for approval for water supply works, and/or water use](#).
2. An application for a Water Supply Works Approval will only be accepted upon receipt of supporting documentation, and payment of the applicable fee (see Application fees for [New or amended Works and/or Use Approvals](#)). The information required for the processing of the water supply work application may include preparation of a dewatering management plan. Please refer to checklist attached.
3. If approved, the Approval will be issued for a period of up to 24 months to cover the dewatering requirements during the construction phase. It will include conditions to ensure that impacts are acceptable and that adequate monitoring and reporting procedures are carried out. The Approval will be issued subject to the proponent meeting requirements of other agencies and consent authorities. For example, an authorisation by either Sydney Water or the local Council, depending where the water will be discharged. If contaminants are likely, or are found to be present in groundwater, and are being discharged to stormwater, including high salinities, a discharge licence under the *Protection of the Environment Operations Act 1997 (NSW)* may also be required.
4. WaterNSW prefers “tanking” (ie. total water proofing below the seasonal high water table) of basement excavations, and avoids the ongoing extraction of groundwater after the initial construction phase. It is also advised to adopt measures to facilitate movement of groundwater post construction (eg. a drainage blanket behind the water-proof membrane).
5. If the basement is not “tanked”, the proponent will require a Water Access Licence (WAL) and need to acquire groundwater entitlements equivalent to the yearly ongoing take of groundwater. Please note: Acquiring groundwater entitlements could be difficult, and may cause delay in project completion. If a WAL is required, please complete an [Application for a new water access licence with a zero share component](#).

<b>DA reference</b>	
<b>Proponent</b>	
<b>Specified location</b>	
<b>Proposed development</b>	

**Please note:** The following information is considered essential to allow Water NSW to assess approval applications. The information must be provided along with the approval application prior to commencement of works. Your application will not be accepted until the following requirements have been satisfactorily addressed and received by this office.

- 1. Application for an Approval under the Water Management Act 2000.
- 2. Application fee | \$1,097.11 (low risk approvals); or \$2,029.63 (where details assessment required). Refer to [Application fees for water access licences, water supply work and use approvals and dealings](#) for definitions.
- 3. Written authorisation for the disposal of the extracted groundwater (obtained from Council or Sydney Water)
- 4. Copy of a valid planning consent for the project and architectural or survey drawings that show the plan and section of the subsurface excavation including relative levels (AHD) and the groundwater table
- 5. A Dewatering Management Plan which clearly and concisely sets out the following:**
  - 5.1. Current groundwater levels, preferably based on at least three repeat measurements from at least three monitoring bores and should be used to develop a water table map for the site and its near environs, be accompanied by an interpretation of the groundwater flow direction from these data, and an assessment of the likely level to which groundwater might naturally rise during the life of the building.  
**Relevant report & Page No:** \_\_\_\_\_
  - 5.2. Predictions of total volume of groundwater to be extracted at the property – the method of calculation and the basis for parameter estimates and any assumptions used to derive the volume are to be clearly documented  
**Relevant report & Page No:** \_\_\_\_\_
  - 5.3. Predicted duration of dewatering at the property, noting that temporary dewatering approvals are generally issued for no more than 12 months  
**Relevant report & Page No:** \_\_\_\_\_
  - 5.4. Details of how dewatering volumes are to be measured, eg. by calibrated flow meter or other suitable method, and of the maximum depth of the proposed dewatering system  
**Relevant report & Page No:** \_\_\_\_\_
  - 5.5. Details of any predicted impacts or particular issues, eg. proximity of groundwater dependent ecosystems springs; or water supply losses by neighbouring groundwater users potential subsidence impacts on nearby structures or infrastructure  
**Relevant report & Page No:** \_\_\_\_\_
  - 5.6. Details of monitoring proposed during the dewatering program. These should be designed to inform and facilitate the protection of any identified potential impacts  
**Relevant report & Page No:** \_\_\_\_\_
  - 5.7. Details of ambient groundwater quality conditions beneath the property and of any proposed treatment to be applied to pumped water prior to disposal – at a minimum, treatment must be undertaken to remove contaminants, manage pH, reduce suspended solids and turbidity to acceptable levels and ensure that dissolved oxygen levels are compatible with ambient quality requirements in receiving waters. Groundwater cannot be re-injected into an aquifer without the specific approval of, and licensing by, DPI Water  
**Relevant report & Page No:** \_\_\_\_\_
  - 5.8. Details of how reporting will occur during and following the dewatering program, to confirm that predicted quantities and quality objectives were met  
**Relevant report & Page No:** \_\_\_\_\_
  - 5.9. Description of the method of dewatering and related construction including any proposal to use temporary piling or support walls and the relative depths thereof  
**Relevant report & Page No:** \_\_\_\_\_