

Engineering Referral Response

Application Number:	DA2024/1784
Proposed Development:	Alterations and additions to a dwelling house including secondary dwelling
Date:	16/01/2025
To:	Thomas Burns
Land to be developed (Address):	Lot 94 DP 32253 , 50 Wesley Street ELANORA HEIGHTS NSW 2101

Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m² or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

Officer comments

16/01/2025

Council's Development Engineer raises no objection to this proposal subject to conditions.

Stormwater

The proposed increase in impervious area is approximately less than 50sqm. An OSD is not required.

The site generally drains to Wesley Street. Stormwater has been conditioned to be disposed of to the existing stormwater system subject to possible required upgrade.

Site Access and Parking

A new single carport is proposed for the main dwelling and a new single carport is proposed for the secondary dwelling. The driveway gradients have been checked to be compliant subject to conditions.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the

Responsible Officer.

Recommended Engineering Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Stormwater Disposal

The applicant is to demonstrate how stormwater from the new development within this consent is disposed of to an existing approved system or in accordance with Northern Beaches Council's Water Management for Development Policy. Details by an appropriately qualified and practicing Civil or Hydraulic Engineer demonstrating that the existing approved stormwater system can accommodate the additional flows, or compliance with Council's policy are to be submitted to the Certifier for approval prior to the issue of the Construction Certificate.

Details demonstrating compliance are to be submitted to the Certifier for approval prior to the issue of the Construction Certificate.

Reason: To ensure appropriate provision for disposal of stormwater management arising from the development.

Vehicle Crossings Application

The Applicant is to submit an application with Council for driveway levels to construct two vehicle crossings in accordance with Northern Beaches Council Standard Drawing in accordance with Section 138 of the Roads Act 1993.

Note, the existing vehicular crossover servicing the proposed secondary dwelling is to be reconstructed. The new vehicular crossover servicing the carport for the main dwelling shall match the adjoining vehicular crossover for the neighbouring property.

Note, driveways are to be in plain concrete only.

The fee associated with the assessment and approval of the application is to be in accordance with Council's Fee and Charges.

A Council approval is to be submitted to the Certifier prior to the issue of the Construction Certificate.

Reason: To facilitate suitable vehicular access to private property.

Off Street Parking Design

The Applicant shall submit a design for the parking facilities and the associated driveways in accordance with the relevant provisions of Australian/New Zealand Standard AS/NZS 2890.1:2004 parking facilities - Off-street car parking, in particular Section 2.6 Design of Domestic Driveways.

Details demonstrating compliance are to be submitted to the Principal Certifier prior to the issue of the Construction Certificate.

Reason: Compliance with this consent.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Road Reserve

The applicant shall ensure the public footways and roadways adjacent to the site are maintained in a safe condition at all times during the course of the work.

Reason: Public safety.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Stormwater Disposal

The stormwater drainage works shall be certified as compliant with all relevant Australian Standards and Codes by a suitably qualified person. Details demonstrating compliance are to be submitted to the Principal Certifier prior to the issue of an Occupation Certificate.

Reason: To ensure appropriate provision for the disposal of stormwater arising from the development.

Certification of Off Street Parking Works

The Applicant shall submit a certificate from a suitably qualified person certifying that the parking facilities and the associated driveways were constructed in accordance within this development consent and the relevant provisions of Australian/New Zealand Standard AS/NZS 2890.1:2004 parking facilities - Off-street car parking, in particular Section 2.6 Design of Domestic Driveways.

Details demonstrating compliance are to be submitted to the Principal Certifier prior to the issue of the Occupation Certificate.

Reason: Compliance with this consent.