

Natural Environment Referral Response - Flood

Application Number:	DA2019/1195
To:	Phil Lane
Land to be developed (Address):	Lot 10 DP 1177 , 0 Pittwater Road MANLY NSW 2095 Lot 11 DP 1177 , 0 Pittwater Road MANLY NSW 2095 Lot 12 DP 1177 , 0 Pittwater Road MANLY NSW 2095 Lot 13 DP 1177 , 0 Pittwater Road MANLY NSW 2095 Lot 14 DP 1177 , 0 Pittwater Road MANLY NSW 2095 Lot 15 DP 1177 , 0 Pittwater Road MANLY NSW 2095 Lot 16 DP 1177 , 0 Pittwater Road MANLY NSW 2095 Lot 18 DP 1177 , 0 Pittwater Road MANLY NSW 2095 Lot 8 DP 1177 , 0 Pittwater Road MANLY NSW 2095 Lot 9 DP 1177 , 0 Pittwater Road MANLY NSW 2095 Lot 19 DP 1177 , 0 Pittwater Road MANLY NSW 2095 Lot 20 DP 1177 , 0 Pittwater Road MANLY NSW 2095 Lot 1 DP 535058 , 0 Pittwater Road MANLY NSW 2095 Lot 17 DP 1177 , 0 Pittwater Road MANLY NSW 2095

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land below the 1 in100 year flood level;
- All Development Applications located on land below the Probable Maximum Flood levels.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

No relevant Flood Risk Management Report has been provided in support of the application. The Adverse Weather Plan relates to a different site to the subject site. A Flood Risk Management Report addressing the high flood risk and potential emergency response must be provided in support of the application.

Referral Body Recommendation

Recommended for refusal

Recommended Natural Environment Conditions:

Nil.