

## Natural Environment Referral Response - Coastal

Application Number:	DA2021/0228
Date:	21/04/2021
Responsible Officer	Gareth David
Land to be developed (Address):	Lot 10 DP 738078 , 1668 Pittwater Road MONA VALE NSW 2103

### Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

### Officer comments

The application has been assessed in consideration of the Coastal Management Act 2016, State Environmental Planning Policy (Coastal Management) 2018 and has also been assessed against requirements of the Pittwater LEP 2014 and Pittwater 21 DCP.

### Coastal Management Act 2016

The subject site has been identified as being within the coastal zone and therefore *Coastal Management Act 2016* is applicable to the proposed development. The proposed development is in line with the objects, as set out under Clause 3 of the *Coastal Management Act 2016*.

### State Environmental Planning Policy (Coastal Management) 2018

The proposed development site of the subject land has been included on the 'Proximity to Coastal Wetlands Area' map under the State Environmental Planning Policy (Coastal Management) 2018 (CM SEPP). Hence, Clauses 11 and 15 of the CM SEPP apply for this DA.

Comment:

On internal assessment, the DA satisfies requirements under clause 15 of the CM SEPP. Requirements under the Clause 11 will be assessed by other units of the Council.

### Pittwater LEP 2014 and Pittwater 21 DCP

### Estuarine Risk Management

The subject property has also been identified as affected by estuarine wave action and tidal inundation

on Council's Estuarine Hazard Mapping. As such, the Estuarine Risk Management Policy for Development in Pittwater (Appendix 7, Pittwater 21 DCP) and the relevant B3.7 Estuarine Hazard Controls will apply to any proposed development of the site.

In accordance with the Pittwater Estuary Mapping of Sea Level Rise Impacts Study (2015), a base estuarine planning level (EPL) of RL 2.64m AHD would apply at the subject site. A reduction factor (RF) based upon the distance from the foreshore of proposed development may also apply at a rate of 0.06m reduction to the EPL for every 5.00m distance from the foreshore edge up to a maximum distance of 40.00m. Considering the proposed development site, the derived EPL of 2.24m AHD is recommended.

On internal assessment, the ground floor level for the proposed additions and alterations is below the derived EPL for the site.

The proposed development is therefore subject to conditions to satisfy the relevant estuarine risk management requirements of P21 DCP.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

#### **Recommended Natural Environment Conditions:**

### **CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE**

#### **Estuarine Planning Level Requirements**

An Estuarine Planning Level (EPL) of 2.24m AHD has been recommended by Council for the proposed development site and shall be applied to all development proposed below this level as follows:

- All structural elements below 2.24m AHD shall be of flood compatible materials;
- All electrical equipment, wiring, fuel lines or any other service pipes and connections must be located either above 2.24m AHD or waterproofed to this level; and
- The storage of toxic or potentially polluting goods, chemicals or materials, which may be hazardous or pollute the waterway, is not permitted below 2.24m AHD.
- All interior power supplies (including electrical fittings, outlets and switches) must be located at or above 2.24m AHD. All exterior power supplies (including electrical fittings, outlets and switches) shall be located at or above 2.24m AHD.

Reason: To ensure aspect of the development are built at the appropriate level

#### **Structural Engineering for Estuarine Risk**

Structural engineering design for the development shall be prepared, with input as necessary from a chartered professional engineer with coastal engineering as a core competency, to ensure that for its design life (taken to be 100years unless otherwise justified and accepted by Council) the development is able to withstand the wave impact forces and loadings.

Note: The potential for component fatigue (wear and tear) should be recognised for the less severe, but more frequent, wave impact loadings.

Reason: To ensure structural engineering is prepared by an appropriately qualified professional