

## Urban Design Referral Response

<b>Application Number:</b>	DA2020/1743
<b>Date:</b>	05/08/2021
<b>To:</b>	Anne-Marie Young
<b>Land to be developed (Address):</b>	Lot 3 DP 26532 , 45 Lantana Avenue WHEELER HEIGHTS NSW 2097

### Officer comments Not Supported

Amended drawings dated August 2021 were submitted. The proposal's has addressed the Urban Design Comments highlighted during the Pre-Lodgement Meeting and their responses are provided below:

1. The overall building bulk and scale should be reduced to be similar to the next door development (comprising of 7 units within four smaller building blocks) to be contextually fitting with the surrounding free-standing houses. The proposed FSR is over the 0.5:1 requirement so the proposed 8 number of units could be reduced to 7. The top floor units should be reduced in area to allow a less top-heavy look by having single storey elements incorporated. Roof overhang could also be reduced to maximise sunlight access to neighbouring properties and comply strictly with the building envelope controls.

**Response:** The proposed FSR of 0.5:1 is now compliant with the amended unit layout.

2. The 30% landscape calculation should be based on landscaped area that is 2m minimum width. As such the footpath along the eastern boundary could be more integrated into the landscape concept. The existing tree courtyard could be taken advantage of being the entry court leading to the units and lift lobbies. One of the ground floor unit in the rear block could be deleted to create a more welcoming entrance.

**Response:** The entry to the rear block lift lobby has been improved..

3. Unit 07 has bedroom and utilities windows opening into the entry passage which is not desirable. Sunlight access to this unit could be improved further.

**Response:** Unit 08 layout has been revised to avoid windows facing the entry passage.

4. Pedestrian footpath entry from the shared driveway could potentially be dangerous having to cross two basement entry ramps. Consider collaborating with the next door neighbour to combine the basement ramp entry point and creating less of a bottle-neck effect improving the entry experience for both developments.

**Response:** Additional pedestrian safety and sightlines considerations have been incorporated.

5. Proposed built forms to comply with the 8m building height and two storey requirement by making sure basement do not protrude above natural ground by more than one metre. Strict compliance with Building envelopes to be demonstrated on drawings.

**Response:** The proposed entry walkway has been provided with a 'fixed angle privacy screen- 1.65 m high' to address the overlooking privacy and noise nuisance issues to neighbouring property at No. 47 Lantana Avenue.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

**Recommended Heritage Advisor Conditions:**

Nil.