

Engineering Referral Response

Application Number:	DA2023/0689
Proposed Development:	Demolition works and construction of a dwelling house
Date:	29/06/2023
To:	Stephanie Gelder
Land to be developed (Address):	Lot 10 DP 9561 , 7 New Street BALGOWLAH HEIGHTS NSW 2093

Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m² or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

Officer comments

The proposal is for the construction of a new dwelling. The site is in Region 3, Zone 1 and as such OSD is required in accordance with Section 9.3.3.2 of Council's Water Management for Development Policy.

The submitted stormwater plan proposes discharge to the kerb via an OSD system. However, the proposed OSD volume appears low. Additional information required for assessment is as follows:

- Drains model
- Amended plans to show predeveloped and post developed flows including flows from the OSD system and bypass flows.

The proposal is therefore unsupported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Engineering Conditions:

Nil.