



## **FIRE SAFETY SCHEDULE**

*Prepared in accordance with Part 9, Divisions 1 and 2 of the Environmental Planning & Assessment Regulation, 2000  
to accompany the subject Construction Certificate.*

Property Address:

345 Condamine St, Manly Vale

Project Proposal:

Change of use from residence to Medical Consulting Room

<b>Fire Safety &amp; Other Measures</b>	<b>Existing Measure</b>	<b>Modify Measure</b>	<b>Proposed Measure</b>	<b>Minimum Standards of Performance</b>
Portable Fire Extinguishers			✓	BCA Clause E1.6 AS 2444-2001
Smoke alarms & Heat Alarms			✓	BCA Clause E2.2a AS 3786-2015