

Environmental Health Referral Response - acid sulfate soils

Application Number:	DA2023/0020
Proposed Development:	Demolition work and change of use of site to an educational establishment (Stella Maris College) and installation of temporary demountable buildings.
Date:	24/01/2023
Responsible Officer	Jordan Davies
Land to be developed (Address):	Lot CP SP 12627 , 50 Eurobin Avenue MANLY NSW 2095 Lot 1 SP 12627 , 1 / 50 Eurobin Avenue MANLY NSW 2095 Lot 2 SP 12627 , 2 / 50 Eurobin Avenue MANLY NSW 2095 Lot 42 DP 14521 , 48 Eurobin Avenue MANLY NSW 2095

Reasons for referral

This application seeks consent for one or more of the following:

- All development in class 1 land
- Any works below ground surface or will lower water table in area class 2 land
- Any works beyond 1 metre or lower water table by 1 metre in class 3 land
- Any works beyond 2 metres or lower water table by 2 metres in class 4 land
- Works on land below 10 metres AHD and within 500m of class 1, 2, 3 or 4 land which are likely to lower water table below 1 metre

And as such, Council's Environmental Investigations officers are required to consider the likely impacts.

Officer comments

General Comments

Environmental Health has reviewed this proposal and the area is in a Class 4 Acid Sulphate Soil zone

It does not appear that any works will be undertaken below 2 meters or will lower the water table.

Recommendation

APPROVAL - no conditions

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Environmental Investigations Conditions:

Nil.