page 1/6

BASIX Certificate

Building Sustainability Index www.basix.nsw.gov.au

Alterations and Additions

Certificate number: A441594

This certificate confirms that the proposed development will meet the NSW government's requirements for sustainability, if it is built in accordance with the commitments set out below. Terms used in this certificate, or in the commitments, have the meaning given by the document entitled "BASIX Alterations and Additions Definitions" dated 06/10/2017 published by the Department. This document is available at www.basix.nsw.gov.au

Secretarv

Date of issue: Monday, 13, December 2021 To be valid, this certificate must be lodged within 3 months of the date of issue.



Planning, Industry & Environment

| Project address | |
|-------------------------------|--|
| Project name | 21 Heather Street, Wheeler Heights |
| Street address | 21 Heather Street Wheeler Heights 2097 |
| Local Government Area | Northern Beaches Council |
| Plan type and number | Deposited Plan 8871 |
| Lot number | 100 |
| Section number | |
| | |
| Project type | |
| Project type Dwelling type | Separate dwelling house |

Certificate Prepared by (please complete before submitting to Council or PCA)

Name / Company Name: Network Irrigation P/L

ABN (if applicable): 057985118

| Fixtures and systems | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check |
|--|---------------------|---------------------------------------|--------------------|
| Lighting | | | |
| The applicant must ensure a minimum of 40% of new or altered light fixtures are fitted with fluorescent, compact fluorescent, or light-emitting-diode (LED) lamps. | | ~ | ~ |
| Fixtures | 1 | | |
| The applicant must ensure new or altered showerheads have a flow rate no greater than 9 litres per minute or a 3 star water rating. | | \checkmark | ~ |
| The applicant must ensure new or altered toilets have a flow rate no greater than 4 litres per average flush or a minimum 3 star water rating. | | \checkmark | ~ |
| The applicant must ensure new or altered taps have a flow rate no greater than 9 litres per minute or minimum 3 star water rating. | | \checkmark | |

| Construction | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check | | |
|--|---|---|--------------------|--|--|
| Insulation requirements | | | | | |
| The applicant must construct the new or altered the table below, except that a) additional insulat is not required for parts of altered construction v | × | ~ | ~ | | |
| Construction | Additional insulation required (R-value) | Other specifications | | | |
| concrete slab on ground floor. | nil | | | | |
| floor above existing dwelling or building. | nil | | | | |
| external wall: framed (weatherboard, fibro, metal clad) | R1.30 (or R1.70 including construction) | | | | |
| external wall: brick veneer | R1.16 (or R1.70 including construction) | | | | |
| internal wall shared with garage: plasterboard (R0.36) | nil | | | | |
| flat ceiling, flat roof: framed | ceiling: R1.58 (up), roof: foil backed blanket (55 mm) | medium (solar absorptance 0.475 - 0.70) | | | |

| Glazing requ | uirements | | | | | | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check |
|---|--------------------------------|--------------------------------|---------------------------|---------------------------|---|--|----------------------|---------------------------------------|--------------------|
| Windows and | d glazed do | oors | | | | | | 1 | |
| | | | | | hading devices, in accordance with r each window and glazed door. | the specifications listed in the table below. | ~ | ~ | ~ |
| The following requirements must also be satisfied in relation to each window and glazed door: | | | | | | ~ | ~ | | |
| have a U-value must be calcul | e and a Solar ated in accor | Heat Gair dance with | n Coefficie h National | ent (SHGC) Fenestratio | no greater than that listed in the tab | ar glazing, or toned/air gap/clear glazing must le below. Total system U-values and SHGCs a. The description is provided for information | | ~ | ~ |
| | | | | | f each eave, pergola, verandah, bal than 2400 mm above the sill. | cony or awning must be no more than 500 mm | \checkmark | \checkmark | ~ |
| For projections least that show | | | he ratio of | the projecti | on from the wall to the height above | the window or glazed door sill must be at | | ~ | ~ |
| Pergolas with polycarbonate roof or similar translucent material must have a shading coefficient of less than 0.35. | | | | | | \checkmark | ~ | | |
| | | | | | e window or glazed door above whi ens must not be more than 50 mm. | ch they are situated, unless the pergola also | | \checkmark | ~ |
| Overshadowin specified in the | | | | | ht and distance from the centre and | the base of the window and glazed door, as | | ~ | ~ |
| Windows a | nd glazed | doors g | lazing r | equireme | nts | | | | |
| Window / doo | r Orientation | - | Oversha | dowing | Shading device | Frame and glass type | | | |
| no. | | glass inc. frame (m2) | Height (m) | Distance (m) | | | | | |
| W1 | E | 0.38 | 2.3 | 1.3 | none | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| D2 | S | 13.3 | 0 | 0 | eave/verandah/pergola/balcony >=900 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| W3 | W | 2.16 | 0 | 0 | projection/height above sill ratio | improved aluminium, single pyrolytic low-e, | | | |

| Glazing requirements | | | | | | | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check |
|----------------------|-----------------|---|--------------------------|----------------------------|---|---|---------------------|---------------------------------------|--------------------|
| Window / do no. | oor Orientation | Area of glass inc. frame (m2) | Oversha Height (m) | adowing Distance (m) | Shading device | Frame and glass type | | | |
| | | | | | >=0.29 | (U-value: 4.48, SHGC: 0.46) | | | |
| W4 | S | 3.38 | 0 | 0 | eave/verandah/pergola/balcony >=600 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| D5 | S | 1.89 | 0 | 0 | eave/verandah/pergola/balcony >=900 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| W6 | S | 1.7 | 0 | 0 | eave/verandah/pergola/balcony >=900 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| W7 | W | 1.76 | 0 | 0 | projection/height above sill ratio >=0.43 | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| W8 | W | 1.76 | 0 | 0 | projection/height above sill ratio >=0.43 | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| W9 | W | 2.31 | 2.2 | 2.7 | projection/height above sill ratio >=0.43 | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |

Legend

In these commitments, "applicant" means the person carrying out the development.

Commitments identified with a " / " in the "Show on DA plans" column must be shown on the plans accompanying the development application for the proposed development (if a development application is to be lodged for the proposed development).

Commitments identified with a "
"
"
in the "Show on CC/CDC plans & specs" column must be shown in the plans and specifications accompanying the application for a construction certificate / complying development certificate for the proposed development.

Commitments identified with a " " in the "Certifier check" column must be certified by a certifying authority as having been fulfilled, before a final occupation certificate for the development may be issued.