

Building Assessment Referral Response

Application Number:	Mod2022/0075
Date:	26/04/2022
To:	Anne-Marie Young
Land to be developed (Address):	Lot 1 DP 1252335 , 701 Barrenjoey Road AVALON BEACH NSW 2107

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Building Assessment Conditions

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Fire Safety

The development is required to comply with Clause C1.5, Volume 1 of the Building Code of Australia and in particular each sole occupancy unit is required to:

1. have access to at least 2 exits; or
2. its own direct access to a road or open space.

Where this requirement cannot be met the building is required to be of Type B construction. Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Modified Construction Certificate.

Reason: To ensure adequate provision is made for fire safety and for building occupant safety