

## Engineering Referral Response

<b>Application Number:</b>	DA2021/1834
<b>Date:</b>	14/10/2021
<b>To:</b>	Penny Wood
<b>Land to be developed (Address):</b>	Lot 56 DP 12764 , 61 Smith Avenue ALLAMBIE HEIGHTS NSW 2100

### Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m2 or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

### Officer comments

#### 14/10/2021:

The application seeks approval for alterations and additions to an existing dwelling, conversion of existing carport to garage at front and replacement of a deck at rear.

#### Access

Site is currently accessed via a brick paved driveway from Morgan Street and concrete driveway slab within the site.

No Changes are proposed to the existing driveway in the Morgan street.

#### Stormwater

Stormwater Plan by NB Consulting Engineers, Job No.181111, Drawing No. D01 to D05, Issue A, Dated 14/2/2020 are satisfactory.

Site is a low level property and an OSD (Onsite Stormwater Detention System) is required.

All the OSD tanks to be placed under rear deck, tanks should not be placed under any habitable area.

No objections to approval subject to conditions as recommended.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Engineering Conditions:

## CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

### On-site Stormwater Detention Details

The Applicant is to provide a certification of drainage plans detailing the provision of on-site stormwater detention in accordance with Northern Beaches Council's Water Management for Development Policy, and generally in accordance with the concept drainage plans prepared by Stormwater Plan by NB Consulting Engineers, Job No.181111, Drawing No. D01 to D05, Issue A, Dated 14/2/2020. Detailed drainage plans are to be prepared by a suitably qualified Civil Engineer, who has membership to the Institution of Engineers Australia, National Professional Engineers Register (NPER) and registered in the General Area of Practice for civil engineering.

The drainage plans must address the following:

- i) OSD to be provided in accordance with Clause 9.0 of Council's Water Management for Development Policy.
- ii) All the OSD tanks to be placed under rear deck, tanks should not be placed under any habitable area.
- iii) The Dispersion trench is to be placed at the rear of property and at least 3m away from any site boundary.
- iv) Detailed drainage plans, including engineering certification, are to be submitted to the Certifying Authority for approval prior to the issue of the Construction Certificate.

Reason: To ensure appropriate provision for the disposal of stormwater and stormwater management arising from the development.

### Vehicle Driveway Gradients

The Applicant is to ensure driveway gradients within the private property are not to exceed a gradient of 1 in 4 (25%) with a transition gradient of 1 in 10 (10%) for 1.5 metres prior to a level parking facility. Access levels across the road reserve are to comply with the allocated vehicle profile detailed in this consent.

Details demonstrating compliance are to be submitted to the Certifying Authority for approval prior to the issue of the Construction Certificate.

Reason: To ensure suitable vehicular access to private property.

### Structural Adequacy and Excavation Work

Excavation work is to ensure the stability of the soil material of adjoining properties, the protection of adjoining buildings, services, structures and / or public infrastructure from damage using underpinning, shoring, retaining walls and support where required. All retaining walls are to be structurally adequate for the intended purpose, designed and certified by a Structural Engineer, except where site conditions permit the following:

- (a) maximum height of 900mm above or below ground level and at least 900mm from any property boundary, and
- (b) Comply with AS3700, AS3600 and AS1170 and timber walls with AS1720 and AS1170.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Construction Certificate.

Reason: To provide public and private safety.

## CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

### Road Reserve

The applicant shall ensure the public footways and roadways adjacent to the site are maintained in a safe condition at all times during the course of the work.

Reason: Public safety.

## CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

### Positive Covenant and Restriction as to User for On-site Stormwater Disposal Structures

The Applicant shall lodge a Legal Documents Authorisation Application with Council. The application is to include the original completed request forms (NSW Land Registry standard forms 13PC and/or 13RPA) and a copy of the Works-as-Executed plan (details overdrawn on a copy of the approved drainage plan by a Registered Surveyor) and Hydraulic Engineers' certification and photographic evidence for the completed onsite stormwater detention system works at site.

A guide to the process can be found on Council's website using the following link;

[https://files.northernbeaches.nsw.gov.au/sites/default/files/documents/pdfforms/legaldocumentsauthoris:-on-site-stormwater-detentionsystems/guide-submitting-ldaa nov19.pdf](https://files.northernbeaches.nsw.gov.au/sites/default/files/documents/pdfforms/legaldocumentsauthoris:-on-site-stormwater-detentionsystems/guide-submitting-ldaa%20nov19.pdf)

The form for the application can be found on Council's website using the following link;

<https://files.northernbeaches.nsw.gov.au/sites/default/files/documents/pdfforms/legaldocumentsauthoris:-on-site-stormwater-detention-systems/4023-legal-documentsauthorisationoct19.pdf>

The Applicant shall create on the Title a positive covenant in respect to the ongoing maintenance and restriction as to user over the on-site stormwater detention system within this development consent.

The terms of the positive covenant and restriction are to be prepared to Council's standard requirements at the applicant's expense and endorsed by Northern Beaches Council's delegate prior to lodgement with the NSW Land Registry Services. Northern Beaches Council shall be nominated as the party to release, vary or modify such covenant. A copy of the certificate of title demonstrating the creation of the positive covenant and restriction as to user for the on-site stormwater detention system is to be submitted.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of final Occupation Certificate.

Reason: To ensure the on-site stormwater disposal system is maintained to an appropriate operational standard and not altered.