

21 April 2023

General Manager
Northern Beaches Council
725 Pittwater Road
Dee Why NSW 2099

Dear Sir/Madam

Re: Stormwater Management Plan – 252 Hudson Parade, Clareville

With reference to the Development Application for the above property, please find enclosed a copy of the site Stormwater Management Plan STORM-1/B, Stormwater Management Details STORM-2/A and Driveway Plan and Long-Sections Civil-1/B for your perusal.

The plan shows collected flows from the proposed roofed areas, along with the surrounding hardstand areas, being discharged into the Pittwater at the rear of the site.

Note that the proposed driveway has been designed in accordance with the Council's Maximum Low Standard Driveway profile. The tree within the footprint of the garage will need to be removed to provide off street parking refer to Civil-1/B.









This is to certify that the Stormwater Management Plan layout as shown on STORM-1/B, STORM-2/A and Civil-1/B by Taylor Consulting Civil & Structural Engineers has been designed in accordance with section 3.1.2, 'Drainage', of the Building Code of Australia Housing Provision, AS/NZS 3500.3.2 – Stormwater Drainage, AS/NZS 2890.1 - Parking facilities Off-street parking and Northern Beaches Council - Water Management for Development Policy.

Should you require any further information please contact the undersigned.

Yours faithfully
TAYLOR CONSULTING

D M SCHAEFER - Director
B.E. Civil – Hons. M.I.E. Aust. N.E.R.






ISSUE DATE	REVISION
APRIL 2023	TO SUIT REVISED ARCHITECTURAL DESIGN

TITLE STORMWATER MANAGEMENT DETAILS 252 HUDSON PARADE, CLAREVILLE			
DRAWN L1	DATE 19 APRIL 2023	CHECKED 	SCALE 1:20 1:10
TAYLOR CONSULTING CIVIL & STRUCTURAL ENGINEERS			

TAYLOR CONSULTING CIVIL & STRUCTURAL ENGINEERS	STORM-2/A



SITE DRAINAGE PLAN
SCALE 1:100

DRAINAGE NOTES	
1. + DENOTES EXISTING GROUND LEVEL.	
2. FALL STORMWATER PIPES AT 1% MIN UNLESS OTHERWISE NOTED.	
3. SUB-SOIL DRAINAGE TO BE CONNECTED TO THE SITE DRAINAGE SYSTEM AS NECESSARY.	
4. SURFACE GRATES 300 SQ. UNLESS OTHERWISE NOTED.	
5. ALL STORMWATER PIPES TO HAVE SOLVENT CEMENT WATERTIGHT JOINTS.	
6. CHECK & LOCATE DEPTH OF EXISTING MAINS & SERVICES PRIOR TO CONSTRUCTION OF STORMWATER SYSTEM AS VARIATIONS IN POSITION OF MAINS COULD AFFECT DRAINAGE CONSTRUCTION DETAILS.	
7. INSPECTIONS MUST BE UNDERTAKEN BY THIS OFFICE (BY PRIOR ARRANGEMENT WITH ENGINEER) DURING CONSTRUCTION TO ENABLE FULL CERTIFICATION UPON COMPLETION OF WORKS.	
8. ALL CONSTRUCTION OF COUNCIL DRAINAGE WORKS TO COMPLY WITH COUNCIL STANDARD.	
9. REMOVE REDUNDANT DRAINAGE PITS AND SEAL PIPES.	
10. PIT BENCHING TO BE HALF THE OUTGOING PIPE DIAMETER. CONCRETE FOR BENCHING TO BE 20 MPa MASS CONCRETE.	
11. APPROVED PRE-CAST PITS MAY BE USED.	
12. ALL PIPES TO BE LAID ON COMPACTED FINE CRUSHED ROCK OR SAND BEDDING 75mm THICK & PIPES BACKFILLED WITH COMPACTED SAND TO 300mm ABOVE TOP OF PIPE, ELSE ATTACHED TO UNDERSIDE OF STRUCTURE AT 600mm C/C AS NECESSARY.	
13. PIPE ROUTES SHOWN ARE INDICATIVE ONLY AND SHOULD BE AS NECESSARY ACCORDING TO SITE CONDITIONS, TREE POSITIONS ETC. CONFORM SIGNIFICANT CHANGES IN PIPES SYSTEM DETAILS WITH SUPERVISING ENGINEER PRIOR TO COMMENCEMENT OF DRAINAGE CONSTRUCTION WORKS.	
14. CONTRACTOR SHALL ENSURE THAT SERVICES TO BUILDINGS NOT AFFECTED BY THE WORKS ARE NOT DISRUPTED. CONTRACTOR SHALL CONSTRUCT TEMPORARY SERVICES TO MAINTAIN EXISTING SUPPLY TO BUILDINGS WHERE REQUIRED. ONCE WORKS ARE COMPLETE AND COMMISSIONED THE CONTRACTOR SHALL REMOVE ALL TEMPORARY SERVICES AND MAKE GOOD ALL DISTURBED AREAS.	
15. STORMWATER SYSTEM REQUIRES SIGNIFICANT MAINTENANCE DUE TO POTENTIAL HIGH POLLUTANT LOAD. FILTERS AND POLLUTANT TRAPS SHOULD BE CHECKED AFTER LARGE STORM EVENTS AND CLEANED EVERY 6 MONTHS.	
16. PLUMBING AND DRAINAGE WORKS TO COMPLY WITH AS-3500, THE NATIONAL DRAINAGE & PLUMBING CODE.	
17. WHERE POSSIBLE DRAINAGE LINES SHALL BE LAID IN AREAS PREVIOUSLY DISTURBED BY OTHER SITE WORKS AND FOLLOW TOPOGRAPHICAL FEATURES TO REDUCE IMPACT AND AVOID TREE ROOTS.	
18. THIS STORMWATER MANAGEMENT PLAN HAS BEEN PREPARED FOR SUBMISSION TO COUNCIL/CERTIFIER AND DOES NOT NECESSARILY CONTAIN ALL APPROPRIATE INFORMATION TO ENABLE FOR ISSUE TO PLUMBER/BUILDER FOR CONSTRUCTION. CONTACT TAYLOR CONSULTING FOR MORE INFORMATION.	

RAINWATER RE-USE NOTES AND SPECIFICATIONS	
1. ROOF WATER ONLY TO BE DRAINED TO THE RAINWATER STORAGE TANK.	
2. THE RAINWATER STORAGE TANK NEEDS TO BE CONNECTED FOR RE-USE AS REQUIRED BY THE OWNER.	
3. RAINWATER STORAGE TANK TO BE CONFIGURED IN ACCORDANCE WITH SYDNEY WATER SPECIFICATIONS 'GUIDELINES FOR RAINWATER TANK ON RESIDENTIAL PROPERTIES'.	
4. PROVIDE MAINS 'TOP-UP' SUPPLY TO RAINWATER TANK. MAINS 'TOP-UP' ZONE TO BE BASED ON THE DAILY NON-POTABLE USAGE THAT MAY BE EXPECTED FROM THE TANK.	
5. PROVIDE A MECHANICAL PUMPING ARRANGEMENT (IN SOUND-PROOF HOUSING) TO PUMP SUPPLIERS SPECIFICATION TO SUIT INTENDED USAGE OF RAINWATER STORAGE. PUMPING ARRANGEMENTS MUST COMPLY WITH EPA GUIDELINES.	
6. INLETS TO RAINWATER TANK MUST BE SCREENED TO PREVENT THE ENTRY OF FOREIGN MATTER, ANIMALS OR INSECTS.	
7. A SIGN MUST BE AFFIXED TO THE RAINWATER TANK CLEARLY STATING THAT THE WATER IN THE TANK IS RAINWATER AND IS NOT TO BE USED FOR HUMAN CONSUMPTION.	
8. RAINWATER TANK TO BE PLACED ON A STRUCTURALLY ADEQUATE BASE IN ACCORDANCE WITH THE MANUFACTURER'S OR STRUCTURAL ENGINEER'S DETAILS.	
9. THE TANK MUST NOT BE INSTALLED OVER ANY MAINTENANCE STRUCTURE OR FITTINGS USED BY A PUBLIC AUTHORITY.	
10. RAINWATER TANK AND ASSOCIATED PLUMBING WORKS TO BE INSTALLED AND CONFIGURED BY A LICENSED PLUMBER. PUMP TO BE INSTALLED BY A LICENSED ELECTRICIAN.	

ISSUE DATE	REVISION
SEPT 2022	TO SUIT CLIENT COMMENTS
APRIL 2023	TO SUIT REVISED ARCHITECTURAL DESIGN
APRIL 2023	SRZ & TPZ NOTATION ADDED

TITLE STORMWATER MANAGEMENT PLAN 252 HUDSON PARADE, CLAREVILLE			
DRAWN JBP	DATE 30 AUGUST 2022	CHECKED 	SCALE @ A1 1:100

STORMWATER SYSTEM DESIGN DATA

SITE DATA

SITE AREA = 1015.4 m² (100%)
PROPOSED IMPERVIOUS AREA = 403.8 m² (39%)
PROPOSED LANDSCAPED AREA = 611.6 m² (61%)
EXISTING IMPERVIOUS AREA = 301 m² (30%)
EXISTING LANDSCAPED AREA = 714.4 m² (70%)

TAYLOR CONSULTING CIVIL & STRUCTURAL ENGINEERS

STORM-1/C