

## Building Assessment Referral Response

<b>Application Number:</b>	DA2021/1844
<b>Date:</b>	19/10/2021
<b>To:</b>	Claire Ryan
<b>Land to be developed (Address):</b>	Lot A DP 304102 , 26 Jamieson Parade COLLAROY NSW 2097

### Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

### Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no concerns with the application subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Building Assessment Conditions

#### **CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE**

#### **Fire separation of garage top dwellings**

Where parts of a Class 1a dwelling are located above a Class 10a private garage that is not associated with the Class 1a dwelling, fire separation works is required to comply with Part 3.7.4 of the Building Code of Australia –'Fire separation of garage top dwellings' and NSW 1.1 Additions. Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for fire safety and for building occupant safety.

**Separating walls****Fire Separation**

A separating wall between Class 1 buildings, or a wall that separates a Class 1 building from a Class 10a building which is not associated with the Class 1 building is required to comply with Part 3.7.3.2 of the Building Code of Australia –‘Separating Walls’. Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for fire safety and for building occupant safety.

**Sound Insulation**

The new building that is proposed to be constructed as an attached secondary dwelling is required to comply with Part 3.8.6 of the Building Code of Australia –‘Sound Insulation’. Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for building occupant health and amenity.

**Laundry Facilities**

A laundry area to incorporate clothes washing facilities, comprising of at least one washtub and space in the same room for a washing machine and is required to comply with Part 3.8.3 of the Building Code of Australia –‘Facilities’. A kitchen sink or washbasin must not be counted as a laundry washtub. Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for building occupant health and amenity.