Development Compliance Group 8am to 6pm Mon - Thurs, 8am to 5pm Fri Phone 9970 1111

22 August 2003

Andrew White 1058 Barrenjoey Road Palm Beach NSW 2108

Dear Sir/Madam

## Re :Construction Certificate Application CC0383/03Property :1058 Barrenjoey Road, Palm Beach

Thank you for selecting Council to assess your application.

As dicussed, the following items remain outstanding and require your attention to enable Council to approve your Construction Certificate :

- Condition B5 The statement as submitted is required to be expanded to state compliance with the AS 3959 -1999 Construction of Buildings in Bush Fire Prone Areas being:
  - (i) Guttering to have a flammability index not greater than 5,
  - (ii) Sarking with a flammability index not greater than 5 is to be installed behind the external cladding,
  - (iii) The eastern elevation timber fascia is to be constructed of fire retardant treated timber, and
  - (iv) The statement is to include a date, name and signature of the author.

All new information provided to Council should clearly quote your application number CC0383/03.

Yours faithfully

Robina Warburton SENIOR ENVIRONMENTAL HEALTH OFFICER