



## Engineering Referral Response

|  |   |
|--|---|
| <b>Application Number:</b>             | DA2019/0587                                     |
| <b>To:</b>                             | Ashley Warnest                                  |
| <b>Land to be developed (Address):</b> | Lot 2 DP 513161 , 1 Beach Road NEWPORT NSW 2106 |

### Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m<sup>2</sup> or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

### Officer comments

The submitted Geotechnical report addresses the relevant DCP controls and certifies that an acceptable risk is achievable for the development. The driveway grade and parking slab designed by NB Consulting Engineers is acceptable. No objection to approval, subject to conditions.

### Referral Body Recommendation

Recommended for approval, subject to conditions

### Refusal comments

### Recommended Engineering Conditions:

#### CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

#### Stormwater Disposal

Stormwater shall be disposed of to an existing approved system or in accordance with Northern Beaches Council's PITTWATER DCP21 clause B5.10.

A certificate is to be provided to the Certifying Authority with the Construction Certificate application by a qualified experienced practicing Civil Engineer, with Corporate membership of the Institute of Engineers Australia (M.I.E.) or who is eligible to become a Corporate member and has appropriate experience and

competence in the related field that the existing approved system can accommodate the additional flows or provide drainage plans demonstrating compliance with Council's requirements.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority for approval prior to the issue of the Construction Certificate.

Reason: To ensure appropriate provision for disposal and stormwater management arising from development.

### **Geotechnical Report Recommendations have been Incorporated into Designs and Structural Plans**

The recommendations of the risk assessment required to manage the hazards as identified in the Geotechnical Report prepared by White geotechnical group dated 8th April, 2019 are to be incorporated into the construction plans. Prior to issue of the Construction Certificate, Form 2 of the Geotechnical Risk Management Policy for Pittwater (Appendix 5 of P21 DCP) is to be completed and submitted to the Accredited Certifier. Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure geotechnical risk is mitigated appropriately.

### **Vehicle Driveway Gradients**

Driveway gradients, car parking and turning maneuvering area within the private property are to comply with AS/NZS 28901:2004

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate

Reason: To ensure suitable vehicular access to private property

### **Structural Adequacy and Excavation Work**

Excavation work is to ensure the stability of the soil material of adjoining properties, the protection of adjoining buildings, services, structures and / or public infrastructure from damage using underpinning, shoring, retaining walls and support where required. All retaining walls are to be structurally adequate for the intended purpose, designed and certified by a Structural Engineer, except where site conditions permit the following:

(a) maximum height of 900mm above or below ground level and at least 900mm from any property boundary, and

(b) Comply with AS3700, AS3600 and AS1170 and timber walls with AS1720 and AS1170.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Construction Certificate.

Reason: To provide public and private safety.

## **CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK**

### **Road Reserve**

The public footways and roadways adjacent to the site shall be maintained in a safe condition at all times during the course of the work.

Reason: Public Safety.

## **CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE**

### **Certification Elevated Parking Facility Work**

An appropriately qualified and practicing Structural Engineer shall certify to the Council / Principal Certifying Authority that the elevated parking facility was constructed in accordance with this consent and the provisions of Australian/New Zealand Standard AS/NZS 2890.1:2004 parking facilities - Off-street car

parking, in particular Section 2.4.5 Physical controls. Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of an Occupation (or Subdivision)

Reason: Compliance with this consent

**Geotechnical Certification Prior to Occupation Certificate**

Prior to issue of the Occupation Certificate, Form 3 of the Geotechnical Risk Management Policy is to be completed and submitted to the Principal Certifying Authority.

Reason: To ensure geotechnical risk is mitigated appropriately.

**Certification of Storm Water Management**

Certification is to be provided to the accredited certifier by a qualified experienced practising Civil Engineer with corporate membership of the Institute of Engineers Australia (M.I.E.), or who is eligible to become a corporate member and has appropriate experience and competence in the related field, that the drainage/stormwater management system has been installed and completed in accordance with the engineering plans and specifications required under this consent.

Reason: To ensure Stormwater Management has been built in accordance with the plans and specifications required under this consent