

---

<b>Sent:</b>	17/05/2021 2:54:18 PM
<b>Subject:</b>	NSW RFS Determination - Your Reference - DA2020/1480 (CNR-18002)
<b>Attachments:</b>	DA20210219000658-Original-1 - 14-05-2021 09_39_50 - Determination Letter.pdf;



## NSW RURAL FIRE SERVICE

**Attention:** Anne-Marie Young

**Your Reference:** DA2020/1480 (CNR-18002)

**Application Details:** s100B – Subdivision – Original

**Site Address:**

8 Forest Road  
Warriewood NSW 2102

Please find attached correspondence relating to the above development.

Should you wish to discuss this matter please contact Craig Casey on 1300 NSW RFS and quote DA20210219000658-Original-1.



Planning and Environment Services

**NSW RURAL FIRE SERVICE**

Locked Bag 17 Granville NSW 2142

**P** 1300 NSW RFS **E** [records@rfs.nsw.gov.au](mailto:records@rfs.nsw.gov.au)

[www.rfs.nsw.gov.au](http://www.rfs.nsw.gov.au) | [www.facebook.com/nswrfs](https://www.facebook.com/nswrfs) | [www.twitter.com/nswrfs](https://www.twitter.com/nswrfs)

**PREPARE. ACT. SURVIVE.**



## NSW RURAL FIRE SERVICE

Northern Beaches Council  
PO Box 882  
MONA VALE NSW 1660

Your reference: DA2020/1480 (CNR-18002)  
Our reference: DA20210219000658-Original-1

**ATTENTION:** Anne-Marie Young

Date: Monday 17 May 2021

Dear Sir/Madam,

**Integrated Development Application**  
**s100B – Subdivision – Strata Title Subdivision**  
**8 Forest Road Warriewood NSW 2102, 1//5055**

I refer to your correspondence dated 17/02/2021 seeking general terms of approval for the above Integrated Development Application.

The New South Wales Rural Fire Service (NSW RFS) has considered the information submitted. General Terms of Approval, under Division 4.8 of the *Environmental Planning and Assessment Act 1979*, and a Bush Fire Safety Authority, under section 100B of the *Rural Fires Act 1997*, are now issued subject to the following conditions:

### Asset Protection Zones

***Intent of measures: to provide sufficient space and maintain reduced fuel loads to ensure radiant heat levels at the buildings are below critical limits and prevent direct flame contact.***

1. At the issue of a subdivision certificate, and in perpetuity to ensure ongoing protection from the impact of bush fires, the site around the proposed buildings must be maintained as an inner protection area (IPA) as follows:

- North for a distance of 14 metres;
- West for a distance of 24 metres;
- South for a distance of 24 metres; and,
- East up to the lots site boundaries.

When establishing and maintaining an IPA the following requirements apply in accordance with the requirements of Appendix 4 of *Planning for Bush Fire Protection 2019*:

- tree canopy cover should be less than 15% at maturity;
- trees at maturity should not touch or overhang the building;
- lower limbs should be removed up to a height of 2m above the ground;
- tree canopies should be separated by 2 to 5m;
- preference should be given to smooth barked and evergreen trees;
- large discontinuities or gaps in vegetation should be provided to slow down or break the progress of fire towards buildings;

1

#### Postal address

NSW Rural Fire Service  
Locked Bag 17  
GRANVILLE NSW 2142

#### Street address

NSW Rural Fire Service  
4 Murray Rose Ave  
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555  
F (02) 8741 5550  
[www.rfs.nsw.gov.au](http://www.rfs.nsw.gov.au)

- shrubs should not be located under trees;
- shrubs should not form more than 10% ground cover; and
- clumps of shrubs should be separated from exposed windows and doors by a distance of at least twice the height of the vegetation.
- grass should be kept mown (as a guide grass should be kept to no more than 100mm in height); and
- leaves and vegetation debris should be removed

### **Construction Standards**

***Intent of measures: to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting firefighting activities.***

2. Proposed construction of Apartment Blocks A1, B1 and B2's western and southern elevations as well as northern elevations of Blocks A1 & A2 (sightlines) and eastern elevation of B2 (sightlines) and roofing, must comply with section 3 and section 7 (BAL 29) Australian Standard AS3959-2018 *Construction of buildings in bush fire-prone areas* or NASH Standard (1.7.14 updated) *National Standard Steel Framed Construction in Bushfire Areas – 2014* as appropriate and Section 7.5 of *Planning for Bush Fire Protection 2019*.

3. Proposed construction of Apartment Blocks A2's eastern elevation, as well as all the internal communal open space elevations of the Apartment Blocks, must comply with section 3 and section 6 (BAL 19) Australian Standard AS3959-2018 *Construction of buildings in bush fire-prone areas* or NASH Standard (1.7.14 updated) *National Standard Steel Framed Construction in Bushfire Areas – 2014* as appropriate and Section 7.5 of *Planning for Bush Fire Protection 2019*.

### **Water and Utility Services**

***Intent of measures: to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting firefighting activities.***

4. The provision of water, electricity and gas must comply with the following in accordance with Table 7.4a of *Planning for Bush Fire Protection 2019*:

- reticulated water is to be provided to the development where available;
- all above-ground water service pipes external to the building are metal, including and up to any taps;
- where practicable, electrical transmission lines are underground;
- where overhead, electrical transmission lines are proposed as follows:

a) lines are installed with short pole spacing (30m), unless crossing gullies, gorges or riparian areas; and  
 b) no part of a tree is closer to a power line than the distance set out in accordance with the specifications in ISSC3 *Guideline for Managing Vegetation Near Power Lines*.

- reticulated or bottled gas is installed and maintained in accordance with AS/NZS 1596:2014 and the requirements of relevant authorities, and metal piping is used;
- all fixed gas cylinders are kept clear of all flammable materials to a distance of 10m and shielded on the hazard side;
- connections to and from gas cylinders are metal;
- polymer-sheathed flexible gas supply lines are not used; and
- above-ground gas service pipes are metal, including and up to any outlets.

### **Landscaping Assessment**

***The intent of measures is for landscaping. To achieve this, the following conditions must apply:***

5. Landscaping within the required asset protection zone must comply with Appendix 4 of *Planning for Bush Fire Protection 2019*. In this regard, the following principles are to be incorporated:

- A minimum 1 metre wide area, suitable for pedestrian traffic, must be provided around the immediate curtilage of the building;
- Planting is limited in the immediate vicinity of the building;
- Planting does not provide a continuous canopy to the building (i.e. trees or shrubs are isolated or located in small clusters);

- Landscape species are chosen to ensure tree canopy cover is less than 15% (IPA), and less than 30% (OPA) at maturity and trees do not touch or overhang buildings;
- Avoid species with rough fibrous bark, or which retain/shed bark in long strips or retain dead material in their canopies;
- Use smooth bark species of trees species which generally do not carry a fire up the bark into the crown;
- Avoid planting of deciduous species that may increase fuel at surface/ ground level (i.e. leaf litter);
- Avoid climbing species to walls and pergolas;
- Locate combustible materials such as woodchips/mulch, flammable fuel stores away from the building;
- Locate combustible structures such as garden sheds, pergolas and materials such as timber garden furniture away from the building; and
- Low flammability vegetation species are used.

For any queries regarding this correspondence, please contact Craig Casey on 1300 NSW RFS.

Yours sincerely,

Nika Fomin  
**Manager Planning & Environment Serv (E)**  
**Built & Natural Environment**



NSW RURAL FIRE SERVICE

# BUSH FIRE SAFETY AUTHORITY

Subdivision – Strata Title Subdivision  
8 Forest Road Warriewood NSW 2102, 1//5055  
RFS Reference: DA20210219000658-Original-1  
Your Reference: DA2020/1480 (CNR-18002)

This Bush Fire Safety Authority is issued on behalf of the Commissioner of the NSW Rural Fire Service under s100b of the Rural Fires Act (1997) subject to the attached General Terms of Approval.

This authority confirms that, subject to the General Terms of Approval being met, the proposed development will meet the NSW Rural Fire Service requirements for Bush Fire Safety under *s100b of the Rural Fires Act 1997*.

**Nika Fomin**

**Manager Planning & Environment Serv (E)  
Built & Natural Environment**

Monday 17 May 2021