

---

**Sent:** 11/03/2020 7:26:24 AM  
**Subject:** Online Submission

11/03/2020

MR Steve Head  
7 Ourimbah Creek Rd7 - 7 Ourimbah Creek RD  
Ourimbah NSW 2258  
shead@ausgrid.com.au

**RE: DA2020/0153 - 25 - 29 Winbourne Road BROOKVALE NSW 2100**

**AUSGRID RESPONSE:**

There are underground cables in the road reserve and on the property approximately 3m either side of the Ausgrid substation S16818. Ausgrid cables must be identified and if any work is to occur in the vicinity of Ausgrid cables, Ausgrid standard NS156 (available on the Ausgrid website) must be complied with.

Ausgrid has no other objections to the proposed development.