




www.bushconaustralia.com.au - Email-[info@bushconaustralia.com.au](mailto:info@bushconaustralia.com.au)

PO Box 363 Balgowlah, NSW, 2093

## Bush Fire Assessment Report

In relation to a proposed development at:

25 Montpelier Place, Manly, NSW

This assessment has been prepared and certified by: Matthew Toghil. BPAD certified practitioner FPAA Accreditation No: BPAD31642 Report No: 25Mon-01    Date: 15/09/2021	
Architectural plans provided by:	Wolski.Coppin Architecture Project No: 22012 Dated: 04.08.2021

## Table of Contents

Executive Summary .....	3
1. Description of the subject property.....	4
2. Development Proposal and Building Classification .....	5
3. Classification of the Vegetation on and surrounding the site .....	6
4. Assessment of effective slope .....	7
5. Access and Egress .....	7
6. Adequacy of water supply.....	7
7. Features that may mitigate the impact of a high intensity bushfire.....	8
8. Environmental impact of any proposed bushfire protection measures.....	8
9. Bushfire Risk Assessment.....	9
Alterations and additions to the existing dwelling .....	9
10. The extent to which the construction conforms or deviates from Chapter 7 of 'Planning for Bushfire Protection 2019' .....	10
11. Recommendations .....	11
12. Summary .....	12
13. References.....	13
Appendix 1: AS3959 2018, Method 2 calculations .....	14
Appendix 2: Performance criteria and acceptable solutions as per Table 7 <i>Planning for bushfire Protection 2019</i> .....	15
Appendix 3: 7.5.2 NSW State Variations under G5.2(a)(i) and 3.10.5.0(c)(i) of the NCC ....	16
Appendix 4: Northern Beaches Council Bushfire Certificate. ....	17

## Executive Summary

The purpose of the report is to determine the category of bushfire attack and subsequent construction standard for the proposed alterations and additions to the existing dwelling at No. 25 Montpelier Place, Manly, NSW.

The site had been identified as 'bush fire prone land' for the purpose of Section 146 of the *Environmental Planning and Assessment Act 1979* and the Legislative requirements for building on bush fire prone lands are applicable.

The proposed development is in infill development as defined within Chapter 7 of *Planning for Bushfire Protection 2019* and this report has been prepared in accordance with the requirements of Section 4.14 of the Environment Planning and Assessment Act.

This assessment includes an analysis of the hazard, threat and subsequent risk of the development proposal and provides recommendations that satisfy the Objective and Performance requirements of the Building Code of Australia, Planning for Bushfire Protection 2019 [PBP] and Australian Standard AS3959, 2018.

Following a site assessment, it was determined the distance of the development from the closest hazard would keep the Bushfire Attack Level (BAL) to BAL-19, in accordance with the methodology described in PBP and AS3959-2018. The development also meets performance criteria as set out in chapter 7 of PBP in relation to APZ's, siting and design, construction standards, access and egress requirements, water and utility services and landscaping.

## 1. Description of the subject property

Property address: Lot 25/-/DP1105469, 25 Montpelier Place, Manly

Local Government Area: Northern Beaches

The development site is a residential block with access off Montpelier Place. The following sections 4-8 describe in detail the vegetation, slope, access and egress, availability of water supplies and environmental considerations for the site.



Figure 1: Location of the subject site

## 2. Development Proposal and Building Classification

The development proposal is for the alterations and additions to the existing dwelling.




Figure 2: Site/roof plan.




Figure 3: Bushfire prone land map.



### 3. Classification of the Vegetation on and surrounding the site

For the purpose of a Bush Fire Risk Assessment, vegetation within 140m of the site is assessed and classified. In this instance there is an area of Category 1 vegetation that lies to the south of the site which is of significance. The vegetation formation within this area consists of Sydney Coastal Heath (Refer to Figure 5) and for the purpose for this assessment will be classified as 'Tall Heath'.



Figure 4: Aerial photo showing vegetation within 140m of the site.




Figure 5: Aerial photo showing vegetation formations surrounding the subject site (Source: NSW Government Central Resource for Sharing and Enabling Environment Data)



## 4. Assessment of effective slope



### Legend:

 Direction of effective slope

Figure 6: Contour map.

Transect Line	Effective slope
T1	Upslope 10 degrees

## 5. Access and Egress

The site has direct access to Montpelier Place, which is a public road, access and egress for emergency vehicles appears adequate.

## 6. Adequacy of water supply

The area has reticulated water supply and hydrants are spaced at a regular distance along Montpelier Place.

## **7. Features that may mitigate the impact of a high intensity bushfire**

There are no significant features on or adjoining the site that may mitigate the impact of a high intensity bushfire on the proposed development.

## **8. Environmental impact of any proposed bushfire protection measures.**

The scope of this assessment has not been to provide an environmental assessment. However, the bushfire protection measures that are proposed will have no adverse environmental effects. All protection measures are either within the boundaries of the allotment or part of the constructed building.



## 9. Bushfire Risk Assessment

### Alterations and additions to the existing dwelling



Figure 7: Aerial photo showing distance to surrounding vegetation.

**Table 1;** Determination of the category of bushfire attack for the site, and subsequent required building standards (Reference: Method 2 AS3959 2018).

Transect	Distance to classified vegetation	Vegetation Classification	Assessment of effective slope	FDI	Bushfire Attack Level
T1	18.49m	Tall Heath	Upslope 10 degrees	100	BAL-19

**Summary:** Based upon the relevant provisions of PBP and AS3959-2018, the maximum anticipated radiant heat attack for the dwelling is <19kW/m<sup>2</sup> and the subsequent minimum construction standard is BAL-19 AS 3959- 2018.

The principle of shielding allows for the next lower BAL level than that determined for the site to be applied to an elevation of the building where the elevation is not exposed to the source of bushfire attack. In this instance, the east and south elevations must be BAL-19 and the north and west elevation can be reduced by one level to BAL-12.5.

[There can only be a reduction of one BAL and this can only apply to the elevation directly opposite the exposed side]

## 10. The extent to which the construction conforms or deviates from Chapter 7 of 'Planning for Bushfire Protection 2019'.

Performance Criteria	How this development meets acceptable solutions
The intent may be achieved where:	
<u>In relation to APZ's:</u> -Defendable space is provided onsite. -An APZ is provided and maintained for the life of the building.	Defendable space is provided on all sides of the building. Asset protection zones are provided for on site and by adjoining development and public roads.
<u>In relation to construction standards:</u> It is demonstrated that the proposed building can withstand bushfire attack in the form of wind, smoke, embers, radiant heat and flame contact.	Construction standards have been recommended in accordance with the requirements of <i>Planning for Bushfire Protection 2019</i> and <i>AS 3959-2018 Construction of buildings in bushfire prone areas</i> .
<u>In relation to access requirements:</u> Safe operational access is provided [and maintained] for emergency service personnel in suppressing a bushfire while residents are seeking to relocate, in advance of a bushfire.	This site has direct access to public roads, and the access and egress for emergency vehicles and evacuation appears to be adequate.
<u>In relation to water and utility services:</u> -Adequate water and electrical services are provided for fire fighting operations.	The area has reticulated water supply with hydrants spaced at a regular distance along Montpelier Palce and surrounding residential streets.
<u>In relation to landscaping:</u> It is designed and managed to minimise flame contact and radiant heat to buildings, and the potential for wind driven embers to cause ignition.	All new landscaping should Appendix 4 of <i>Planning for Bushfire Protection 2019</i> which outlines the requirements for landscaping and property maintenance.
<u>In relation to emergency and evacuation planning</u>	It is advised the residents should complete a <i>Bushfire Survival Plan</i> as formulated by the NSW Rural Fire Service and Fire and Rescue NSW.

## 11. Recommendations

The following recommendations are made for the bushfire protection measures for the proposed alterations and additions to the existing dwelling at No. 25 Montpelier Place, Manly, NSW and are based upon the relevant provisions of the NSW RFS guideline entitled *Planning for Bushfire Protection 2019*.

1) <u>Construction standard.</u> North and west elevations	All new construction shall comply with a minimum standard of section 3 [construction general] and section 5 (BAL-12.5), AS 3959-2018 and Chapter 7 of <i>Planning for Bushfire Protection 2019</i> .
2) <u>Construction standard.</u> East and south elevations	All new construction shall comply with a minimum standard of section 3 [construction general] and section 6 (BAL-19), AS 3959-2018 and Chapter 7 of <i>Planning for Bushfire Protection 2019</i> .
3) <u>Asset Protection Zones</u>	All new landscaping should be designed in accordance with the Asset protection Zone principles of Appendix 4 of PBP 2019.
4) <u>Emergency Risk Management</u>	It is advised the residents should complete a <i>Bushfire Survival Plan</i> as formulated by the NSW Rural Fire Service and Fire and Rescue NSW. An emergency evacuation is not recommended as a condition of consent.
5) <u>Adjacent Structures [class 10a &amp; 10b]</u>	Where Class 10a & 10b structures are within 6m from a dwelling in bush fire prone areas it must be built in accordance with the NCC.
6) <u>Water supplies</u>	Reticulated water supply is located on the adjoining road at regular intervals and is easily accessible. No additional water supplies have been recommended.
7) <u>Fences and gates</u>	All fences in bush fire prone areas should be made from either hardwood or non-combustible material. However, in circumstances where the fence connects directly to the dwelling, or in areas of BAL-29 or greater, they should be made of non-combustible material.

## 12. Summary

This report consists of a bushfire risk assessment for alterations and additions to the existing dwelling at No. 25 Montpelier Place, Manly, NSW.

The report concludes that the proposed development is on designated bushfire prone land and the legislative requirements for development of bushfire prone areas are applicable. The proposed development will be constructed to the minimum standard required in accordance with the guidelines of *Planning for Bushfire Protection 2019* and *AS 3959-2018 Construction of buildings in bushfire prone areas*.

This report has considered all of the elements of bushfire attack and provided the proposed development is constructed in accordance with the recommendations of Section 11 of this report, it is my considered opinion that the development satisfies the Objectives and Performance requirements of the *Building Code of Australia, Planning for bushfire Protection 2019* and *Australian Standard AS3959, 2018*.

*Note: Not with standing the precautions adopted, it should always be remembered that bushfires burn under a wide range of conditions and an element of risk, no matter how small always remains, and although the standard is designed to improve the performance of such buildings, there can be no guarantee, because of the variable nature of bushfires, that any one building will withstand a bushfire attack on every occasion. This report is a Bushfire Hazard Assessment that provides the required information to assist Local Councils and the Rural fire Service in determining compliance in accordance with Planning for Bushfire Protection 2019 and AS3959, 2018. The local Council is the final consenting authority and the construction of the building must comply with the recommendations included in the council's conditions of consent.*



Matthew Toghil- Bushfire Consultant  
Accreditation No: BPAD31642  
Grad Cert in Bushfire Protection, UWS 2012  
Certificate IV Building and Construction  
Certificate III in Public Safety (firefighting and emergency operations)



BPAD-A Certified Practitioner/Certified Business - Certification No BPD-PA09328  
Ron Coffey – Bushfire Safety Engineer  
Grad I Fire E [Institute of Fire Engineers - 1973]  
Grad Cert Fire Safety Eng. [UWS - 2003]  
Grad Dip Building in Bushfire Prone Areas [UWS – 2005]  
Ass Prof Cert in Expert Evidence in the Land & Environment Court [UTS – 2005]  
Member - Institute of Fire Engineers  
Member - Fire Protection Association Australia



## 13. References

### **Australian Building Codes Board**

Building Code of Australia

Volume 1 & 2

Canprint

### **Australian Building Codes Board [2001]**

Fire Safety Engineering Guidelines

Edition 2001

ABCB Canberra

### **D. Drysdale D. [1998]**

Introduction to Fire Dynamics 2<sup>nd</sup> Edition

John Wiley & Sons Ltd

### **NSW Government Environmental Planning and Assessment Act [1979]**

Part 79BA-Consultation and development consent- Certain bushfire prone land

NSW Government Printer

### **Planning for Bushfire Protection 2019**

A guide for Councils, Planners, Fire Authorities and Developers

*This document provides the necessary planning considerations when developing areas for residential use in residential, rural residential, rural and urban areas when development sites are in close proximity to areas likely to be affected by bushfire events and replaces Planning for Bushfire Protection 2006.*

*This document is essential reading. Download a copy from the RFS website or purchase a copy through the NSW Government online shop or phone 9228 6333.*

### **Ramsay C & Rudolph L [2003]**

Landscape and building design for bushfire prone areas

CSIRO Publishing

### **Standards Australia [2018]**

Australian Standards 3959

Australian Building Code Board

## Appendix 1: AS3959 2018, Method 2 calculations



### NBC Bushfire Attack Assessment Report V4.1

AS3959 (2018) Appendix B - Detailed Method 2

Print Date: 15/09/2021

Assessment Date: 15/09/2021

Site Street Address: 25 Montpelier Place, Manly  
Assessor: Matthew Toghil; Bushcon Australia Pty Ltd  
Local Government Area: Northern Beaches Alpine Area: No

#### Equations Used

Transmissivity: Fuss and Hammins, 2002  
Flame Length: RFS PBP, 2001/Vesta/Catchpole  
Rate of Fire Spread: Noble et al., 1980  
Radiant Heat: Drysdale, 1985; Sullivan et al., 2003; Tan et al., 2005  
Peak Elevation of Receiver: Tan et al., 2005  
Peak Flame Angle: Tan et al., 2005

Run Description: T1

#### Vegetation Information

Vegetation Type: Tall Heath  
Vegetation Group: Shrub & Heath  
Vegetation Slope: 10 Degrees  
Surface Fuel Load(t/ha): 36.9  
Vegetation Height(m): 3  
Vegetation Slope Type: Upslope  
Overall Fuel Load(t/ha): 36.9  
Only Applicable to Shrub/Scrub and Vesta

#### Site Information

Site Slope: 0 Degrees  
Elevation of Receiver(m): Default  
Site Slope Type: Level  
APZ/Separation(m): 18.49

#### Fire Inputs

Veg./Flame Width(m): 100  
Flame Temp(K): 1090

#### Calculation Parameters

Flame Emissivity: 95  
Heat of Combustion(kJ/kg) 18600  
Moisture Factor: 5  
Relative Humidity(%): 25  
Ambient Temp(K): 308  
FDI: 100

#### Program Outputs

Level of Construction: BAL 19  
Radiant Heat(kW/m2): 17.22  
Flame Length(m): 10.13  
Rate Of Spread (km/h): 2.09  
Transmissivity: 0.84  
Fire Intensity(kW/m): 39841  
Peak Elevation of Receiver(m): 4.84  
Flame Angle (degrees): 73  
Maximum View Factor: 0.27  
Inner Protection Area(m): 18  
Outer Protection Area(m): 0

## Appendix 2: Performance criteria and acceptable solutions as per Table 7 Planning for bushfire Protection 2019

ACCESS	PERFORMANCE CRITERIA	ACCEPTABLE SOLUTIONS
	The intent may be achieved where:	
	<ul style="list-style-type: none"><li>firefighting vehicles are provided with safe, all-weather access to structures and hazard vegetation.</li></ul>	<ul style="list-style-type: none"><li>property access roads are two-wheel drive, all-weather roads.</li></ul>
	<ul style="list-style-type: none"><li>the capacity of access roads is adequate for firefighting vehicles.</li></ul>	<ul style="list-style-type: none"><li>the capacity of road surfaces and any bridges/causeways is sufficient to carry fully loaded firefighting vehicles (up to 23 tonnes), bridges and causeways are to clearly indicate load rating.</li></ul>
	<ul style="list-style-type: none"><li>there is appropriate access to water supply.</li></ul>	<ul style="list-style-type: none"><li>hydrants are provided in accordance with the relevant clauses of AS 2419.1:2005;</li><li>There is suitable access for a Category 1 fire appliance to within 4m of the static water supply where no reticulated supply is available.</li></ul>
	<ul style="list-style-type: none"><li>firefighting vehicles can access the dwelling and exit the property safely.</li></ul>	<ul style="list-style-type: none"><li>at least one alternative property access road is provided for individual dwellings or groups of dwellings that are located more than 200 metres from a public through road;</li><li>There are no specific access requirements in an urban area where an unobstructed path (no greater than 70m) is provided between the most distant external part of the proposed dwelling and the nearest part of the public access road (where the road speed limit is not greater than 70kph) that supports the operational use of emergency firefighting vehicles.</li><li>In circumstances where this cannot occur, the following requirements apply:<ul style="list-style-type: none"><li>minimum 4m carriageway width;</li><li>in forest, woodland and heath situations, rural property roads have passing bays every 200m that are 20m long by 2m wide, making a minimum trafficable width of 6m, at the passing bay;</li><li>a minimum vertical clearance of 4m to any overhanging obstructions, including tree branches;</li><li>property access must provide a suitable turning area in accordance with Appendix 3;</li><li>curves have a minimum inner radius of 6m and are minimal in number to allow for rapid access and egress;</li><li>the minimum distance between inner and outer curves is 6m;</li><li>the crossfall is not more than 10 degrees;</li><li>maximum grades for sealed roads do not exceed 15 degrees and not more than 10 degrees for unsealed roads; and</li><li>a development comprising more than three dwellings has formalised access by dedication of a road and not by right of way.</li></ul></li></ul>
	Note: Some short constrictions in the access may be accepted where they are not less than 3.5m wide, extend for no more than 30m and where the obstruction cannot be reasonably avoided or removed. The gradients applicable to public roads also apply to community style development property access roads in addition to the above.	
PERFORMANCE CRITERIA	ACCEPTABLE SOLUTIONS	
The intent may be achieved where:		
<ul style="list-style-type: none"><li>an adequate water supply is provided for firefighting purposes.</li></ul>	<ul style="list-style-type: none"><li>reticulated water is to be provided to the development, where available; and</li><li>a static water supply is provided where no reticulated water is available.</li></ul>	
<ul style="list-style-type: none"><li>water supplies are located at regular intervals; and</li><li>the water supply is accessible and reliable for firefighting operations.</li></ul>	<ul style="list-style-type: none"><li>fire hydrant spacing, design and sizing comply with the relevant clauses of AS 2419.1:2005;</li><li>hydrants are not located within any road carriageway; and</li><li>reticulated water supply to urban subdivisions uses a ring main system for areas with perimeter roads.</li></ul>	
<ul style="list-style-type: none"><li>flows and pressure are appropriate.</li></ul>	<ul style="list-style-type: none"><li>fire hydrant flows and pressures comply with the relevant clauses of AS 2419.1:2005.</li></ul>	
<ul style="list-style-type: none"><li>the integrity of the water supply is maintained.</li></ul>	<ul style="list-style-type: none"><li>all above-ground water service pipes external to the building are metal, including and up to any taps.</li></ul>	
<ul style="list-style-type: none"><li>a static water supply is provided for firefighting purposes in areas where reticulated water is not available.</li></ul>	<ul style="list-style-type: none"><li>where no reticulated water supply is available, water for firefighting purposes is provided in accordance with Table 5.3d;</li><li>a connection for firefighting purposes is located within the IPA or non-hazard side and away from the structure, 65mm Storz outlet with a ball valve is fitted to the outlet;</li><li>ball valve and pipes are adequate for water flow and are metal;</li><li>supply pipes from tank to ball valve have the same bore size to ensure flow volume;</li><li>underground tanks have an access hole of 200mm to allow tankers to refill direct from the tank;</li><li>a hardened ground surface for truck access is supplied within 4m;</li><li>above-ground tanks are manufactured from concrete or metal;</li><li>raised tanks have their stands constructed from non-combustible material or bush fire-resisting timber (see Appendix F of AS 3959);</li><li>unobstructed access can be provided at all times;</li><li>underground tanks are clearly marked;</li><li>tanks on the hazard side of a building are provided with adequate shielding for the protection of firefighters;</li><li>all exposed water pipes external to the building are metal, including any fittings;</li><li>where pumps are provided, they are a minimum 5hp or 3kW petrol or diesel-powered pump, and are shielded against bush fire attack; any hose and reel for firefighting connected to the pump shall be 19mm internal diameter; and</li><li>fire hose reels are constructed in accordance with AS/NZS 1221:1997, and installed in accordance with the relevant clauses of AS 2441:2005.</li></ul>	

ASSET PROTECTION ZONES	PERFORMANCE CRITERIA	ACCEPTABLE SOLUTIONS
	The intent may be achieved where:	
	<ul style="list-style-type: none"><li>APZs are provided commensurate with the construction of the building; and</li><li>A defensible space is provided.</li></ul>	<ul style="list-style-type: none"><li>an APZ is provided in accordance with Table A1.12.2 or A1.12.3 in Appendix 1.</li></ul>
	<ul style="list-style-type: none"><li>APZs are managed and maintained to prevent the spread of a fire to the building.</li></ul>	<ul style="list-style-type: none"><li>APZs are managed in accordance with the requirements of Appendix 4 of PBP.</li></ul>
	<ul style="list-style-type: none"><li>the APZ is provided in perpetuity.</li><li>APZ maintenance is practical, soil stability is not compromised and the potential for crown fires is minimised.</li></ul>	<ul style="list-style-type: none"><li>APZs are wholly within the boundaries of the development site.</li><li>APZ are located on lands with a slope less than 18 degrees.</li></ul>
	<p><b>Home-based child care:</b> the building must not be exposed to radiant heat levels exceeding 29kW/m<sup>2</sup> (1090K).</p>	<ul style="list-style-type: none"><li>an APZ is provided in accordance with Table A1.12.2 or A1.12.3 in Appendix 1.</li></ul>
PERFORMANCE CRITERIA	ACCEPTABLE SOLUTIONS	
The intent may be achieved where:		
<ul style="list-style-type: none"><li>landscaping is designed and managed to minimise flame contact and radiant heat to buildings; and the potential for wind-driven embers to cause ignitions.</li></ul>	<ul style="list-style-type: none"><li>compliance with the NSW RFS 'Asset protection zone standards' (see Appendix 4);</li><li>a clear area of low-cut lawn or pavement is maintained adjacent to the house;</li><li>fencing is constructed in accordance with section 7.6; and</li><li>trees and shrubs are located so that:<ul style="list-style-type: none"><li>the branches will not overhang the roof;</li><li>the tree canopy is not continuous; and</li><li>any proposed windbreak is located on the elevation from which fires are likely to approach.</li></ul></li></ul>	
<p><b>Home-based child care:</b> a bush fire emergency and evacuation management plan is prepared.</p>	<ul style="list-style-type: none"><li>a Bush Fire Emergency Management and Evacuation Plan is prepared by the operator consistent with the NSW RFS publication: A Guide to Developing a Bush Fire Emergency Management and Evacuation Plan, and the AS 3745:2010.</li></ul>	
PERFORMANCE CRITERIA	ACCEPTABLE SOLUTIONS	
The intent may be achieved where:		
<ul style="list-style-type: none"><li>location of electricity services limits the possibility of ignition of surrounding bush land or the fabric of buildings.</li></ul>	<ul style="list-style-type: none"><li>where practicable, electrical transmission lines are underground; and</li><li>where overhead, electrical transmission lines are proposed as follows:<ul style="list-style-type: none"><li>lines are installed with short pole spacing (30m), unless crossing gullies, gorges or riparian areas; and</li><li>no part of a tree is closer to a power line than the distance set out in accordance with the specifications in IS5C3 Guideline for Managing Vegetation Near Power Lines.</li></ul></li></ul>	
<ul style="list-style-type: none"><li>location and design of gas services will not lead to ignition of surrounding bushland or the fabric of buildings.</li></ul>	<ul style="list-style-type: none"><li>reticulated or bottled gas is installed and maintained in accordance with AS/NZS 1596:2014 and the requirements of relevant authorities; and metal piping is used;</li><li>all fixed gas cylinders are kept clear of all flammable materials to a distance of 10m and shielded on the hazard side;</li><li>connections to and from gas cylinders are metal; polymer-sheathed flexible gas supply lines are not used; and</li><li>above-ground gas service pipes are metal, including and up to any outlets.</li></ul>	
<ul style="list-style-type: none"><li>the proposed building can withstand bush fire attack in the form of embers, radiant heat and flame contact.</li></ul>	<ul style="list-style-type: none"><li>BAL is determined in accordance with Tables A1.12.5 to A1.12.7; and</li><li>construction provided in accordance with the NCC and as modified by section 7.5 (please see advice on construction in the flame zone).</li></ul>	
<ul style="list-style-type: none"><li>proposed fences and gates are designed to minimise the spread of bush fire.</li></ul>	<ul style="list-style-type: none"><li>fencing and gates are constructed in accordance with section 7.6.</li></ul>	
<ul style="list-style-type: none"><li>proposed Class 10a buildings are designed to minimise the spread of bush fire.</li></ul>	<ul style="list-style-type: none"><li>Class 10a buildings are constructed in accordance with section 8.3.2.</li></ul>	
<p><b>Home-based child care:</b> the proposed building can withstand bush fire attack in the form of wind, localised smoke, embers and expected levels of radiant heat.</p>	<ul style="list-style-type: none"><li>an APZ is provided in accordance with Table A1.12.2 or A1.12.3 in Appendix 1 of this document around the entire building or structure; and</li><li>the existing dwelling is required to be upgraded to improve ember protection. This is to be achieved by enclosing or covering openings with a corrosion-resistant steel, bronze or aluminium mesh with a maximum aperture of 2mm. Where applicable this includes the openable portion of the windows, vents, weepholes and eaves, but does not include roof tile spaces. Weather strips, draught excluders or draught seals shall be installed at the base of side hung external doors as per AS 3959. The subfloor space must be enclosed.</li></ul>	

Note: the above specifications and requirements apply in relation to residential infill developments but may be used to guide the application of BPMs for 'other' developments (see Chapter 8).

## Appendix 3: 7.5.2 NSW State Variations under G5.2(a)(i) and 3.10.5.0(c)(i) of the NCC

Certain provisions of AS 3959 are varied in NSW based on the findings of the Victorian Bush Fires Royal Commission and bush fire industry research.

The following variations to AS 3959 apply in NSW for the purposes of NSW G5.2(a)(i) of Volume One and NSW 3.10.5.0(c)(i) of Volume Two of the NCC; clause 3.10 of AS 3959 is deleted and any sarking used for BAL-12.5, BAL-19, BAL-29 or BAL-40 shall:

- be non-combustible; or
- comply with AS/NZS 4200.1, be installed on the outside of the frame and have a flammability index of not more than 5 as determined by AS 1530.2; and
- clause 5.2 and 6.2 of AS 3959 is replaced by clause 7.2 of AS 3959, except that any wall enclosing the subfloor space need only comply with the wall requirements for the respective BAL; and
- clause 5.7 and 6.7 of AS 3959 is replaced by clause 7.7 of AS 3959, except that any wall enclosing the subfloor space need only comply with the wall requirements for the respective BAL; and
- fascias and bargeboards, in BAL-40, shall comply with:
  - clause 8.4.1(b) of AS 3959; or
  - clause 8.6.6 of AS 3959.

The interpretation of this variation is:

Enclosed subfloors: For subfloor supports there are no requirements for supporting posts, columns, stumps, stringers piers and poles for subfloor supports for BAL 12.5 and BAL 19 when the subfloor space is enclosed with a wall that complies with the determined BAL level for the site.

Unenclosed subfloors: For unenclosed subfloor supporting posts, columns, stumps, stringers piers and poles the requirements are upgraded from BAL 12.5 and BAL 19 to BAL 29 level.

Enclosed verandas: There are no requirements for supporting posts, columns, stumps, stringers piers and poles for verandas, decks, steps and landings when the subfloor space is enclosed with a wall that complies with the determined BAL level for the site.

Unenclosed verandas: The requirements for supporting posts, columns, stumps, stringers piers and poles for verandas, decks, steps, and landings are upgraded from BAL 19 and BAL 12.5 to BAL 29 level.

For unenclosed subfloors of the main building or verandas, decks, steps and landings for BAL 12.5, 19 and BAL29 supporting posts, columns, stumps, stringers piers and poles shall be:

1. A non-combustible material; or
2. A Bushfire resistant timber; or
3. A combination of 1 and 2

Acceptable timber species:

Black-butt, Turpentine, Silver Top Ash, Spotted Gum, Red Iron Bark, Kwila, Red River Gum

Sarking: To comply with the NSW State variation any sarking used for BAL 12.5 shall:

- Be Non-combustible; or
- Comply with AS/NZ 4200.1 be installed on the outside of the frame and have a flammability index of not more than 5 as determined by AS1530.2



## Appendix 4: Northern Beaches Council Bushfire Certificate.

### BUSHFIRE RISK ASSESSMENT CERTIFICATE

THIS FORM IS TO BE COMPLETED BY A RECOGNISED CONSULTANT IN BUSHFIRE RISK ASSESSMENT IN ACCORDANCE WITH SECTION 4.14 1(b) OF THE ENVIRONMENTAL PLANNING AND ASSESSMENT ACT 1979 NO 203

PROPERTY ADDRESS:	25 Montpelier Place Manly
DESCRIPTION OF PROPOSAL:	Alterations & Additions
PLAN REFERENCE: (relied upon in report preparation)	Wolski, Coppin Architecture Project No: 22012 Dated: 01.09.2021
BAL RATING:	BAL-19 <small>(If the BAL rating is FZ the application is to be referred to NSW RFS for assessment.)</small>
DOES THE PROPOSAL RELY ON ALTERNATE SOLUTIONS:	YES <input type="radio"/> NO <input checked="" type="radio"/> <small>(Circle the relevant response)</small> <small>(If YES the application is to be referred to NSW RFS for assessment.)</small>

I Matthew Toghil of Bushfire Australia Pty Ltd.  
(Print Name) (Trading or Company Name)

have carried out a bushfire risk assessment on the above mentioned proposal and property. A detailed Bushfire Assessment Report is attached which includes the submission requirements set out in Appendix 2 of Planning for Bushfire Protection 2019 together with recommendations as to how the relevant specifications and requirements are to be achieved.

REPORT REFERENCE:	25Mon-01
REPORT DATE:	15.09.2021
CERTIFICATION No/ACCREDITED SCHEME:	BPAD31642.

I hereby certify, in accordance with Section 4.14 of the Environmental Planning and Assessment Act 1979 No 203:

- That I am a person recognised by the NSW Rural Fire Service as a qualified consultant in bushfire risk assessment; and
- That subject to the recommendations contained in the attached Bushfire Risk Assessment Report the proposed development conforms to the relevant specifications and requirements

I am aware that the Bushfire Assessment Report, prepared for the above mentioned site is to be submitted in support of a development application for this site and will be relied upon by Northern Beaches Council as the basis for ensuring that the bushfire risk management aspects of the proposed development have been addressed in accordance with Planning for Bushfire Protection 2019.

SIGNATURE:  DATE: 15.09.2021