

Natural Environment Referral Response - Riparian

Application Number:	DA2022/2265
Proposed Development:	Demolition works, tree removal and construction of an industrial and warehouse facility with parking and strata subdivision.
Date:	16/02/2023
To:	Thomas Prosser
Land to be developed (Address):	Lot 21 DP 881819 , 323 - 327 Warringah Road FRENCHS FOREST NSW 2086

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land, and located within 40 metres of land, containing a watercourse, or
- All Development Applications on land containing a wetland, or located within 100m of land containing a wetland,
- All Development Applications on land that is mapped as "DCP Map Waterways and Riparian Land".

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

Supported.

This application was assessed in consideration of:

- Supplied plans and reports;
- Relevant LEP and DCP clauses; and
- Northern Beaches Water Management for Development Policy

The site is at the headwaters of Brookvale Creek and Middle Creek. Water that leaves the site must not significantly impact on the biophysical, hydrological or ecological integrity of the creeks, or the quantity and quality of surface and ground water flows that they receive.

The proposal includes stormwater quality treatments that are appropriate for the site (see the Water Management referral for further details on water quality).

Stormwater treatment measures must be maintained at all times in accordance with manufacturer's specifications and as necessary to achieve the required stormwater quality targets for the development. Appropriate sediment and erosion controls must be installed prior to any disturbance of soil on site and maintained until all work is complete and groundcover re-established.

On assessment the application on assessment meets the requirements of the relevant Environmental Planning Instruments and policies relating to waterways, riparian areas, and groundwater.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Soil and Water Management Plan

A Soil and Water Management Plan (SWMP) shall be prepared by a suitably qualified Civil Engineer, who has membership to the Engineers Australia, National Engineers Register and implemented onsite prior to commencement. The SWMP must meet the requirements outlined in the Landcom publication Managing Urban Stormwater: Soils and Construction - Volume 1, 4th Edition (2004) and Council's Water Management for Development Policy.

The SWMP must include the following as a minimum:-

- Site boundaries and contours;
- Vehicle access points, proposed roads and other impervious areas (e.g. parking areas and site facilities)
- Location of all drains, pits, downpipes and waterways on and nearby the site;
- Planned stages of excavation, site disturbance and building;
- Stormwater management and discharge points;
- Integration with onsite detention/infiltration;
- Sediment control basin locations and volume (if proposed);
- Proposed erosion and sediment controls and their locations;
- Location of washdown and stockpile areas including covering materials and methods;
- Vegetation management including removal and revegetation;
- A schedule and programme of the sequence of the sediment and erosion control works or devices to be installed and maintained.
- Inspection and maintenance program;
- North point and scale.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To promote the long-term sustainability of ecosystem functions.

Water Quality Management

The applicant must install a filtration device (such as a sediment control pit or absorption trench) that captures organic matter and coarse sediments prior to discharge of stormwater from the land. All stormwater treatment measures must make provision for convenient and safe regular inspection, periodic cleaning, and maintenance.

Details demonstrating compliance are to be submitted to the Certifier for approval prior to the issue of the Construction Certificate.

Reason: Protection of the receiving environment.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Installation and Maintenance of Sediment and Erosion Controls

Council proactively regulates construction sites for sediment management.

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004) prior to commencement of any other works on site.

Erosion and sediment controls are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and vegetation cover has been re-established across 70 percent of the site, and the remaining areas have been stabilised with ongoing measures such as jute mesh or matting.

Reason: Protection of the receiving environment.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Removal of Sediment and Erosion Controls

Before demobilising from the site and once vegetation cover has been re-established across 70 percent of the site, the applicant is to remove all temporary sediment and erosion controls.

Any area of the site that requires ongoing stabilisation must have jute mesh or matting incorporated into the revegetated area. Mulch may be used on slopes subject to sheet flow with a gradient of no more than 1 metre in height for every 3 horizontal metres. Mulch must be laid to a depth of 50-100mm. If using mulch within two metres of the top of bank of a waterway, coir logs or similar must be placed at the downslope edge of the mulched area to prevent migration of the mulch to the waterway.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority for approval prior to the issue of the Occupation Certificate.

Reason: Protection of the receiving environment

ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

Maintenance of Stormwater Treatment Measures

Stormwater treatment measures must be maintained at all times in accordance with manufacturer's specifications and as necessary to achieve the required stormwater quality targets for the development.

Northern Beaches Council reserves the right to enter the property and carry out appropriate maintenance of the device at the cost of the property owner.

Reason: Protection of the receiving environment.