

DEVELOPMENT APPLICATION ASSESSMENT REPORT

| | |
|----------------------------|-------------|
| Application Number: | DA2021/1074 |
|----------------------------|-------------|

| | |
|---|---|
| Responsible Officer: | Nick Keeler |
| Land to be developed (Address): | Lot 7 DP 12667, 13 Ozone Parade DEE WHY NSW 2099 |
| Proposed Development: | Alterations and additions to a Dwelling House |
| Zoning: | Warringah LEP2011 - Land zoned R2 Low Density Residential |
| Development Permissible: | Yes |
| Existing Use Rights: | No |
| Consent Authority: | Northern Beaches Council |
| Land and Environment Court Action: | No |
| Owner: | Gregory John Caisley Samantha Caisley |
| Applicant: | Samantha Caisley |

| | |
|----------------------------------|---|
| Application Lodged: | 15/07/2021 |
| Integrated Development: | No |
| Designated Development: | No |
| State Reporting Category: | Residential - Alterations and additions |
| Notified: | 23/07/2021 to 06/08/2021 |
| Advertised: | Not Advertised |
| Submissions Received: | 2 |
| Clause 4.6 Variation: | Nil |
| Recommendation: | Approval |

| | |
|---------------------------------|--------------|
| Estimated Cost of Works: | \$ 33,500.00 |
|---------------------------------|--------------|

PROPOSED DEVELOPMENT IN DETAIL

The applicant seeks development consent for alterations and additions to the existing dwelling including the construction of a roof above the existing raised rear deck.

AMENDED PLANS

During assessment, Council requested the applicant revise the design of the roof to help minimise potential view impacts from adjacent properties. The design revision includes the removal of the existing gable at the rear of the dwelling and the lowering of the profile of the roof above the deck.

In accordance with the provisions of the Northern Beaches Community Participation Plan, as the amendments are considered to be minor and will result in a lesser environmental impact on nearby

properties and the public domain, re-notification of the application was not required. However, all objectors were informally notified of the amended plans and were given the opportunity to respond.

ASSESSMENT INTRODUCTION

The application has been assessed in accordance with the requirements of the Environmental Planning and Assessment Act 1979 and the associated Regulations. In this regard:

- An assessment report and recommendation has been prepared (the subject of this report) taking into account all relevant provisions of the Environmental Planning and Assessment Act 1979, and the associated regulations;
- A site inspection was conducted and consideration has been given to the impacts of the development upon the subject site and adjoining, surrounding and nearby properties;
- Notification to adjoining and surrounding properties, advertisement (where required) and referral to relevant internal and external bodies in accordance with the Act, Regulations and relevant Development Control Plan;
- A review and consideration of all submissions made by the public and community interest groups in relation to the application;
- A review and consideration of all documentation provided with the application (up to the time of determination);
- A review and consideration of all referral comments provided by the relevant Council Officers, State Government Authorities/Agencies and Federal Government Authorities/Agencies on the proposal.

SUMMARY OF ASSESSMENT ISSUES

SITE DESCRIPTION

| | |
|-----------------------------------|---|
| Property Description: | Lot 7 DP 12667 , 13 Ozone Parade DEE WHY NSW 2099 |
| Detailed Site Description: | <p>The subject site consists of one (1) allotment located on the eastern side of Ozone Parade.</p> <p>The site is regular in shape with a frontage of 17.07m along Ozone Parade and a depth of 28.04m. The site has a surveyed area of 478.6m².</p> <p>The site is located within the R2 Low Density Residential zone and accommodates a two-storey residential dwelling with a raised rear deck and an outbuilding.</p> <p>The site has a crossfall of approx. 1m from the south towards the north.</p> <p>The site contains a mostly landscaped front setback area with grass and hedging vegetation. The rear contains a large grassed area and tree.</p> <p>Detailed Description of Adjoining/Surrounding Development</p> |

Adjoining and surrounding development is characterised by low density residential dwellings, many with ancillary structures and/or outbuildings.

Map:



SITE HISTORY

The land has been used for residential purposes for an extended period of time. A search of Council's records has revealed the following relevant history:

Application **DA2004/0456** for first floor additions was approved on 23/07/2004 by Council staff.

Application **MOD2004/0456/1** for modification of development consent DA2004/0456 granted for first floor additions was approved on 10/10/2005 by Council staff.

Application **DA2005/0749** for new workshed following demolition of garage was approved on 24/10/2005 by Council staff.

ENVIRONMENTAL PLANNING AND ASSESSMENT ACT, 1979 (EPAA)

The relevant matters for consideration under the Environmental Planning and Assessment Act, 1979, are:

| Section 4.15 Matters for Consideration' | Comments |
|--|--|
| Section 4.15 (1) (a)(i) – Provisions of any environmental planning instrument | See discussion on "Environmental Planning Instruments" in this report. |
| Section 4.15 (1) (a)(ii) – Provisions of any draft environmental planning instrument | Draft State Environmental Planning Policy (Remediation of Land) seeks to replace the existing SEPP No. 55 (Remediation of Land). Public consultation on the draft policy was completed on 13 April 2018. The subject site has been used for residential purposes for |

| Section 4.15 Matters for Consideration' | Comments |
|---|--|
| | an extended period of time. The proposed development retains the residential use of the site, and is not considered a contamination risk. |
| Section 4.15 (1) (a)(iii) – Provisions of any development control plan | Warringah Development Control Plan applies to this proposal. |
| Section 4.15 (1) (a)(iia) – Provisions of any planning agreement | None applicable. |
| Section 4.15 (1) (a)(iv) – Provisions of the Environmental Planning and Assessment Regulation 2000 (EP&A Regulation 2000) | <p><u>Division 8A</u> of the EP&A Regulation 2000 requires the consent authority to consider "Prescribed conditions" of development consent. These matters have been addressed via a condition of consent.</p> <p><u>Clause 50(1A)</u> of the EP&A Regulation 2000 requires the submission of a design verification certificate from the building designer at lodgement of the development application. This clause is not relevant to this application.</p> <p><u>Clauses 54 and 109</u> of the EP&A Regulation 2000 allow Council to request additional information. Additional information was requested in relation to revised architectural plans.</p> <p><u>Clause 92</u> of the EP&A Regulation 2000 requires the consent authority to consider AS 2601 - 1991: The Demolition of Structures. This matter has been addressed via a condition of consent.</p> <p><u>Clauses 93 and/or 94</u> of the EP&A Regulation 2000 requires the consent authority to consider the upgrading of a building (including fire safety upgrade of development). This clause is not relevant to this application.</p> <p><u>Clause 98</u> of the EP&A Regulation 2000 requires the consent authority to consider insurance requirements under the Home Building Act 1989. This matter has been addressed via a condition of consent.</p> <p><u>Clause 98</u> of the EP&A Regulation 2000 requires the consent authority to consider the provisions of the Building Code of Australia (BCA). This matter has been addressed via a condition of consent.</p> <p><u>Clause 143A</u> of the EP&A Regulation 2000 requires the submission of a design verification certificate from the building designer prior to the issue of a Construction Certificate. This clause is not relevant to this application.</p> |
| Section 4.15 (1) (b) – the likely impacts of the development, including environmental impacts | <p>(i) Environmental Impact</p> <p>The environmental impacts of the proposed development on the natural and built environment are addressed under the</p> |

| Section 4.15 Matters for Consideration' | Comments |
|--|---|
| on the natural and built environment and social and economic impacts in the locality | <p>Warringah Development Control Plan section in this report.</p> <p>(ii) Social Impact The proposed development will not have a detrimental social impact in the locality considering the character of the proposal.</p> <p>(iii) Economic Impact The proposed development will not have a detrimental economic impact on the locality considering the nature of the existing and proposed land use.</p> |
| Section 4.15 (1) (c) – the suitability of the site for the development | The site is considered suitable for the proposed development. |
| Section 4.15 (1) (d) – any submissions made in accordance with the EPA Act or EPA Regs | See discussion on “Notification & Submissions Received” in this report. |
| Section 4.15 (1) (e) – the public interest | No matters have arisen in this assessment that would justify the refusal of the application in the public interest. |

EXISTING USE RIGHTS

Existing Use Rights are not applicable to this application.

BUSHFIRE PRONE LAND

The site is not classified as bush fire prone land.

NOTIFICATION & SUBMISSIONS RECEIVED

The subject development application has been publicly exhibited from 23/07/2021 to 06/08/2021 in accordance with the Environmental Planning and Assessment Act 1979, Environmental Planning and Assessment Regulation 2000 and the Community Participation Plan.

As a result of the public exhibition process council is in receipt of 2 submission/s from:

| Name: | Address: |
|--------------------------|----------------------------------|
| Mrs Kelly Nicole Taggart | 9 Ozone Parade DEE WHY NSW 2099 |
| Bruce James Mahony | 11 Ozone Parade DEE WHY NSW 2099 |

The following issues were raised in the submissions and each have been addressed below:

- View loss

The matters raised within the submissions are addressed as follows:

- *Concerns are raised the proposed deck roof will unreasonably impact upon existing view*

corridors towards the north from adjacent and nearby properties. Concern is also raised that the proposed privacy screen on the southern elevation adversely impacts upon the view corridor.

Comment:

The development originally proposed incorporating a gable-style roof was considered to cause unreasonable impact to the view corridor of Long Reef beach, Long Reef headland and other distant headlands enjoyed by dwellings to the south of the site. To help minimise view impacts, the applicant submitted a revised roof design to replace the gable element with a lower profile design. The objectors have advised they do not raise any view loss concern regarding the amended roof design.

The proposal includes the construction of a privacy screen along the southern edge of the deck to help minimise overlooking impacts of the adjacent property. While this solution is considered to appropriately mitigate privacy impacts, the screen will result in significant impact to the view corridor. Upon discussion with the southern adjacent property owner, it is considered the screen's impact upon the view corridor is more significant than the privacy protection it offers. As such, a condition is included to require deletion of the privacy screen.

REFERRALS

| Internal Referral Body | Comments |
|-----------------------------|---|
| NECC (Coast and Catchments) | <p>The subject land has been included on the 'Coastal Use Area' maps but not been included on the Coastal Vulnerability Area Map under the State Environmental Planning Policy (Coastal Management) 2018 (CM SEPP). Hence, Clauses 14 and 15 of the CM SEPP apply for this DA.</p> <p>Comment:</p> <p>As assessed in the submitted Statement of Environmental Effects (SEE) report, the DA satisfies the requirements under clauses 14 and 15 of the CM SEPP.</p> <p>As such, it is considered that the application does comply with the requirements of the State Environmental Planning Policy (Coastal Management) 2018.</p> |

ENVIRONMENTAL PLANNING INSTRUMENTS (EPIs)*

All, Environmental Planning Instruments (SEPPs, REPs and LEPs), Development Controls Plans and Council Policies have been considered in the merit assessment of this application.

In this regard, whilst all provisions of each Environmental Planning Instruments (SEPPs, REPs and

LEPs), Development Controls Plans and Council Policies have been considered in the assessment, many provisions contained within the document are not relevant or are enacting, definitions and operational provisions which the proposal is considered to be acceptable against.

As such, an assessment is provided against the controls relevant to the merit consideration of the application hereunder.

State Environmental Planning Policies (SEPPs) and State Regional Environmental Plans (SREPs)

SEPP (Coastal Management) 2018

Refer to Coast & Catchments comments for CM SEPP consideration.

Warringah Local Environmental Plan 2011

| | |
|--|-----|
| Is the development permissible? | Yes |
| After consideration of the merits of the proposal, is the development consistent with: | |
| aims of the LEP? | Yes |
| zone objectives of the LEP? | Yes |

Principal Development Standards

| Standard | Requirement | Proposed | % Variation | Complies |
|----------------------|-------------|----------|-------------|----------|
| Height of Buildings: | 8.5m | 7.4m | N/A | Yes |

Compliance Assessment

| Clause | Compliance with Requirements |
|---------------------------------|------------------------------|
| 4.3 Height of buildings | Yes |
| 6.2 Earthworks | Yes |
| 6.4 Development on sloping land | Yes |

Warringah Development Control Plan

Built Form Controls

| Built Form Control | Requirement | Proposed | % Variation* | Complies |
|----------------------------|-------------|-------------------|--------------|----------|
| B1 Wall height | 7.2m | No walls proposed | N/A | N/A |
| B3 Side Boundary Envelope | N - 4m | Within envelope | N/A | Yes |
| | S - 4m | Within envelope | N/A | Yes |
| B5 Side Boundary Setbacks | N - 0.9m | 2.0m | N/A | Yes |
| | S - 0.9m | 4.7m | N/A | Yes |
| B7 Front Boundary Setbacks | 6.5m | Behind dwelling | N/A | N/A |

| | | | | |
|---|-----|-----------------------|-----|-----|
| B9 Rear Boundary Setbacks | 6m | 7.9m | N/A | Yes |
| D1 Landscaped Open Space (LOS) and Bushland Setting | 40% | No change to existing | N/A | Yes |

***Note:** The percentage variation is calculated on the *overall* numerical variation (ie: for LOS - Divide the proposed area by the numerical requirement then multiply the proposed area by 100 to equal X, then 100 minus X will equal the percentage variation. Example: $38/40 \times 100 = 95$ then $100 - 95 = 5\%$ variation)

Compliance Assessment

| Clause | Compliance with Requirements | Consistency Aims/Objectives |
|---|------------------------------|-----------------------------|
| A.5 Objectives | Yes | Yes |
| B1 Wall Heights | N/A | N/A |
| B3 Side Boundary Envelope | Yes | Yes |
| B5 Side Boundary Setbacks | Yes | Yes |
| B7 Front Boundary Setbacks | Yes | Yes |
| B9 Rear Boundary Setbacks | Yes | Yes |
| C4 Stormwater | Yes | Yes |
| C7 Excavation and Landfill | Yes | Yes |
| C8 Demolition and Construction | Yes | Yes |
| C9 Waste Management | Yes | Yes |
| D1 Landscaped Open Space and Bushland Setting | Yes | Yes |
| D2 Private Open Space | Yes | Yes |
| D3 Noise | Yes | Yes |
| D6 Access to Sunlight | Yes | Yes |
| D7 Views | Yes | Yes |
| D8 Privacy | Yes | Yes |
| D9 Building Bulk | Yes | Yes |
| D10 Building Colours and Materials | Yes | Yes |
| D11 Roofs | Yes | Yes |
| D12 Glare and Reflection | Yes | Yes |
| D14 Site Facilities | Yes | Yes |
| D20 Safety and Security | Yes | Yes |
| E1 Preservation of Trees or Bushland Vegetation | Yes | Yes |
| E2 Prescribed Vegetation | Yes | Yes |
| E6 Retaining unique environmental features | Yes | Yes |
| E10 Landslip Risk | Yes | Yes |

THREATENED SPECIES, POPULATIONS OR ECOLOGICAL COMMUNITIES

The proposal will not significantly affect threatened species, populations or ecological communities, or their habitats.

CRIME PREVENTION THROUGH ENVIRONMENTAL DESIGN

The proposal is consistent with the principles of Crime Prevention Through Environmental Design.

POLICY CONTROLS

Northern Beaches Section 7.12 Contributions Plan 2021

As the estimated cost of works is less than \$100,001.00 the policy is not applicable to the assessment of this application.

CONCLUSION

The site has been inspected and the application assessed having regard to all documentation submitted by the applicant and the provisions of:

- Environmental Planning and Assessment Act 1979;
- Environmental Planning and Assessment Regulation 2000;
- All relevant and draft Environmental Planning Instruments;
- Warringah Local Environment Plan;
- Warringah Development Control Plan; and
- Codes and Policies of Council.

This assessment has taken into consideration the submitted plans, Statement of Environmental Effects, all other documentation supporting the application and public submissions, and does not result in any unreasonable impacts on surrounding, adjoining, adjacent and nearby properties subject to the conditions contained within the recommendation.

In consideration of the proposal and the merit consideration of the development, the proposal is considered to be:

- Consistent with the objectives of the DCP
- Consistent with the zone objectives of the LEP
- Consistent with the aims of the LEP
- Consistent with the objectives of the relevant EPIs
- Consistent with the objects of the Environmental Planning and Assessment Act 1979

It is considered that the proposed development satisfies the appropriate controls and that all processes and assessments have been satisfactorily addressed.

RECOMMENDATION

THAT Council as the consent authority grant Development Consent to DA2021/1074 for Alterations and additions to a Dwelling House on land at Lot 7 DP 12667, 13 Ozone Parade, DEE WHY, subject to the conditions printed below:

DEVELOPMENT CONSENT OPERATIONAL CONDITIONS

1. Approved Plans and Supporting Documentation

The development must be carried out in compliance (except as amended by any other condition of consent) with the following:

a) Approved Plans

| Architectural Plans - Endorsed with Council's stamp | | |
|--|--------------|--------------------|
| Drawing No. | Dated | Prepared By |
| 2102 CDC 1 Issue D - Site Plan | 25/10/2021 | B+W |
| 2102 CDC 1 Issue D - Ground Floor Plan | 25/10/2021 | B+W |
| 2102 CDC 1 Issue D - First Floor Plan | 25/10/2021 | B+W |
| 2102 CDC 1 Issue D - Elevations | 25/10/2021 | B+W |
| 2102 CDC 1 Issue D - Elevations & Section | 25/10/2021 | B+W |

| Reports / Documentation – All recommendations and requirements contained within: | | |
|---|--------------|--------------------------|
| Report No. / Page No. / Section No. | Dated | Prepared By |
| Preliminary Geotechnical Assessment (Ref: J3550) | 01/07/2021 | White Geotechnical Group |

b) Any plans and / or documentation submitted to satisfy the Conditions of this consent.

c) The development is to be undertaken generally in accordance with the following:

| Waste Management Plan | | |
|------------------------------|--------------|--------------------|
| Drawing No/Title. | Dated | Prepared By |
| Waste Management Plan | 07/07/2021 | Samantha Caisley |

In the event of any inconsistency between conditions of this consent and the drawings/documents referred to above, the conditions of this consent will prevail.

Reason: To ensure the work is carried out in accordance with the determination of Council and approved plans.

2. Prescribed Conditions

- (a) All building works must be carried out in accordance with the requirements of the Building Code of Australia (BCA).
- (b) BASIX affected development must comply with the schedule of BASIX commitments specified within the submitted BASIX Certificate (demonstrated compliance upon plans/specifications is required prior to the issue of the Construction Certificate);
- (c) A sign must be erected in a prominent position on any site on which building work, subdivision work or demolition work is being carried out:
 - (i) showing the name, address and telephone number of the Principal Certifying Authority for the work, and
 - (ii) showing the name of the principal contractor (if any) for any building work and a telephone number on which that person may be contacted outside working hours, and

- (iii) stating that unauthorised entry to the work site is prohibited.
Any such sign is to be maintained while the building work, subdivision work or demolition work is being carried out, but must be removed when the work has been completed.
- (d) Residential building work within the meaning of the Home Building Act 1989 must not be carried out unless the Principal Certifying Authority for the development to which the work relates (not being the Council) has given the Council written notice of the following information:
 - (i) in the case of work for which a principal contractor is required to be appointed:
 - A. the name and licence number of the principal contractor, and
 - B. the name of the insurer by which the work is insured under Part 6 of that Act,
 - (ii) in the case of work to be done by an owner-builder:
 - A. the name of the owner-builder, and
 - B. if the owner-builder is required to hold an owner-builder permit under that Act, the number of the owner-builder permit.

If arrangements for doing the residential building work are changed while the work is in progress so that the information notified under becomes out of date, further work must not be carried out unless the Principal Certifying Authority for the development to which the work relates (not being the Council) has given the Council written notice of the updated information.
- (e) Development that involves an excavation that extends below the level of the base of the footings of a building on adjoining land, the person having the benefit of the development consent must, at the person's own expense:
 - (i) protect and support the adjoining premises from possible damage from the excavation, and
 - (ii) where necessary, underpin the adjoining premises to prevent any such damage.
 - (iii) must, at least 7 days before excavating below the level of the base of the footings of a building on an adjoining allotment of land, give notice of intention to do so to the owner of the adjoining allotment of land and furnish particulars of the excavation to the owner of the building being erected or demolished.
 - (iv) the owner of the adjoining allotment of land is not liable for any part of the cost of work carried out for the purposes of this clause, whether carried out on the allotment of land being excavated or on the adjoining allotment of land.

In this clause, allotment of land includes a public road and any other public place.

Reason: Legislative requirement.

3. **General Requirements**

- (a) Unless authorised by Council:
Building construction and delivery of material hours are restricted to:
 - 7.00 am to 5.00 pm inclusive Monday to Friday,
 - 8.00 am to 1.00 pm inclusive on Saturday,
 - No work on Sundays and Public Holidays.

Demolition and excavation works are restricted to:

- 8.00 am to 5.00 pm Monday to Friday only.

(Excavation work includes the use of any excavation machinery and the use of jackhammers, rock breakers, excavators, loaders and the like, regardless of whether the activities disturb or alter the natural state of the existing ground stratum or are breaking up/removing materials from the site).

- (b) Should any asbestos be uncovered on site, its demolition and removal must be carried out in accordance with WorkCover requirements and the relevant Australian Standards.
- (c) At all times after the submission the Notice of Commencement to Council, a copy of the Development Consent and Construction Certificate is to remain onsite at all times until the issue of a final Occupation Certificate. The consent shall be available for perusal of any Authorised Officer.
- (d) Where demolition works have been completed and new construction works have not commenced within 4 weeks of the completion of the demolition works that area affected by the demolition works shall be fully stabilised and the site must be maintained in a safe and clean state until such time as new construction works commence.
- (e) Onsite toilet facilities (being either connected to the sewer or an accredited sewer management facility) for workers are to be provided for construction sites at a rate of 1 per 20 persons.
- (f) Prior to the release of the Construction Certificate, payment of the Long Service Levy is required. This payment can be made at Council or to the Long Services Payments Corporation. Payment is not required where the value of the works is less than \$25,000. The Long Service Levy is calculated on 0.35% of the building and construction work. The levy rate and level in which it applies is subject to legislative change. The applicable fee at the time of payment of the Long Service Levy will apply.
- (g) The applicant shall bear the cost of all works associated with the development that occurs on Council's property.
- (h) No skip bins, building materials, demolition or excavation waste of any nature, and no hoist, plant or machinery (crane, concrete pump or lift) shall be placed on Council's footpaths, roadways, parks or grass verges without Council Approval.
- (i) Demolition materials and builders' wastes are to be removed to approved waste/recycling centres.
- (j) No trees or native shrubs or understorey vegetation on public property (footpaths, roads, reserves, etc.) or on the land to be developed shall be removed or damaged during construction unless specifically approved in this consent including for the erection of any fences, hoardings or other temporary works.
- (k) Prior to the commencement of any development onsite for:
 - i) Building/s that are to be erected
 - ii) Building/s that are situated in the immediate vicinity of a public place and is dangerous to persons or property on or in the public place
 - iii) Building/s that are to be demolished
 - iv) For any work/s that is to be carried out
 - v) For any work/s that is to be demolished

The person responsible for the development site is to erect or install on or around the development area such temporary structures or appliances (wholly within the

development site) as are necessary to protect persons or property and to prevent unauthorised access to the site in order for the land or premises to be maintained in a safe or healthy condition. Upon completion of the development, such temporary structures or appliances are to be removed within 7 days.

- (l) A "Road Opening Permit" must be obtained from Council, and all appropriate charges paid, prior to commencement of any work on Council property. The owner/applicant shall be responsible for all public utilities and services in the area of the work, shall notify all relevant Authorities, and bear all costs associated with any repairs and/or adjustments as those Authorities may deem necessary.
- (m) The works must comply with the relevant Ausgrid Network Standards and SafeWork NSW Codes of Practice.
- (n) Requirements for new swimming pools/spas or existing swimming pools/spas affected by building works.
 - (1) Child resistant fencing is to be provided to any swimming pool or lockable cover to any spa containing water and is to be consistent with the following;

Relevant legislative requirements and relevant Australian Standards (including but not limited) to:

- (i) Swimming Pools Act 1992
- (ii) Swimming Pools Amendment Act 2009
- (iii) Swimming Pools Regulation 2018
- (iv) Australian Standard AS1926 Swimming Pool Safety
- (v) Australian Standard AS1926.1 Part 1: Safety barriers for swimming pools
- (vi) Australian Standard AS1926.2 Part 2: Location of safety barriers for swimming pools.
- (2) A 'KEEP WATCH' pool safety and aquatic based emergency sign, issued by Royal Life Saving is to be displayed in a prominent position within the pool/spa area.
- (3) Filter backwash waters shall be conveyed to the Sydney Water sewerage system in sewered areas or managed on-site in unsewered areas in a manner that does not cause pollution, erosion or run off, is separate from the irrigation area for any wastewater system and is separate from any onsite stormwater management system.
- (4) Swimming pools and spas must be registered with the Division of Local Government.

Reason: To ensure that works do not interfere with reasonable amenity expectations of residents and the community.

FEES / CHARGES / CONTRIBUTIONS

4. Security Bond

A bond (determined from cost of works) of \$1,000 and an inspection fee in accordance with Council's Fees and Charges paid as security are required to ensure the rectification of any damage that may occur to the Council infrastructure contained within the road reserve adjoining the site as a result of construction or the transportation of materials and equipment to and from the development site.

An inspection fee in accordance with Council adopted fees and charges (at the time of payment) is payable for each kerb inspection as determined by Council (minimum (1) one inspection).

All bonds and fees shall be deposited with Council prior to Construction Certificate or demolition work commencing, and details demonstrating payment are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

To process the inspection fee and bond payment a Bond Lodgement Form must be completed with the payments (a copy of the form is attached to this consent and alternatively a copy is located on Council's website at www.northernbeaches.nsw.gov.au).

Reason: To ensure adequate protection of Council's infrastructure.

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

5. Stormwater Drainage Disposal

The stormwater drainage systems for the development are to be designed, installed and maintained in accordance with Council's Water Management for Development Policy.

All stormwater drainage systems must comply with the requirements of Council's Water Management for Development Policy. Any recommendations identified within a Geotechnical Report relevant to the development are to be incorporated into the design of the stormwater drainage system. Details demonstrating compliance from a qualified and practising Civil Engineer and where relevant a Geotechnical Engineer must be submitted to and approved by the Certifying Authority prior to the issue of a Construction Certificate.

When the proposed discharge point for the development in this consent cannot strictly comply with the Water Management for Development Policy, the Applicant must apply to verify the proposed discharge point by gaining Council approval via a Stormwater Drainage Application. Council approval must be provided to the Certifying Authority prior to the issue of a Construction Certificate when a Stormwater Drainage Application is required. The Stormwater Drainage Application form can be found on Council's website.

Compliance with this condition must not result in variations to the approved development or additional tree removal.

Reason: To ensure satisfactory management of stormwater.

6. Amendments to the approved plans

The following amendments are to be made to the approved plans:

- The privacy screen along the southern edge of the deck must be deleted.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the construction certificate.

Reason: To ensure development minimises unreasonable impacts upon surrounding land.

7. Compliance with Standards

The development is required to be carried out in accordance with all relevant Australian Standards.

Details demonstrating compliance with the relevant Australian Standard are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure the development is constructed in accordance with appropriate standards.

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

8. Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

9. Survey Certificate

A survey certificate prepared by a Registered Surveyor is to be provided demonstrating all perimeter walls columns and or other structural elements, floor levels and the finished roof/ridge height are in accordance with the approved plans.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

Reason: To demonstrate the proposal complies with the approved plans.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

10. Stormwater Drainage Disposal Certification

Certification from an appropriately qualified and practising Civil Engineer demonstrating the stormwater drainage systems have been designed and installed in accordance with the requirements of Council's Water Management for Development Policy and where relevant a Geotechnical Engineer shall be provided to the Certifying Authority prior to the issue of an Occupation Certificate, and;

If any on site stormwater detention system is installed the Applicant shall lodge the Legal Documents Authorisation Application with Council.

The application is to include the completed request forms (NSW Land Registry standard forms 13PC and/or 13RPA) and a copy of the Works-as-Executed plan (details overdrawn on a copy of the approved drainage plan), hydraulic engineers' certification. A guide to the process and associated Legal Document Authorisation Application form can be found on Council's website. The Applicant shall create on the Title a positive covenant in respect to the ongoing maintenance and restriction as to user over the on-site stormwater detention system within this development consent.

The terms of the positive covenant and restriction are to be prepared to Council's standard requirements at the applicant's expense and endorsed by Northern Beaches Council's delegate prior to lodgement with the NSW Land Registry Services. Northern Beaches Council shall be nominated as the party to release, vary or modify such covenant. A copy of the certificate of title

demonstrating the creation of the positive covenant and restriction as to user for the on-site stormwater detention system is to be submitted.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of final Occupation Certificate.

Reason: To ensure satisfactory management of stormwater.

In signing this report, I declare that I do not have a Conflict of Interest.

Signed



Nick Keeler, Planner

The application is determined on 02/11/2021, under the delegated authority of:



Rodney Piggott, Manager Development Assessments