



Warringah Council

NOTICE OF DETERMINATION

Application Number: DA2009/0652

APPLICATION DETAILS

Applicant Name and Address: Boston Blyth Fleming Town Planners
Suite 1 9 Narabang Way
BELROSE NSW 2085

Land to be developed (Address): Lot 1 DP 836109 14 Patey Street DEE WHY

Proposed Development: Alterations and additions to Delmar Private Hospital comprising offices and associated storage and equipment rooms

DETERMINATION - APPROVED

Made on (Date): 11 September 2009

Consent to operate from (Date): 11 September 2009

Consent to lapse on (Date): 11 September 2012

Details of Conditions

The conditions, which have been applied to the consent, aim to ensure that the Environmental Impacts of Development are minimised and the Health and Safety of the community is maintained in accordance with the relevant standards and the Building Code of Australia.

NOTE:

If the works are to be certified by a Private Certifying Authority, then it is the certifier's responsibility to ensure all outstanding fees and bonds have been paid to Council prior to the issue of the Construction Certificate or as otherwise specified by Consent conditions.

Pursuant to Section 95(2) of the Environmental Planning and Assessment Act 1979, Council has varied the provisions of Section 95(1) and advise that the consent will lapse 3 years from the date upon which the consent operates.

Section 95A of the Environmental Planning and Assessment Act 1979, allows for an extension of 1 year to the period in which the consent will lapse, except for complying development. Such an application must be made in accordance with Clause 114 of the Environmental Planning and Assessment Regulation 2000.



Warringah Council

GENERAL CONDITIONS

CONDITIONS THAT IDENTIFY APPROVED PLANS

1. Approved Plans and Supporting Documentation

The development must be carried out in compliance (except as amended by any other condition of consent) with the following:

Architectural Plans - Endorsed with Council's stamp		
Drawing No.	Dated	Prepared By
050 Revision A	14/05/09	Quattro Design Pty Ltd
100 Revision B	2/07/09	Quattro Design Pty Ltd

No construction works (including excavation) shall be undertaken prior to the release of the Construction Certificate.

Reason: To ensure the work is carried out in accordance with the determination of Council and approved plans. (DACPLB01)

2. Limitation of Development Consent for Signage

Pursuant to the provisions of State Environmental Planning Policy No 64-Advertising and Signage this development consent will expire 15 years after the date on which this Development Consent becomes effective and operates

Reason: Statutory requirement under State Environmental Planning Policy No 64-Advertising and Signage.(DACPLB08)

3. Prescribed Conditions

- (a) All building works must be carried out in accordance with the requirements of the Building Code of Australia (BCA).
- (b) BASIX affected development must comply with the schedule of BASIX commitments specified within the submitted BASIX Certificate (demonstrated compliance upon plans/specifications is required prior to the issue of the Construction Certificate);
- (c) A sign must be erected in a prominent position on any site on which building work, subdivision work or demolition work is being carried out:
 - (i) showing the name, address and telephone number of the Principal Certifying Authority for the work, and
 - (ii) showing the name of the principal contractor (if any) for any building work and a telephone number on which that person may be contacted outside working hours, and
 - (iii) stating that unauthorised entry to the work site is prohibited.



Any such sign is to be maintained while the building work, subdivision work or demolition work is being carried out, but must be removed when the work has been completed.

- (d) Residential building work within the meaning of the Home Building Act 1989 must not be carried out unless the Principal Certifying Authority for the development to which the work relates (not being the Council) has given the Council written notice of the following information:
- (i) in the case of work for which a principal contractor is required to be appointed:
 - A. the name and licence number of the principal contractor, and
 - B. the name of the insurer by which the work is insured under Part 6 of that Act,
 - (ii) in the case of work to be done by an owner-builder:
 - A. the name of the owner-builder, and
 - B. if the owner-builder is required to hold an owner-builder permit under that Act, the number of the owner-builder permit.

If arrangements for doing the residential building work are changed while the work is in progress so that the information notified under becomes out of date, further work must not be carried out unless the Principal Certifying Authority for the development to which the work relates (not being the Council) has given the Council written notice of the updated information.

- (e) Development that involves an excavation that extends below the level of the base of the footings of a building on adjoining land, the person having the benefit of the development consent must, at the person's own expense:
- (i) protect and support the adjoining premises from possible damage from the excavation, and
 - (ii) where necessary, underpin the adjoining premises to prevent any such damage.
 - (iii) must, at least 7 days before excavating below the level of the base of the footings of a building on an adjoining allotment of land, give notice of intention to do so to the owner of the adjoining allotment of land and furnish particulars of the excavation to the owner of the building being erected or demolished.
 - (iv) the owner of the adjoining allotment of land is not liable for any part of the cost of work carried out for the purposes of this clause, whether carried out on the allotment of land being excavated or on the adjoining allotment of land.

In this clause, allotment of land includes a public road and any other public place.

Reason: Legislative Requirement (DACPLB09)

4. General Requirements

- (a) Unless authorised by Council:

Building construction and delivery of material hours are restricted to:
7.00 am to 5.00 pm inclusive Monday to Friday
8.00 am to 1.00 pm inclusive on Saturday,



Warringah Council

No work on Sundays and Public Holidays.

Demolition and excavation works are restricted to:
8.00 am to 5.00 pm Monday to Friday only.

(Excavation work includes the use of any excavation machinery and the use of jackhammers, rock breakers, excavators, loaders and the like, regardless of whether the activities disturb or alter the natural state of the existing ground stratum or are breaking up/removing materials from the site).

- (b) At all times after the submission the Notice of Commencement to Council, a copy of the Development Consent and Construction Certificate is to remain onsite at all times until the issue of a final Occupation Certificate. The consent shall be available for perusal of any Authorised Officer.
- (c) Where demolition works have been completed and new construction works have not commenced within 4 weeks of the completion of the demolition works that area affected by the demolition works shall be fully stabilised and the site must be maintained in a safe and clean state until such time as new construction works commence.
- (d) Onsite toilet facilities (being either connected to the sewer or an accredited sewer management facility) for workers are to be provided for construction sites at a rate of 1 per 20 persons.
- (e) Prior to the release of the Construction Certificate payment of the Long Service Levy is required. This payment can be made at Council or to the Long Services Payments Corporation. Payment is not required where the value of the works is less than \$25,000. The Long Service Levy is calculated on 0.35% of the building and construction work. The levy rate and level in which it applies is subject to legislative change. The applicable fee at the time of payment of the Long Service Levy will apply.
- (f) Smoke alarms are to be installed throughout all new and existing portions of any Class 1a building in accordance with the Building Code of Australia prior to the occupation of the new works.
- (g) The applicant shall bear the cost of all works associated with the development that occurs on Council's property.
- (h) No building, demolition, excavation or material of any nature shall be placed on Council's footpaths, roadways, parks or grass verges without Council Approval.
- (i) All permanent survey markers shall be retained, undamaged, and not relocated.

Reason: To ensure that works do not interfere with reasonable amenity expectations of residents and the community. (DACPLB10)



Warringah Council

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

5. Section 94A Contributions

The Section 94A Contributions are required to be paid for this development. This amount has been calculated using the Warringah Section 94A Development Contributions Plan. The amount will be adjusted at the time of payment according to the quarterly CPI (Sydney - All Groups Index).

The basis for the contributions is as follows:

<i>Warringah Section 94A Development Contributions Plan</i>			
Contribution based on total development cost of		\$	275,000.00
Contribution - all parts Warringah	Levy Rate	Contribution Payable	Council Code
Total S94A Levy	0.95%	\$2,613	6923
S94A Planning and Administration	0.05%	\$138	6924
Total	1.0%	\$2,750	

Details demonstrating payment are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To retain a level of service for the existing population and to provide the same level of service for the population resulting from new development. (DACPLC01)

6. Compliance with Standards

The development (where applicable) is to be carried out in accordance with relevant Australian Standards.

(Note: At the time of determination the following (but not limited to) Standards applied:

- (a) AS/NZS 2890.1:2004 Parking facilities - Off-street car parking.
- (b) AS2601.2001 - Demolition of Structures
- (c) AS4361.2 - Guide to lead paint management - Residential and commercial buildings
- (d) AS 1428.2 - 1992, Design for access and mobility - Enhanced and additional requirements - Buildings and facilities
- (e) AS4282:1997 Control of the Obtrusive Effects of Outdoor Lighting
- (f) All sound producing plant, equipment, machinery or fittings will not exceed more than 5dB(A) above the background level when measured from any property boundary and will comply with the Environment Protection Authority's NSW Industrial Noise Policy.)

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure the development is constructed in accordance with appropriate standards.(DACPLC02)



Warringah Council

7. External Colours and Materials (Industrial, Commercial, Mixed & Apartment Buildings)

(a) External Roofing

The external finish to the roof shall have a medium to dark range in order to minimise solar reflections to neighbouring properties. Light colours such as off white, cream, silver or light grey colours are not permitted.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure that excessive glare or reflectivity nuisance from glazing does not occur as a result of the development. (DACPLC04)

8. Bonds

Security Bond

- (a) A bond (determined from cost of works) of \$[2000.00] and an inspection fee paid of \$210.00 as security to ensure the rectification of any damage that may occur to the Council infrastructure contained within the road reserve adjoining the site as a result of construction or the transportation of materials and equipment to and from the development site.

(NOTE: This bond may be refunded and replaced by the Maintenance Bond upon submission to Council of the final Compliance Certificate or Subdivision Certificate.)

All bonds and fees shall be deposited with Council prior to Construction Certificate or demolition work commencing, details demonstrating payment are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate protection of Council infrastructure. (DACENC01)

9. Stormwater Disposal

Plans indicating all details relevant to the collection and disposal of stormwater from the site, buildings, paved areas and where appropriate adjacent catchments, shall be submitted prior to the issue of the Construction Certificate. The plans must indicate the provision of a rainwater tank in accordance with the approved plans. Stormwater shall be conveyed from the site to Patey Street.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure appropriate provision for disposal and stormwater management and compliance with the BASIX requirements, arising from the development. (DACENC07)



Warringah Council

10. Amended Plans

Amended plans are to be provided to the certifying authority prior to the issue of the Construction Certificate showing the following:

- a. The planter box along the western elevation of the is to be setback from the western side boundary by a minimum of 0.1m

Reason: *To ensure that the proposed development does not adversely impact upon the adjoining property.*

CONDITIONS THAT MUST BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

11. Trees

- (1) Tree roots of 50mm or greater in diameter encountered during excavation, shall only be cut following consultation with a qualified Arborist. Tree roots between 10mm and 50mm in diameter, severed during excavation, shall be cut cleanly by hand.

Reason: *Protection of trees.*

- (2) The following guidelines are to be complied with at all times:
 - (a) The applicant shall ensure that at all times during the development period no activities, storage or disposal of materials shall take place beneath the canopy of any tree covered under Council's Tree Preservation Order unless specifically approved by Council.
 - (b) Trees marked for retention are not to be damaged or used to display signage, or as fence or cable supports for any reason.
 - (c) Siting of sheds, stockpiles and vehicle parking should be sited so that they are remote from trees.
 - (d) Site personnel are to be made aware of tree requirements and protective measures. Paving materials placed within the dripline of any tree should be of a porous material.

Reason: *Protection of trees.*

- (3) During the construction period the applicant is responsible for ensuring all protected trees are maintained in a healthy and vigorous condition. This is to be done by ensuring that all identified tree protection measures are adhered to. In this regard all protected plants on this site shall not exhibit:
 - (a) A general decline in health and vigour.
 - (b) Damaged, crushed or dying roots due to poor pruning techniques.
 - (c) More than 10% loss or dieback of roots, branches and foliage.
 - (d) Mechanical damage or bruising of bark and timber of roots, trunk and branches.
 - (e) Yellowing of foliage or a thinning of the canopy untypical of its species.
 - (f) An increase in the amount of deadwood not associated with normal growth.
 - (g) An increase in kino or gum exudation.



Warringah Council

- (h) Inappropriate increases in epicormic growth that may indicate that the plants are in a stressed condition.
- (i) Branch drop, torn branches and stripped bark not associated with natural climatic conditions.

The presence of any of these symptoms or signs may be considered by Council as a breach of the Conditions of Development Approval.

Reason: *Protection of trees.*

- (4) All trees on neighbouring properties are to be protected from adverse impacts caused by the works. Any excavations or changes of level occurring within the canopy of trees on neighbouring properties shall only be undertaken following consultation by a suitably qualified Arborist.

Any mitigating measures and recommendations required by the Arborist are to be implemented.

The owner of the adjoining allotment of land is not liable for the cost of work carried out for the purpose of this clause.

Reason: *Protection of trees.*

12. Tree Pruning

Any tree pruning necessary for construction shall be carried out under the supervision of an appropriately qualified Arborist and be in accordance with the relevant Australian Standards.

Note: The following Australian Standard applied at the time of determination:

- Australian Standard AS 4373.2007 - Pruning of Amenity Trees.

Reason: *To ensure protection and longevity of existing trees.*

13. Installation and Maintenance of Sediment Control

Measures used for erosion and sediment control on building sites are to be adequately maintained at all times and must be installed in accordance with Warringah Council Specifications for Erosion and Sediment Control. All measures shall remain in proper operation until all development activities have been completed and the site fully stabilised.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

Reason: To protect the environment from the effects of sedimentation and erosion from development sites.(DACPLE02)



Warringah Council

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO ISSUE OF OCCUPATION CERTIFICATE

14. Required Planting

The tree/s listed in the following Schedule shall be planted prior to the issue of an Interim/Final Occupation Certificate.

Schedule

Tree Species	Location	Pot Size
Shade tolerant native species such as lilly pilly capable of attaining a min height of 3m	Western boundary adjacent to the new building. Min 2m centres	25 ltr

Reason: To maintain environmental amenity

15. Removal of All Temporary Structures/Material and Construction Rubbish

Once construction has been completed all silt and sediment fences, silt, rubbish, building debris, straw bales and temporary fences are to be removed from the site.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To ensure bushland management. (DACPLF01)

16. Fire Safety Matters

At the completion of all works, a Fire Safety Certificate will need to be prepared which references all the Essential Fire Safety Measures applicable and the relative standards of Performance (as per Schedule of Fire Safety Measures). This certificate must be prominently displayed in the building and copies must be sent to Council and the NSW Fire Brigade.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Interim / Final Occupation Certificate.

Each year the Owners must send to the Council and the NSW Fire Brigade an annual Fire Safety Statement which confirms that all the Essential Fire Safety Measures continue to perform to the original design standard.

Reason: Statutory requirement under Part 9 Division 4 & 5 of the Environmental Planning and Assessment Regulation 2000.
(DACPLF07)



Warringah Council

17. Stormwater Disposal

The stormwater drainage works shall be certified as compliant with all relevant Australian Standards and Codes by a suitably qualified person.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

(Note: The following Standards and Codes applied at the time of determination:

- a) Australian/New Zealand Standard AS/NZS 3500.3:2003 - Plumbing and drainage - Stormwater drainage
- b) Australian/New Zealand Standard AS/NZS 3500.3:2003/Amdt 1:2006 - Plumbing and drainage - Stormwater drainage
- c) National Plumbing and Drainage Code.)

Reason: To ensure appropriate provision for the disposal of stormwater arising from the development. (DACENF05)

Right to Review by the Council

You may request Council review the determination of the application under Section 82A of the Environmental Planning & Assessment Act 1979 if it is NOT integrated or designated development. Any request to review the application must be made and determined within 12 months from the date of determination.

NOTE: A fee will apply for any request to review the determination.

Right of Appeal

If you are dissatisfied with this decision Section 97 of the Environmental Planning & Assessment Act 1979 may give you the right to appeal to the Land and Environment Court within 12 months after the date on which you receive this notice.

Signed _____ on behalf of the consent authority

Signature _____
Name Adrian Melo
Development Assessment Officer

Date 11 September 2009