

Natural Environment Referral Response - Riparian

Application Number:	DA2019/0922
To:	Thomas Burns
Land to be developed (Address):	Lot G DP 396772 , 19 Waterview Street MONA VALE NSW 2103

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land, and located within 40 metres of land, containing a watercourse, or
- All Development Applications on land containing a wetland, or located within 100m of land containing a wetland,
- All Development Applications on land that is mapped as "DCP Map Waterways and Riparian Land".

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

This application has been assessed against:

- Pittwater LEP
- Pittwater 21 DCP B5.8 Water Quality and B8.2 Sediment and Erosion Controls

The application proposes to increase impervious surfaces by more than 50m² therefore water quality controls apply.

This application is recommended for approval subject to conditions.

Referral Body Recommendation

Recommended for approval, subject to conditions

Recommended Natural Environment Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Water Quality - Low Density Residential

To comply with Pittwater 21 DCP B5.8, the applicant must install stormwater quality improvement measures as follows:

- Pre-screening of organic matter (eg. leaf litter) prior to the collection of rainwater in the rainwater tank

- filtration of stormwater to capture organic matter and coarse sediments prior to discharge from the land.

Provision must be made for maintenance access.

Details demonstrating compliance are to be submitted to the Certifying Authority for approval prior to the issue of the Construction Certificate.

Reason: Protection of the receiving environment

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004).

Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site.