

## Engineering Referral Response

Application Number:	DA2019/0354
To:	Kye Miles
Land to be developed (Address):	Lot 1 DP 778031 , 712 A Barrenjoey Road AVALON BEACH NSW 2107

### Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m2 or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

### Officer comments

The subject site is burdened by a Council drainage easement and pipelines. In this regard, the applicant is required to demonstrate compliance with Pittwater Council's Pittwater 21 DCP 2014 Clause B5.12 Stormwater Drainage Systems and Natural Watercourses, Structures Over and Adjacent to Easements, Piped Drainage System or Natural Watercourses . This consists of accurately locating, confirming dimensions and plotting Council's stormwater pipelines and associated infrastructure to scale on the DA plans which show the proposed works. This should be carried out by a service locating contractor and registered surveyor. (The applicant will need to provide evidence of methodology used for locating).

The applicant can view Council's stormwater maps by following the below instructions.

Northern Beaches Council has public stormwater drainage maps online. Please follow the relevant link below and select the 'Stormwater' map from the 'No Overlay Map' drop down menu. You can then search by address and use the zoom functionality to see pipe diameters and asset id numbers.  
<https://services.northernbeaches.nsw.gov.au/icongis/index.html>

### THIS INFORMATION IS PROVIDED UNDER THE FOLLOWING CONDITIONS:

The information shown on the stormwater drainage map is indicative only and outlines the approximate locations of Council-owned stormwater infrastructure according to Council's records. Please note that there may be drainage assets in place that Council do not have records of, or infrastructure that has been upgraded, replaced or removed since this information was recorded.

Confirmation of the location and condition of the infrastructure and/or easements should be obtained prior to any of the following being carried out:

- (a) construction work; or

DA2019/0354

- (b) design work; or
- (c) purchase of the property; or
- (d) other actions relevant to Council stormwater infrastructure.

Northern Beaches Council does not warrant that the data does not contain errors. Northern Beaches Council shall be in no way liable for any loss, damage or injury as a result of the use of this data. Northern Beaches Council has the copyright of this data and it should not be passed on to anyone, without the consent of Northern Beaches Council's Stormwater Assets Engineer or Stormwater Assets Technician.

Development Engineers cannot support the application due to insufficient information to assess the impact upon Council's Stormwater Assets in accordance with Clause B5.12 of Pittwater 21 DCP 2014.

#### **Additional information received 24/05/2019**

The submitted plan identifying the location of Council's stormwater line with respect to the proposed development works addresses Council's requirements. The proposal will not require OSD and the existing driveway access is to remain which is satisfactory. No objection to approval, subject to conditions as recommended.

#### **Referral Body Recommendation**

Recommended for approval, subject to conditions

#### **Refusal comments**

#### **Recommended Engineering Conditions:**

### **FEES / CHARGES / CONTRIBUTIONS**

#### **Construction, Excavation and Associated Works Bond (Drainage)**

A Bond of \$5,000 as security against any damage to Council's Stormwater drainage infrastructure as part of this consent.

Reason: Protection of Council's Infrastructure.

### **CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE**

#### **Stormwater Disposal**

A drainage plan in accordance with the requirements of section 3.1.2 Drainage of the Building Code of Australia Housing Provision and AS/NZS 3500.3.2:1998 - Stormwater Drainage – Acceptable solutions are to be submitted and certified by an appropriately qualified and practicing Civil Engineer, indicating all details relevant to the collection and disposal of stormwater from the proposed building. Stormwater shall be conveyed from the site to the kerb in Barrenjoey Road.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority for approval prior to the issue of the Construction Certificate.

Reason: To ensure appropriate provision for disposal and stormwater management arising from the development.

**Structures Located Adjacent to Council Pipeline or Easement**

All structures are to be located clear of any Council pipeline or easement. Footings of any structure adjacent to an easement or pipeline are to be designed in accordance with Council's Pittwater 21 DCP 2014 Clause B5.12. A statement of compliance is to be prepared by a suitably qualified Structural Engineer and submitted to Council for approval. The approval from Council is to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: Protection of Council's Infrastructure.

**Pre-Construction Stormwater Assets Dilapidation Report**

A pre-construction / demolition Dilapidation Survey of Council's Stormwater Assets is to be prepared by a suitably qualified person in accordance with Council's Guidelines for Preparing a Dilapidation Survey of Council Stormwater Asset, to record the existing condition of the asset prior to the commencement of works. Council's Guidelines are available at:

<https://files.northernbeaches.nsw.gov.au/sites/default/files/documents/general-information/engineering-specifications/2009084729guidelineforpreparingadilapidationsurveyofcouncilstormwaterassets2.pdf>

The pre-construction / demolition dilapidation report must be submitted to Council for approval and the Council approval issued to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: Protection of Council's Infrastructure.

**CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK****Certification of Structures Located Adjacent to Council Pipeline or Council Easement**

All structures are to be located clear of any Council pipeline or easement. Footings of any structure adjacent to an easement or pipeline are to be designed in accordance with Council's Pittwater 21 DCP 2014 Clause B5.12.

A statement of compliance is to be prepared by a suitably qualified Structural Engineer and submitted to Council and Council's acceptance of the certification is to be submitted to the Certifying Authority prior to the issue of the Occupation Certificate.

Reason: Protection of Council's Infrastructure.

**Maintenance of Road Reserve**

The public footways and roadways adjacent to the site shall be maintained in a safe condition at all times during the course of the work.

Reason: Public Safety.

**Protection of Adjoining Property - Excavation**

Where excavations extend below the level of the base of the footings of a building or Council asset on the lot or an adjoining allotment of land, the person causing the excavation must preserve and protect the building and asset from damage and, if necessary, underpin and support the adjoining building or asset in an approved manner.

Reason: To ensure private and public safety.

**CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE  
OCCUPATION CERTIFICATE**

**Stormwater Disposal**

The stormwater drainage works shall be certified as compliant with all relevant Australian Standards and Codes by a suitably qualified person. Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To ensure appropriate provision for the disposal of stormwater arising from the development.

**Certification of Structures Located Adjacent to Council Pipeline or Council Easement**

All structures are to be located clear of any Council pipeline or easement. Footings of any structure adjacent to an easement or pipeline are to be designed in accordance with Council's Pittwater 21 DCP 2014 Clause B5.12.

A statement of compliance is to be prepared by a suitably qualified Structural Engineer and submitted to Council and Council's acceptance of the certification is to be submitted to the Certifying Authority prior to the issue of the Occupation Certificate.

Reason: Protection of Council's Infrastructure.

**Post-Construction Dilapidation Survey**

A post-construction Dilapidation Survey of Council's Stormwater Assets is to be prepared by a suitably qualified person in accordance with Council's Guidelines for Preparing a Dilapidation Survey of Council Stormwater Asset in order to determine if the asset has been damaged by the works. Council's Guidelines are available at

<https://files.northernbeaches.nsw.gov.au/sites/default/files/documents/general-information/engineering-specifications/2009084729guidelineforpreparingadilapidationsurveyofcouncilstormwaterassets2.pdf>

The post construction dilapidation report must be submitted to the Council for review and Council's acceptance of the report issued to the Principal Certifying Authority prior to the issue of the Occupation Certificate. Any damaged to Council's stormwater infrastructure is to be rectified in accordance with Council's technical specifications prior to the release of the security bond.

Reason: Protection of Council's Infrastructure.